



# **Saskatoon Light & Power Inventory Catalogue**

**Revised January 23, 2025**

# Product Approval and Inclusion Process for Saskatoon Light & Power Catalogue

At the City of Saskatoon – Saskatoon Light & Power, we are always on the lookout for innovative and high-quality products to enhance our catalogue and better serve our customers. If you have a product that you believe aligns with an item in our catalogue, then we encourage you to follow the steps below for product approval:

## **1. Product Submission:**

- a. Please prepare a comprehensive product proposal that includes detailed information about your product such as features, specifications, and any relevant certifications.
- b. Attach high-quality images or product renders that showcase the product from different angles.

## **2. Compliance and Certification:**

- a. Ensure that your product complies with industry standards and regulations.
- b. If applicable, include any certifications or test reports that demonstrate the product's safety and quality.

## **3. Contact Information:**

- a. Include your complete contact information including the name, email address, and phone number of a dedicated representative we can reach out to for further discussion.

## **4. Samples for Evaluation:**

- a. If possible, offer product samples for our team to evaluate the quality, functionality, and overall appeal of your product.

Please submit the above information to [saskatoon.light.power@saskatoon.ca](mailto:saskatoon.light.power@saskatoon.ca) with the subject line 'Inventory Catalogue Submission for Review', and our team will carefully review your proposal. We appreciate your interest in partnering with Saskatoon Light & Power and look forward to the possibility of adding your products to our catalogue.

# TABLE OF CONTENTS

Index.....	iii
Supplier's Codes .....	vii
<b>Section 1 Pole Line Hardware .....</b>	<b>1 – 1</b>
Anchors	
Bolts	
Braces And Brackets	
Washers	
Guy Wire	
<b>Section 2 Wire / Cable / Cutouts, etc. ....</b>	<b>2 – 1</b>
Clamps & Grips	
Lubricant	
Cutouts and Arrestors	
Insulators	
Wire & Cable	
<b>Section 3 Distribution Poles .....</b>	<b>3 – 1</b>
Wood Poles	
Steel Poles	
Fibreglass Poles	
<b>Section 4 Street Lighting .....</b>	<b>4 – 1</b>
Refractors	
Ballasts	
Fixtures & Lamps	
Streetlight Poles & Arms	
Photo Electric Cells	
<b>Section 5 Connectors .....</b>	<b>5 – 1</b>
Connectors	
Compression Sleeves	
Bolted Lugs	
<b>Section 6 Transformers.....</b>	<b>6 – 1</b>
Padmount Transformers	
Switching Cubicles	
Concrete Bases	
Elbows & Accessories	
Overhead Transformers	

# TABLE OF CONTENTS

<b>Section 7</b>	<b>Fusing &amp; Splicing.....</b>	<b>7 – 1</b>
	Transformer Bushings	
	Fuses	
	Tape	
	Markers	
	Solder	
	Kellems Grips	
	Stress Cone Kits	
	Underground – Splice Parts	
	Heat Shrink	
<b>Section 8</b>	<b>Switchgear &amp; Metering.....</b>	<b>8 – 1</b>
	Relay	
	Meter Seals	
	Current Transformers	
	Test Blocks	
<b>Section 9</b>	<b>Ducts, Grounding, Cable Injection &amp; Miscellaneous.....</b>	<b>9 – 1</b>
	Pipe Straps	
	Duct Pipe	
	Anchors	
	Capacitors	
	Locks	
	Bandit	
	Grounding	
	Ty-Wraps	
	Gloves & Mitts	
<b>Section 10</b>	<b>Clothing.....</b>	<b>10 – 1</b>
	FR Pullover Top	
	FR Button Up Top	
	FR Work Pants	
	FR Cargo Pants	
	FR Coveralls (Lined and Unlined)	
	FR Bid Overalls (Lined and Unlined)	
	FR Hooded Fleece	
	FR Winter Jacket	
	FR Rain Overalls	
	FR Rain Jackets	
	FR Balaclava/ Neck Gaiter/ Toque	
	FR Hard Hat Liner	



# TABLE OF CONTENTS

<b>Section 11</b>	<b>Landfill Gas Generation .....</b>	<b>11 – 1</b>
	Service Items	
	Ignition System	
	Coolant System	
	Turbo Exhaust	
	Fuel Train	
	General Engine	
	Engine Controls	
	Starter	

# INDEX

## ADAPTERS

Base Plate for Steel Pole .....	4-13
Interbase Low Profile.....	8-12
Socket.....	8-12
Steel Pole Tenon .....	4-13

<b>AGS UNIT</b> .....	2-5
-----------------------	-----

<b>AMFACTS</b> .....	5-6-7
----------------------	-------

## ANCHORS

Pole Key.....	1-2
Drop In.....	9-8
Helix.....	1-1
Rod.....	1-1

## ARMS (see Street Lighting)

<b>ARMOUR RODS</b> .....	2-24
--------------------------	------

<b>ARRESTORS</b> .....	2-13
------------------------	------

<b>AQUASEAL</b> .....	7-22
-----------------------	------

<b>BALLASTS</b> .....	4-31
-----------------------	------

<b>BANDIT &amp; BUCKLES</b> .....	9-12
-----------------------------------	------

<b>BANNER HARDWARE</b> .....	4-32
------------------------------	------

## BASES

Break Away Reaction Plates.....	4-14
Concrete .....	6-10-12
Decorative .....	4-1,9
Fiberglass .....	6-10,21
Mounting for Epoxy Crossarm .....	1-8
Precast Streetlight .....	4-1
Precast Switching Cubicle .....	6-11
Precast Transformer .....	6-10
Steel Anchor.....	4-1

<b>BAYONET</b> .....	1-8
----------------------	-----

<b>BOLLARDS</b> .....	1-2
-----------------------	-----

## BOLTS

Carriage.....	1-3-4
Double Arming .....	1-3
Lag .....	1-6
Machine.....	1-4-6

## BRACES

Alley Arm .....	1-7
Angle Arm .....	1-7
Cross Arm.....	1-8

## BRACKETS

Bullhorn .....	4-12
Cable Support.....	7-25
Decorative Backing.....	4-11

## BRACKETS – continued

Kellems Grip Mounting.....	7-25
Mid-Span Triplex.....	1-9
Network .....	1-22-23
Standoff .....	1-9
Transformer Mounting.....	1-9

<b>BRAID</b> .....	7-20
--------------------	------

<b>BULL LINE</b> .....	2-7
------------------------	-----

<b>BUMPER POST</b> .....	1-2
--------------------------	-----

<b>BUSHING WELL</b> .....	6-23
---------------------------	------

<b>BUSHING WELL INSERTS</b> .....	6-18
-----------------------------------	------

## BUSHINGS

Adapter .....	6-19
One Piece.....	6-23
Standoff .....	6-21
Transformer .....	7-2

<b>CABINETS</b> .....	6-21
-----------------------	------

<b>CABLE</b> .....	2-26-37
--------------------	---------

## CABLE SUPPORTS

Kellems.....	7-26
--------------	------

<b>CADWELD CARTRIDGES</b> .....	7-23
---------------------------------	------

<b>CAPACITOR BANKS</b> .....	9-10
------------------------------	------

<b>CAPACITOR UNITS</b> .....	9-9
------------------------------	-----

## CAPS

Protective.....	6-22
Photo Cell Shorting.....	4-27-28

<b>CINCH TIES &amp; TY-WRAPS</b> .....	9-15-16
--	---------

## CLAMPS

Bonding Jumper.....	5-6
Cable Cleats .....	2-20-21
Ground Rod .....	2-5
Guy .....	1-14
Hot Line.....	2-7
Deadend Strain.....	2-3
Service Wedge.....	2-2
Suspension .....	2-5

<b>CLEVISES</b> .....	1-10
-----------------------	------

## COLD SHRINK

Splice .....	7-31-32
--------------	---------

## COMPOUNDS

Splicing.....	2-7
---------------	-----

## CONNECTORS

Ampact.....	5-6-7
Bolted.....	5-20

# INDEX

## CONNECTORS - continued

Buchanan.....	5-15
Compression .....	5-18-20
GelCap .....	5-14
Parallel, Groove, Compression .....	5-1-4
Shearbolt .....	5-17-18
Sleeves .....	5-8-15
Split Bolt .....	5-4-5
Station .....	5-21-22
Stirrup .....	5-7-8
Two Bolt .....	5-5
Type "T" .....	5-20

<b>CONTACTORS</b> .....	4-29
Coils .....	4-29

## COUPLINGS

Ground Rod.....	2-6
-----------------	-----

## COVERS

Meter Blankoff.....	8-11
---------------------	------

<b>CROSSARMS</b> .....	1-10-11
------------------------	---------

<b>CURRENT TRANSFORMERS</b> .....	8-12-14
-----------------------------------	---------

<b>CUTOUTS</b> .....	2-9-10,13
----------------------	-----------

<b>DAMPERS</b> .....	2-26
----------------------	------

## DEADENDS

Automatic.....	2-2
Compression .....	2-1-2

## DUCT

Bellend.....	9-5
Bends.....	9-3-4
Couplings.....	9-5-6
Pipe .....	9-2-3,7
Spacers .....	9-6

<b>DUPLEX</b> .....	2-29
---------------------	------

<b>DUXSEAL</b> .....	7-22
----------------------	------

<b>ELBOWS &amp; ACCESSORIES</b> .....	6-15-23
---------------------------------------	---------

## EXTENSIONS

Steel Streetlight Pole.....	4-14
-----------------------------	------

<b>FAULT INDICATORS</b> .....	6-13-15
-------------------------------	---------

<b>FEED-THROUGHS</b> .....	6-19-20
----------------------------	---------

<b>FIBRE OPTIC CABLE</b> .....	2-36-37
--------------------------------	---------

## FITTINGS

Ball Clevis .....	1-13
Clevis – Clevis.....	2-1
Guy .....	1-14-16
Socket Eye .....	1-12
Clevis Socket .....	1-12
Y Clevis .....	1-13

<b>FIXTURES</b> .....	4-16-24
-----------------------	---------

## FR CLOTHING

FR Balaclava.....	10-10
FR Cargo Pants Men's.....	10-3-4
FR Cargo Pants Women's .....	10-4-5
FR Hard Hat Liner.....	10-10
FR Hooded Fleece .....	10-8
FR Lined Bib Overalls.....	10-8
FR Neck Gaiter .....	10-10
FR Rain Jackets .....	10-10
FR Rain Overalls .....	10-9-10
FR Shirts Buttoned Men's .....	10-2
FR Shirts Buttoned Women's.....	10-2
FR Shirts Pullover Men's .....	10-1
FR Shirts Pullover Women's.....	10-1
FR Unlined Bib Overalls .....	10-7
FR Unlined Coveralls .....	10-6-7
FR Winter Jacket .....	10-9
FR Work Pants Men's .....	10-3
FR Work Pants Women's .....	10-3-4

## FUSES

Elbow.....	7-14
Ferrule.....	7-15
Knife Blade.....	7-16
Limiting .....	7-17-18
Network .....	7-18-19
Neutral Link.....	7-15
Padmount.....	7-6-11
Plug.....	7-14
Power.....	7-12-13
PT.....	7-16
Switching Cubicle.....	7-13
Type K.....	7-2-3
Type T.....	7-4
Types H, X, F.....	7-5

<b>GEL CAPS</b> .....	5-14
-----------------------	------

# INDEX

## GLOBES

Washington Fixtures ..... 4-32

**GLOVES** ..... 9-17-18

## GRIPS

Preformed Deadend..... 2-3-4

Preformed Guy..... 1-14

**GROUND ROD** ..... 2-6

**GROUNDING MATERIAL** ..... 9-13-14

**GUARDS**..... 1-16

**HANDI-RING** ..... 8-11

## HEAT SHRINK

Splice..... 7-30

**HEATER CABINET** ..... 9-12

## HOOKS

Cable Hangers ..... 7-26

Hooks & Arms for U/G Cable Rack 1-17-18

## INSULATORS

Ball and Socket ..... 2-16

Cable Rack ..... 2-21

Clevis ..... 2-15

Epoxy Deadend..... 2-17

Fiberglass Guy Strain..... 1-27

Guy Strain ..... 2-15

Indoor Switching Cubicle ..... 2-22

Phase Conduction Spacing..... 2-17

Pin Type..... 2-14

Polymer..... 2-17-18

Post..... 2-18-20

Station Post ..... 2-19-19

Suspension ..... 2-16

Triplex Spreader Block ..... 2-22

**JUNCTION BOX**..... 6-13

**LAMPS** ..... 4-25-26

## LANDFILL GAS GENERATION

Coolant System ..... 11-6-10

Engine Controls..... 11-15-16

Fuel Train..... 11-12-14

General Engine..... 11-14-15

General Sensors..... 11-3

## LANDFILL GAS GENERATION continued

Ignition System..... 11-4-6

Oil System ..... 11-4

Service Items ..... 11-1-3

Turbo Exhaust..... 11-11-12

**LOCKS** ..... 9-11

## LUBRICANTS

Cable Pulling ..... 2-8

Switch Contact..... 2-8

Termi Kit ..... 2-8

## LUGS

Bolted..... 5-16-17

Compression ..... 5-18-20

**MAN HOLE** ..... 7-23

## MARKERS

Cable Tags ..... 7-21

Omni Balls Red..... 7-21

Phase..... 7-21

**MITTS** ..... 9-18

## MOULDING

Ground Wire ..... 2-22

## NUTS

Galvanized ..... 1-24, 26

Eye ..... 1-19

Lock ..... 1-20

Pisa..... 1-1

Thimble Eye..... 1-19

**OIL SWITCHES**..... 2-23 & 4-29

**PADLOCKS** ..... 9-11

**PEDESTALS** ..... 6-12-13

**PHOTO ELECTRIC CELLS** ..... 4-27-28

Bracket..... 4-28

Shorting Cap ..... 4-27-28

## PINS

Insulator ..... 1-20-21

## PIPE

Bends ..... 9-3-4

Cement/Primer..... 9-7

Duct ..... 9-2-3

# INDEX

## PIPE - continued

Galvanized .....	9-2
HDPE .....	9-2-3
Sceptacon .....	9-7
Spacers .....	9-6
Straps.....	9-1

## PLASTIC LATCH..... 7-6

## POLES (DISTRIBUTION)

Steel.....	3-1-2
Fiberglass.....	3-2
Wood.....	3-1

## POTENTIAL TRANSFORMERS..... 8-15

## PREFORMED

Armour Rod .....	2-24
Composite .....	2-25
Plastic Line.....	2-24
Super Top Ties.....	2-25

## PRIMARY METERING UNIT ..... 8-17 |

## PYROTENAX CLIPS ..... 9-1 |

## QUADRIplex..... 2-29

## RACKS ..... 1-21-22 |

## REFRACTORS

Wallpack Fixtures .....	4-32
-------------------------	------

## RELAY FEEDER ..... 8-1 |

## RISERS

Fibreglass .....	1-17
Plastic.....	1-17

## SEALS

Meter .....	8-10
Padlock.....	8-11

## SLEEVES

Compression .....	5-8-15
Guy Wire Serving .....	1-14

## SOCKETS

Pig Tail.....	4-27
---------------	------

## SPLICE KITS

Grounding Sock .....	7-32
Underground .....	7-28

## STAPLES

Moulding.....	1-24
---------------	------

## STREET LIGHTING

Arms .....	4-3-6,8-12
Hand Hole Assembly.....	4-15
Poles.....	4-2-10
Pole & Fixture Combination.....	4-22
Relays .....	4-28
Shims .....	1-27
Weatherheads.....	4-30

## STRESS CONE KITS ..... 7-24-25 |

## SWITCHES

Oil .....	2-23 & 4-29
Three Phase Group Operated.....	2-11-12

## SWITCHING CUBICLES..... 6-8-9

## TAPE..... 7-20 |

## TEST BLOCKS ..... 8-16-17 |

## THIMBLE

Eye .....	1-19
-----------	------

## TRANSFORMERS

Cluster Mount Assembly .....	1-9
Dry Type.....	8-16
Overhead.....	6-23-28
Padmount.....	6-1-8

## TRIPLEX ..... 2-29 |

## TY-WRAPs & CINCH TIES ..... 9-15-16 |

## WASHERS ..... 1-24-26 |

## WIRE




Guy .....	1-27
Metering.....	2-35
Streetlight.....	2-33

# SUPPLIER CODES


AB .....	AB Chance	EK.....	Ekstrom
ABB.....	ABB Inc.	EE .....	English Electric
AC .....	Acculite	ELMD.....	Elasimold
ACME .....	Acme	ENE .....	Enerscan
AE.....	American Electric	EPAC.....	EPAC
AL.....	Aim Lite		
ALUM .....	Alumaform		
AMP .....	Ampact	FAN .....	Fanner
ANSI.....	ANSI	FAR .....	Fargo
AP .....	Atlas Power	FED-P.....	Federal Pioneer
		FER.....	Ferraz
		FER-P .....	Ferranti-Packard
		FP.....	Fisher Pierce
B&T .....	Bearing & Transmission		
BAND.....	Band-It		
BEL .....	Beline Manufacturing		
BEM .....	Bemag	GE.....	General Electric
BET .....	Bethea	GLD.....	Gould
BEV .....	Bevro	GLP .....	GLP HiTech
BLK .....	Blackburn	GRNL .....	Greenlee
BM.....	Bren Maur	GST&D.....	General Switchgear GST&D
BRO.....	Brooks		
BUCH.....	Buchanan		
BUR.....	Burndy	HA .....	Hastings
BUSS .....	Buss	HCI.....	HCI Lighting
		HEL .....	Helix
		HOL.....	Holophane
		HOM.....	Homac
		HU .....	Hughes Bros
		HUB.....	Hubbel
		HYD .....	Hydel
CAD.....	Cadweld		
CAN.....	Canron	IBV .....	Iberville
CAB.....	Cablelim	IDI .....	Ideal Electric Industries
CAR.....	Carlton	ILS.....	ILSCO
CC.....	Cross Canada	INT .....	Intermatic
CG .....	Condu-Grip	INV .....	Inventronics
CGE .....	Canadian General Electric	IPEX.....	IPEX
CH .....	Cutler Hammer		
CIM .....	CIM		
CLM .....	CLM Industries		
CON.....	Continental(Maclean Power)		
COND.....	Condux International		
CP .....	Cooper Power		
		JOS .....	Joslyn
		JSNA .....	JS Hardware North America
DG .....	DG Technologies Ltd.		
DIV .....	Diversified		
DIX.....	Dixie		
DL.....	Dura-Line	KAB.....	Kabar
DULM .....	Dulmison	KEE .....	Keene
		KELL.....	Kellems
		KL.....	K-Line
		KRN.....	Kearney
EWC .....	Eastern Wire & Conduit		




# SUPPLIER CODES




LAND.....	Landmark	RIC.....	Richards
LAPP.....	LAPP	RTE.....	Raychem/Tyco
LAR.....	Larson		
LED.....	LED Roadway Lighting		
LITH.....	Lithonia		
		S&C.....	S & C Electric
		SAFT.....	Soft Nife Corp
		SAL.....	Salisbury
MAC P.....	Macleam Power	SANG.....	Sangamo
MAR.....	Martec	SB.....	Safety Base
MARC.....	Marcus	SCEP.....	Sceptor
MER.....	Mersen	SCT.....	Structural Composite Technologies
MOL.....	Moloney	SDL.....	SDL Lighting
MULT.....	Multicast	SED.....	Sediver
		SG.....	Structural Glass (SCT)
		SHAW.....	Shawmut
		SL.....	Slater or Slacan
NAT.....	National	SMW.....	Saskatoon Machine Works
NED.....	Nedco	SOLA.....	Sola
NEX.....	Nexans	SQ D.....	Square D
NGK.....	NGK Insulators	SS.....	Safety Supply
NOR.....	Nordic	STAN.....	Standard Products
		STAR.....	Star
		STERN.....	Sternberg
OB.....	Ohio Brass (Hubbell Power)	STO.....	Stopaq
		SUPC.....	Support Concepts
		SW.....	Saskatoon Welding
		SYC.....	Sycor
		SYL.....	Sylvania
P&C.....	Patton & Cooke	T&B.....	Thomas & Betts
PAND.....	Panduit	TE.....	TE Connectivity
PAY.....	Payer	TORK.....	Tork
PCL.....	Prairie Central Line	TRANS.....	Transec
PE.....	Perma Engineering Ltd.	TRIN.....	Trinetics
PEN.....	Pencell	TRY.....	Trydor
PER.....	Permali		
PHI.....	Philips		
PLP.....	Performed Lined Products		
POL.....	Poltec		
POLE.....	Polesystems		
PP.....	Porcelain Product		
PREC.....	Precision		
PRY.....	Prysmian	U-LINE.....	U-Line
PTS.....	PTS Potelco	UD.....	Underground Devices
PU.....	Penn Union		
PUR.....	Pursley		
		VIS.....	Visionaire
R&M.....	R & M Plastics		
RAY.....	Raychem (RTE)		
RECK.....	Recknell Industries	WEST.....	Westinghouse
REL.....	Reliable		




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Multi Helix Anchor 	1-01-48 <b>5001198</b>	Blade 8 Inch	<b>AB E102-1636</b> <b>JOS J25997CAB1</b> <b>DIX D-84-2-6</b>
Anchor Rod 	1-01-53 <b>5001199</b>	1" x 7'	<b>AB 12334P</b> <b>KAB K156-23</b> <b>JOS J12255R</b> <b>DIX D-101</b>
Triple Eye Pisa Nut for Power Anchor 	1-01-63 <b>5001200</b>	1 Inch	<b>AB 12585</b> <b>JOS J12585</b> <b>KAB K156-36</b> <b>DIX D-6567</b>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Pole Key Anchor use 2 per pole (BOOK OUT SEPARATELY)</p> 	<p>1-01-72 <b>5000000</b></p>	<p>7" x 27 1/4"</p>	<p><b>AB</b> P4817</p>
<p>Bumper Post</p> 	<p>1-02-01 <b>5000001</b></p>	<p>8" Helix, 3 1/2" OD 75" Shaft</p>	<p><b>AB</b> T1120224</p>
<p>Bollard Plastic Sleeve</p>  <p>Bollard Pipe</p> 	<p>1-03-01 <b>5000002</b></p> <p>1-03-03 <b>5000003</b></p>	<p>4" x 52"</p> <p>SCH40 4" x 84"</p>	<p>U-LINE H-6425</p> <p>Russel Metals - pipe is cut from a 252" length 3 pieces at 84"</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Carriage Bolt 	1-08-45 <b>5001201</b>	3/8" x 4 1/2"	<b>HUB 8634 1/2</b> <b>JOS J8634 1/2</b>
Double Arming Bolt 	1-09-18 <b>5001202</b>  1-09-20 <b>5001203</b>  1-09-22 <b>5001204</b>	5/8" x 18"  5/8" x 20"  5/8" x 22"	<b>SL 9868</b> <b>HUB 8868</b> <b>JOS J8868</b>  <b>SL 9870</b> <b>HUB 8870</b> <b>JOS J8870</b>  <b>SL 9872</b> <b>HUB 8872</b> <b>JOS J8872</b>
Double Arming Bolt 	1-09-24 <b>5001205</b>  1-09-26 <b>5001206</b>	5/8" x 24"  5/8" x 26"	<b>SL 9874</b> <b>HUB 8874</b> <b>JOS J8874</b>  <b>SL 9876</b> <b>HUB 8876</b> <b>JOS J8876</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Carriage Bolt for Steel Anchors</p> 	<p>1-10-04 <b>500004</b></p>	<p>1" x 4"</p>	<p>GB5HDG1.4</p>
<p>Machine Bolt</p> 	<p>1-12-05 <b>5001207</b></p> <p>1-12-06 <b>5001208</b></p> <p>1-12-07 <b>5001209</b></p>	<p>1/2" x 5"</p> <p>1/2" x 6"</p> <p>1/2" x 7"</p>	<p><b>HUB 8705</b> <b>JOS J8705</b></p> <p><b>HUB 8706</b> <b>JOS J8706</b></p> <p><b>HUB 8707</b> <b>JOS J8707</b></p>
<p>Machine Bolt</p> 	<p>1-12-08 <b>5001210</b></p> <p>1-12-10 <b>5001211</b></p> <p>1-12-12 <b>5001212</b></p>	<p>1/2" x 8"</p> <p>1/2" x 10"</p> <p>1/2" x 12"</p>	<p><b>HUB 8708</b> <b>JOS J8708</b></p> <p><b>HUB 8710</b> <b>JOS J8710</b></p> <p><b>HUB 8712</b> <b>JOS J8712</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Machine Bolt 	1-13-06 <b>5001213</b>  1-13-08 <b>5001214</b>  1-13-10 <b>5001215</b>  1-13-12 <b>5001216</b>	5/8" x 6"  5/8" x 8"  5/8" x 10"  5/8" x 12"	HUB 8806 JOS J8806  HUB 8808 JOS J8808  HUB 8810 JOS J8810  HUB 8812 JOS J8812 T&B BM512
Machine Bolt 	1-13-14 <b>5001217</b>  1-13-16 <b>5001218</b>  1-13-18 <b>5001219</b>  1-13-20 <b>5001220</b>	5/8" x 14"  5/8" x 16"  5/8" x 18"  5/8" x 20"	HUB 8814 JOS J8814 T&B BM514  HUB 8816 JOS J8816  HUB 8818 JOS J8818  HUB 8820 JOS J8820
Machine Bolt 	1-13-22 <b>5001221</b>  1-13-24 <b>5001222</b>	5/8" x 22"  5/8" x 24"	HUB 8822 JOS J8822  HUB 8824 JOS J8824



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Machine Bolt</p> 	<p>1-14-08 <b>5001223</b></p> <p>1-14-10 <b>5001224</b></p> <p>1-14-12 <b>5001225</b></p> <p>1-14-14 <b>5001226</b></p>	<p>3/4" x 8"</p> <p>3/4" x 10"</p> <p>3/4" x 12"</p> <p>3/4" x 14"</p>	<p><b>HUB 8908</b> <b>SL 9908</b> <b>JOS J8908</b></p> <p><b>HUB 8910</b> <b>SL 9910</b> <b>JOS J8910</b></p> <p><b>HUB 8912</b> <b>SL 9912</b> <b>JOS J8912</b></p> <p><b>HUB 8914</b> <b>SL 9914</b> <b>JOS J8914</b></p>
<p>Machine Bolt</p> 	<p>1-14-16 <b>5001227</b></p>	<p>3/4" x 16"</p>	<p><b>HUB 8916</b> <b>SL 9916</b> <b>JOS J8916</b></p>
<p>Lag Bolt</p> 	<p>1-14-82 <b>5000005</b></p> <p>1-14-86 <b>5000006</b></p>	<p>3/8" x 2"</p> <p>1/2" x 4"</p>	<p><b>HYD 238LG</b></p> <p><b>HYD 412LG</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Grounding Clip #4 For Composite Crossarms	1-15-04 <b>5000007</b>	8 per crossarm, use with #8 x 1" self tapping screws	CLIP236
Alley Arm Brace 	1-17-60 <b>5001228</b>  1-17-84 <b>5000008</b>	60"   84"	HUB 6979 KAB K14-1  HUB 6984
Angle Arm Brace 	1-18-60 <b>5001229</b>  1-18-72 <b>5001230</b>	60"   72"	SL 7953 HUB 6953 JOS J1510 HYD 3460AVB  SL 7955 HUB 6955 JOS J1512



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Mounting Base for 138 KV Epoxy Crossarm (Part of Crossarm 1-30-02)</p> 	<p>1-18-80 <b>500009</b></p>		<p>See 1-30-02</p>
<p>Crossarm Brace</p> 	<p>1-19-24 <b>500010</b></p> <p>1-19-30 <b>5001231</b></p> <p>1-19-32 <b>5001232</b></p>	<p>24 "</p> <p>30"</p> <p>32"</p>	<p><b>SL 8024</b></p> <p><b>SL 8030</b> <b>HUB 7130</b></p> <p><b>SL 8032</b> <b>HUB 7132</b></p>
<p>Bayonet, Steel (Corner)</p> 	<p>1-20-04 <b>5000011</b></p>	<p>84"</p>	<p><b>HU AS2613-F4</b></p>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Standoff Bracket with 13/16" Diameter Centre Hole for 3/4" Steel Pin</p> 	<p>1-21-04 <b>5001489</b></p>	<p>25 KV</p>	<p><b>PTS PA619H HUB 1SBM18CL MAC P G1MDA118AT</b></p>
<p>Mid-Span Triplex Bracket</p> 	<p>1-21-06 <b>5000012</b></p>		<p><b>Enerscan 2611 NO SUBS</b></p>
<p>Transformer Cluster Mount Assembly</p> 	<p>1-21-44 <b>5000013</b></p>	<p>For 3-Single Phase Trf. from 25 KVA to 75 KVA</p>	<p><b>JOS J6980</b></p>










DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Aluminum Platforms</p> <p>6 Foot In-Line</p> <p>20 Foot Across Alley</p> <p>20 Foot Switch Mount</p>	<p>1-22-06 <b>5026797</b></p> <p>1-22-20 <b>5026799</b></p> <p>1-22-21 <b>5026801</b></p>	<p>Centre Capacity</p> <p>5000 LBS</p> <p>6880 LBS</p>	<p><b>NO SUBS</b></p> <p><b>ALUM S2PAL-2-6</b></p> <p><b>ALUM EHD2PAL-20</b></p> <p><b>ALUM 2B2-20</b></p>
<p>Clevis - Spool Insulator Type (2-18-13 Insulator)</p> 	<p>1-25-09 <b>5001233</b></p> <p>1-25-10 <b>5001234</b></p>	<p>1/2" Pin 3/4" Clevis Bolt Small Secondary</p> <p>5/8" Pin 3/4" Clevis Bolt Large Secondary</p>	<p><b>HUB 0341</b> <b>SL 1341</b> <b>JOS J0313</b></p> <p><b>SL 1340</b> <b>HYD 517CL</b> <b>JOS J0342</b></p>
<p>Clevis - Strain Insulator Type 5KV Primary</p> 	<p>1-25-14 <b>5001235</b></p>	<p>5" x 2 1/2" 1/2" Clevis Bolt</p>	<p><b>SL 832</b> <b>JOS J732</b> <b>HUB 732</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Crossarm Composite 8 Foot Tangent C/W Bracket</p> <p>Crossarm Composite 8 Foot Deadend C/W Bracket</p> <p>Crossarm Composite 8 Foot Accessory Arm C/W Bracket</p> <p>Crossarm Composite 8 Foot Alley Arm C/W Bracket and Brace</p>	<p>1-28-08 <b>5000014</b></p> <p>1-28-18 <b>5000015</b></p> <p>1-28-28 <b>5000016</b></p> <p>1-28-38 <b>5024547</b></p>	<p>3 1/2" x 4 1/2" x 8' 3 Pin</p> <p>3 1/2" x 4 1/2" x 8' 3 Pin</p> <p>3 3/4" x 4 3/4" x 10' 3 Pin</p>	<p><b>ALUM FTA18-96-A-IP-HXF</b> <b>PUPI TB22000966742</b> <b>MACP 3001-178</b></p> <p><b>ALUM FDA25-3-96-EB-IP-FG-HYW</b> <b>PUPI</b> <b>DA300096E35562</b></p> <p><b>ALUM FTA20-3-96-A-IP-HES</b> <b>PUPI TB22000961522</b> <b>MACP 3001-022</b></p> <p><b>PUPI D100345</b> <b>MACP 3010-073</b></p>
<p>Fir Crossarm Penta Treated</p> 	<p>1-29-06 <b>5000017</b></p> <p>1-29-12 <b>5000018</b></p>	<p>3 1/2" x 4 1/2" x 8' 3 Pin</p> <p>3 3/4" x 4 3/4" x 10' 3 Pin</p>	<p><b>Dwg. MS-149A</b></p> <p><b>Dwg. ST-OH-047</b></p>
<p>Epoxy Crossarm 138 KV (Includes Mounting Base 1-18-80)</p> 	<p>1-30-02 <b>5000019</b></p>	<p>72"</p>	<p><b>PTS 7588-72TB</b></p>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Crossarm Composite 10 Foot Tangent C/W Bracket</p> <p>Crossarm Composite 10 Foot Deadend C/W Bracket</p> <p>Crossarm Composite 10 Foot AccessaryArm C/W Bracket</p> <p>Crossarm Composite 10 Foot Alley Arm C/W Bracket and Brace</p>	<p>1-31-08 <b>5024810</b></p> <p>1-31-18 <b>5024811</b></p> <p>1-31-28 <b>5024812</b></p> <p>1-31-38 <b>5024813</b></p>	<p>3 1/2" x 4 1/2" x 10" 3 Pin</p>	<p><b>PUPI</b> TB20001205222 <b>MACP</b> 3003-336</p> <p><b>PUPI</b> DA3000120E34352</p> <p><b>PUPI</b> TB200001205232 <b>MACP</b> 3003-335</p> <p><b>PUPI</b> D100346 <b>MACP</b> 3010-072</p>
<p>Suspension Insulator Fitting Clevis Socket</p> 	<p>1-32-11 <b>5001236</b></p>		<p><b>SL</b> 60157-C <b>HUB</b> 87603-2000 <b>PLP</b> SC-5194</p>
<p>Suspension Insulator Fitting Ball Eye</p> 	<p>1-32-13 <b>5024808</b></p>		<p><b>HUB</b> BE30CVN</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Suspension Insulator Fitting Socket Eye 	1-32-20 <b>5000020</b>	to use with 2-02-45	<b>PLP SE5152</b>
Suspension Insulator Fitting Ball Clevis 	1-32-31 <b>5001237</b>		<b>BET CB55L</b> <b>HUB 70488-2000</b>
Y-Clevis Eye Standard   90 Degree 	1-32-40 <b>5001238</b>  1-32-41 <b>5024974</b>	for use with 2-02-45	<b>HUB YCS05</b> <b>MAC P YCE-65-625A</b> <b>PLP YCE-30</b>  <b>HUB YCS0590</b> <b>MAC P RYCE-65-625A</b> <b>PLP YC-5207</b>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Tower U-Bolt</p> 	<p>1-32-50 <b>5024809</b></p> <p>1-32-51 <b>5024976</b></p>	<p>3" Spacing</p> <p>3 1/2" Spacing</p>	<p>SL 29788</p> <p>SL 83622</p>
<p>Preformed Guy Grip Dead-End</p> 	<p>1-33-00 <b>5001239</b></p> <p>1-33-03 <b>5001240</b></p> <p>1-33-07 <b>5001241</b></p> <p>1-33-11 <b>5001242</b></p>	<p>5/16"</p> <p>3/8"</p> <p>7/16"</p> <p>1/4"</p>	<p>SL 14066 FAN 5/16 GSBG PLP GDE-2106 HEL 40301-L</p> <p>SL 14055 FAN 3/8 GSBG PLP GDE-2107</p> <p>SL 14056 FAN 7/16 GSBG PLP GDE-2108</p> <p>SL 14052 FAN 1/4 GSBG PLP GDE-2104 HEL 40201-5L</p>
<p>Clamp - 3 Bolt Curved Jaws</p>  <p>Guy Clamp - 3 Bolt</p>  <p>Guy Clamp - Offset</p> 	<p>1-33-13 <b>5001243</b></p> <p>1-33-14 <b>5001244</b></p> <p>1-33-15 <b>5001245</b></p> <p>1-33-16 <b>5001246</b></p>	<p>For Poly Covered Messenger</p> <p>5/8" Bolts</p> <p>1/4" to 3/8" Strand</p> <p>5/16" to 1/2" Strand</p>	<p><b>ALLIED BOLT 4080</b> <b>MAC P PA422</b></p> <p><b>HYD 358.GU</b> <b>JOS J931</b> <b>LAC 744</b> <b>SL 7461</b> <b>HUB 6461</b></p> <p><b>JOS J926</b> <b>HUB 6409</b></p> <p><b>JOS J927</b> <b>HUB 6410</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Guy Wire Serving Sleeve 	1-33-17 <b>5001247</b>  1-33-18 <b>5001248</b>  1-33-19 <b>5001249</b>  1-33-20 <b>5001250</b>	1/4" Strand  5/16" Strand  3/8" Strand  7/16" Strand	SL 7452 <b>HUB 6452</b>  SL 7453 <b>HUB 6453</b>  SL 7454 <b>KAB K49-2</b> <b>HUB 6454</b>  SL 7458 <b>HUB 6455</b>
Guy Wire Splice	1-33-50 <b>5000022</b>	5/16" Strand	<b>T&amp;B ATSG516</b> <b>MAC P MPS5001</b>
Guy Strut Pole Fitting 	1-33-90 <b>5001251</b>		SL 2056 <b>CP DG9D1</b> <b>KAB K43-4</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Guy Strut Guy Fitting</p> 	<p>1-33-92 <b>5001252</b></p>		<p>SL 2057 HUB 0512 KAB K43-3</p>
<p>Guy Fitting</p> 	<p>1-33-94 <b>5001253</b></p>		<p>SL 7587 HYD 34GH</p>
<p>Clevis Thimble Use with preform on Composite Deadend Crossarm</p> 	<p>1-33-96 <b>5025474</b></p>		<p>JSNA CLT0570-36K- C1.5 SL 24237-E (80468)</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Guy Guard PVC Plastic - Yellow</p> 	<p>1-34-02 <b>5001254</b></p>	<p>6'</p>	<p><b>R&amp;M RMYGG-U-7</b> <b>IPEX 25602</b></p>
<p>Fibreglass Cable Guard - Single Riser</p> <p>Fibreglass Cable Guard - Double Riser</p> 	<p>1-34-07 <b>5000023</b></p> <p>1-34-08 <b>5000024</b></p>	<p>Holes for Nails to be 3/16"</p> <p>Holes for Nails to be 3/16"</p>	
<p>Plastic Riser</p>  <p>Adapter</p> 	<p>1-34-20 <b>5000025</b></p> <p>1-34-25 <b>5000026</b></p>	<p>2" 10 Foot U Guard</p> <p>Adapter 2" Riser</p>	









DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Arms - Non Metallic</p>  	<p>1-36-11 <b>500027</b></p> <p>1-36-14 <b>500028</b></p>	<p>11"</p> <p>14"</p>	<p>UD RA11</p> <p>UD RA14</p>
<p>Arm Lock</p> 	<p>1-36-20 <b>500029</b></p>		<p>UD HDL</p>
<p>Cable Rack - Non Metallic</p>  	<p>1-36-24 <b>500030</b></p> <p>1-36-36 <b>500031</b></p>	<p>24"</p> <p>36"</p>	<p>UD CR24-B</p> <p>UD CR36-B</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Hook for Underground Cable Rack (See 2-20-21 for insulators)  	1-37-07 <b>5001255</b>  1-37-10 <b>5001256</b>  1-37-13 <b>5000032</b>  1-37-21 <b>5000033</b>	7 1/2"  10"  13 1/4"  21"	SL 2132 CP DU5S2  SL 2133 CP DU5S3 MACP U625  SMW 96022-1  SMW 96022-2
Eye Nut  	1-50-00 <b>5001257</b>  1-50-01 <b>5001258</b>	5/8" Thread min. eye 1 1/4" x 1 5/8"  3/4" Thread min. eye 1 1/4" x 1 5/8"	SL 7502 CP DG3E1 JOS J1092 HUH EN60 T&B K58  SL 7503 CP DG3E3 JOS J1093
Thimble Eye  	1-50-03 <b>5001259</b>  1-50-04 <b>5001260</b>	5/8" Thread  3/4" Thread	SL 7510 JOS J6510 HUB 6510  SL 7511 JOS J6511 HUB 6511

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Twin Eye Double Thimble</p> 	<p>1-50-05 <b>5001261</b></p>	<p>5/8" Thread</p>	<p><b>JOS J6515</b> <b>HUB 6560</b></p>
<p>Lock Nut</p> 	<p>1-51-01 <b>5001262</b></p>	<p>3/4" Thread</p>	<p><b>HUB 3513</b> <b>JOS J8584</b> <b>HUH MF70</b></p>
<p>Insulator Pin Steel c/w nylon pins</p> 	<p>1-53-02 <b>5000034</b></p>	<p>For Insulator with 1" Pin Hole Pin 6" above Crossarm</p>	<p><b>MAC P J211Z</b> <b>NO SUBS</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Insulator Pin Pole Top c/w nylon pins</p> 	<p>1-53-05 <b>5000035</b></p>	<p>For Insulator with 1" Pin Hole</p>	<p><b>JOS J26945Z</b></p>
<p>Insulator Pin Crossarm Corner</p> 	<p>1-53-09 <b>5000036</b></p>	<p>For Insulator with 1" Pin Hole For 15 KV 8" height c/w nylon pin &amp; locknut</p>	<p><b>PCL P402ZPCLSPL</b></p>
<p>Insulator Pin Steel</p> 	<p>1-53-10 <b>5001490</b></p>	<p>1" Nylon 5/8" Female Threads</p>	<p><b>AB 4258P</b> <b>Mac P J2840Z</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Three Spool Secondary Rack</p> 	<p>1-73-03 <b>5000037</b></p>		<p><b>HUB C2070050</b></p>
<p>Underground Cable Rack</p> 	<p>1-73-15 <b>5001263</b></p> <p>1-73-24 <b>5001264</b></p> <p>1-73-30 <b>5001265</b></p>	<p>15"</p> <p>24"</p> <p>30"</p>	<p><b>SL 2124</b> <b>HUB C203-1124</b></p> <p><b>SL 2125</b> <b>HUB C203-1125</b> <b>MACP U618</b></p> <p><b>SL 2126</b> <b>HUB C203-1126</b> <b>MACP U619</b> <b>JOS J5126</b></p>
<p>Aluminum Fibre Optic Bracket Z Bracket</p> 	<p>1-74-00 <b>5000038</b></p>		<p><b>SW SW250AFOB2SLP</b> <b>DWG A1s-273</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Network Bus Insulator Bracket</p> 	<p>1-75-01 5000039</p>		<p>Dwg. A1S-104</p>
<p>Network Bus Insulator Bracket</p> 	<p>1-75-02 5000040</p>		<p>Dwg. A1S-105 Rev. 2</p>
<p>Network Bus Termination Bracket</p> 	<p>1-75-04 5000041</p>		<p>Dwg. A1S-137 Rev. 1</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Network Ground Wire Bracket (Stainless Steel)</p> 	<p>1-75-06 <b>5000042</b></p>		<p>Dwg. A1S-134</p>
<p>Moulding Staples</p> 	<p>1-85-02 <b>5000043</b></p> <p>1-85-04 <b>5001266</b></p> <p>1-85-06 <b>5000044</b></p>	<p>Galvanized</p> <p>2" X 3/4" X 3/16"</p> <p>3" X 1 1/16" X 1/4"</p> <p>4" X 1 1/2" X 1/4"</p>	<p>LAR 340321</p> <p>LAR 321312 HUB C205-0220</p> <p>LAR 322522</p>
<p>Double Coil Lock Washer</p> 	<p>1-92-21 <b>5001267</b></p> <p>1-92-22 <b>5001268</b></p> <p>1-92-23 <b>5001269</b></p>	<p>1/2" Bolt</p> <p>5/8" Bolt</p> <p>3/4" Bolt</p>	<p>JOS J176 AB C205-0185</p> <p>JOS J177 AB C205-0186</p> <p>JOS J178 AB C205-0187</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Nut Galvanized Square 	1-93-13 <b>500045</b>  1-93-14 <b>500046</b>	5/8"  3/4"	MP J8563  MP J8564
Split Lock Washer 	1-93-20 <b>5001270</b>  1-93-21 <b>5001271</b>  1-93-22 <b>5001272</b>	3/8" Bolt  1/2" Bolt  5/8" Bolt	SL 22332 CP DF7W1  SL 22333 HUB 4035  SL 22335 HUB 4036 KAB K3-3
Round Flat Washer 	1-93-30 <b>5001273</b>  1-93-31 <b>5001274</b>  1-93-32 <b>5001275</b>	3/8" Bolt  1/2" Bolt  5/8" Bolt	SL 7801 HUB 6801  SL 7803 HUB 6803 KAB K20-2  SL 7805 HUB 6805 KAB K20-3






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Square Flat Washer</p> 	<p>1-93-39 <b>5001276</b></p> <p>1-93-40 <b>5001277</b></p> <p>1-93-41 <b>5000047</b></p> <p>1-93-42 <b>5001278</b></p>	<p>2" x 2" x 3/16" 11/16" Hole 5/8" Bolt</p> <p>2 1/4" x 2 1/4" x 3/16" 13/16" Hole 3/4" Bolt</p> <p>3" x 3" x 1/4" 11/16" Hole 5/8" Bolt</p> <p>3" x 3" x 1/4" 13/16" Hole 3/4" Bolt</p>	<p><b>SL 7811</b> <b>HUB 6813</b> <b>HYD 3622SW11</b></p> <p><b>SL 7814</b> <b>JOS J1076</b> <b>HUB 6814</b> <b>HYD 3624SW13</b></p> <p><b>SL 7817</b></p> <p><b>CP DF2W7</b> <b>SL 7817</b></p>
<p>Square Curved Washer Galvanized</p> 	<p>1-93-50 <b>5001279</b></p> <p>1-93-52 <b>5001280</b></p>	<p>3" x 3" x 1/4" 11/16" Hole 5/8" Bolt</p> <p>3" x 3" x 1/4" 13/16" Hole 3/4" Bolt</p>	<p><b>SL 7822 1/2</b> <b>CP DF4W4</b> <b>JOS J113</b> <b>HYD 1433CW11</b></p> <p><b>SL 7825</b> <b>CP DF4W5</b> <b>JOS J6823</b></p>
<p>Nut Galvanized For Street Light Bases</p>	<p>1-94-01 <b>5000048</b></p> <p>1-94-02 <b>5000049</b></p>	<p>1"</p> <p>1 1/4"</p>	




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Washers Galvanized USS For Street Light Bases	1-94-11 <b>500050</b>  1-94-12 <b>500051</b>	1"  1 1/4"	
Shims For Street Lighting	1-94-21 <b>500052</b>  1-94-22 <b>500053</b>	1"  1 1/4"	
Guy Wire - Grade #110 (Hard)    Guy Wire - Grade #160 (Crucible) 	1-95-15 <b>500054</b>  1-95-16 <b>500055</b>  1-95-17 <b>500056</b>  1-95-18 <b>500057</b>	1/4"  5/16"  3/8"  7/16"	<b>National Strand</b> Siemens Martin Grade 5350  <b>National Strand</b> Siemens Martin Grade 5350





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Fibreglass Guy Strain Insulators</p> 	<p>1-98-01 <b>5001281</b></p> <p>1-98-06 <b>5001282</b></p>	<p>15,000 lb. use with 5/16" guy</p> <p>21,000 lb. use with 3/8" guy</p>	<p><b>MAC P GCC15-36R2</b> <b>AP APF136R2</b></p> <p><b>MAC P GCC21-36R2</b> <b>AP APF-236R2</b> <b>KL KL-36PR</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Compression Deadend One Piece with Eye Fitting</p> 	<p>2-01-05 <b>5000058</b></p>	<p>477 MCM ALUM</p>	<p><b>BUR YDWE331AT</b></p>
<p>Compression Deadend Two Piece with Eye Fitting</p> 	<p>2-01-06 <b>5000059</b></p> <p>2-01-08 <b>5001487</b></p> <p>2-01-09 <b>5001488</b></p>	<p>266.8 MCM ACSR PARTRIDGE</p> <p>336 MCM ACSR ORIOLE</p> <p>477 MCM ACSR HAWK</p>	<p><b>SL T1305-01 HUB SEDA1109 CICAME TDA-107N</b></p> <p><b>SL T1305-07 HUB SEDA1313 CICAME TDA-117N</b></p> <p><b>SL T1305-11 HUB SEDA1809 CICAME TDA-125N</b></p>
<p>Fitting - Clevis - Clevis</p> 	<p>2-01-12 <b>5000060</b></p>		<p><b>ALMAT A180-1</b></p>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Compression Deadend Network Bus</p> 	<p>2-01-15 <b>5000061</b></p>	<p>750 MCM Copper</p>	<p>Multicast Inc. <b>Dwg. #A215-011</b></p>
<p>Automatic Deadend</p> 	<p>2-01-20 <b>5000062</b></p>	<p>4/0 ALUM or ACSR</p>	<p><b>FAR GD449</b></p>
<p>Service Wedge Clamp</p> 	<p>2-02-14 <b>5001283</b></p>	<p>#2 - #6</p>	<p><b>BLK W621 MACP 7195</b></p> <p><b>NO SUBS</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Deadend Strain Clamp (Hot Line) Steel: (For copper conductor only)</p> 	<p>2-02-15 <b>5000063</b></p> <p>2-02-16 <b>5001284</b></p>	<p>#4 STR - 2/0 STR(19) 0.204 - 0.563</p> <p>4/0 STR 0.250 - 0.730 0.300 - 0.630</p>	<p><b>MACP HDSO-47-F NO SUBS</b></p> <p><b>CON SDE-73F EPAC MSC-62</b></p>
<p>Deadend Strain Clamp (Hot Line) Aluminum (For alum &amp; ACSR conductor only)</p> 	<p>2-02-17 <b>5001285</b></p> <p>2-02-18 <b>5001286</b></p>	<p>#2 STR - 2/0 STR (19) 0.250 - 0.447 0.250 - 0.460 0.160 - 0.460 0.180 - 0.520</p> <p>4/0 ALUM - 477 MCM ALUM 0.522 - 0.813 0.460 - 0.860 0.522 - 0.811 0.310 - 0.880</p>	<p><b>BUR CUW26RE SL 62312 EPAC ASC50 CON SGA-52-23 MACP ASD 2L N</b></p> <p><b>MACP HDSO-88 HUB ADEZ88N</b></p> <p><b>NO SUBS</b></p>
<p>Preformed Deadend Grip For Quad &amp; Triplex <b>Only</b></p> 	<p>2-02-20 <b>5001287</b></p> <p>2-02-21 <b>5001288</b></p>	<p>2/0 ACSR Messenger</p> <p>4/0 ACSR Messenger</p>	<p><b>AB CSG-080 PAY 21-SSG SL 15141 BM 21GSDE-401-450 HEL 60800</b></p> <p><b>AB CSG-100 PAY 26-SSG SL 15143 BM 26GSDE-511-580 HEL 60910</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Preformed Deadend Grip</p> 	<p>2-02-22 <b>5001289</b></p> <p>2-02-24 <b>5001290</b></p> <p>2-02-25 <b>5001291</b></p>	<p>2/0 ACSR Bare Dia .447 Range .410-.447 Coded Brown or Blue</p> <p>2/0 AAC Poly SB Dia .502 Range .461-.516 Coded Orange</p> <p>2/0 ACSR Poly SB Dia .535 Range .517-.577 Coded Purple or Red</p>	<p><b>SL 80004</b> <b>AB 60AWCG</b> <b>PAY QUAIL-31-ADN</b> <b>HEL 31022</b></p> <p><b>AB 70GCG</b> <b>PAY THORN32NADN</b> <b>BM DG-2516</b> <b>HEL 30030</b></p> <p><b>AB 80GCG</b> <b>PAY CORYPHA-</b> <b>35NADN</b> <b>BM DG-2517</b> <b>HEL 30033</b></p>
<p>Preformed Deadend Grip</p> 	<p>2-02-26 <b>5001292</b></p> <p>2-02-27 <b>5001293</b></p> <p>2-02-29 <b>5001294</b></p>	<p>4/0 ACSR Bare Dia .563 Range .542-.563 Coded Black or Red</p> <p>4/0 ACSR Poly AAC Range .578 - .653 Coded Blue</p> <p>336.4 MCM AAC Poly Dia- .791 Range .740-.837 Coded Brown Coded Pink/Green</p>	<p><b>AB 80AWCG</b> <b>PAY PENGUIN37ADN</b> <b>HEL 31033</b></p> <p><b>BM DG-2100</b> <b>HEL 30040</b> <b>HXU 30040-BC</b></p> <p><b>AB 110GCG</b> <b>PAY ANONA-40-</b> <b>NADN</b> <b>BM DG-2102</b> <b>HXU 36030-MH</b> <b>HEL 36030</b></p>
<p>Preformed Deadend Grip</p> 	<p>2-02-30 <b>5001295</b></p>	<p>477 MCM AAC Poly Dia .951 Range .948-1.071 Coded Black</p>	<p><b>AB 130GCG</b> <b>PAY HUCKLE-</b> <b>BERRY-40-NADN</b> <b>HEL 36033</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Suspension Clamp Ground Wire</p>  <p>Shield Wire</p>  <p>AL 266-477</p>	<p>2-02-33 <b>5000064</b></p> <p>2-02-35 <b>5024978</b></p> <p>2-02-36 <b>5024980</b></p>		<p><b>SL 6455</b></p> <p><b>MAC P FSC-83</b></p> <p><b>MAC P LS-2-S</b></p>
<p>AGS Unit c/w Clamp and Structural Rod</p> <p>Replacement Structural Rod 2-56-13</p> <p>Replacement Structural Rod 2-56-15</p> 	<p>2-02-44 <b>5000065</b></p> <p>2-02-45 <b>5000066</b></p>	<p>266.8 ACSR Range 0.620-0.645</p> <p>477 ACSR Range 0.346-0.870</p>	<p><b>PLP AGS-5108</b> c/w Socket Eye SE-5150</p> <p><b>PLP AGS-5118</b></p>
<p>Ground Rod Clamp</p> 	<p>2-02-50 <b>5001296</b></p> <p>2-02-51 <b>5001297</b></p>	<p>Rod Diameter 5/8"</p> <p>3/4"</p>	<p><b>AMP 81402-1</b> <b>ILS BGRC-58</b> <b>HYD 758C</b> <b>PP 8058</b> <b>BUR GRC58</b> <b>HUB GC-5/G5</b></p> <p><b>AMP 81403-1</b> <b>ILS BGRC-68</b> <b>PP 8034</b> <b>HYD 733C</b> <b>BUR GR3426</b></p>








DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Ground Rod Coupling Connector Bronze</p> 	<p>2-02-53 <b>5001298</b></p>	<p>5/8"</p>	<p><b>BLK 60C</b> <b>SL 9534</b> <b>JOS 9182</b> <b>HYD 58.SC</b> <b>PP 8534</b></p>
<p>Ground Rod Driving Stud</p> 	<p>2-02-55 <b>5001299</b></p>		<p><b>SL 29534</b> <b>BLK 60DS</b> <b>JOS 9186</b> <b>HYD 58.DS</b> <b>PP 19534</b></p>
<p>Copperclad Steel Sectional Ground Rod</p>  <p>ConduDisc Grounding Plate</p> 	<p>2-02-57 <b>5001300</b></p> <p>2-02-59 <b>5026284</b></p>	<p>5/8" x 8'</p> <p>45' - #4 Str Copperweld Camo</p>	<p><b>SL 29438</b> <b>JOS 9158</b> <b>HYD 5808.SC</b> <b>PP 18438</b> <b>BLK 6258S</b> <b>CAD 635880</b></p> <p><b>SAE</b> 06112-CD-4WC-45</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Hot Line Clamp For Alum/Cu Main Line Conductor With #4 AWG Cu Tap</p> <p>For Armoured Main Line Conductor With #4 AWG Cu Tap</p> 	<p>2-03-00 <b>500067</b></p> <p>2-03-01 <b>500068</b></p> <p>2-03-02 <b>500069</b></p>	<p>1/0 to #6 AWG</p> <p>336.4 MCM to #6 AWG</p> <p>266.8 MCM to #4 AWG</p>	<p><b>AB S1520AGP</b></p> <p><b>AB S1530AGP</b></p> <p><b>AB S1540AGP</b></p>
<p>Bull Line - Poly Pull Tape</p> 	<p>2-04-10 <b>5001301</b></p>	<p>1800# X 900 Meter Box</p>	<p><b>DL WP18-3000</b> <b>GRNL 4436</b></p>
<p>Aluminum Oxidation Inhibitor Splicing Compound (Penetrox)</p> 	<p>2-05-12 <b>5001302</b></p>	<p>8 oz. Bottle</p>	<p><b>AMP 80665-3</b> <b>BUR Pena 138</b> <b>T&amp;B CTB8</b> <b>ILS DE-OX 8OZ</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Cable Pulling Lubricant</p> 	<p>2-05-14 <b>500070</b></p> <p>2-05-16 <b>500071</b></p> <p>2-05-18 <b>500072</b></p>	<p>1 Quart</p> <p>5 Gallon</p> <p>5 Gallon Winter Grade</p>	<p><b>POLYWATER</b> J-35 <b>NO SUBS</b></p> <p><b>POLYWATER</b> J-640 <b>NO SUBS</b></p> <p><b>POLYWATER</b> WJ-640 <b>NO SUBS</b></p>
<p>Switch Contact Lubricant 7 Release Compound</p> 	<p>2-05-19 <b>500073</b></p>	<p>150 Gram</p>	<p><b>Dow Corning</b> Dow 7</p>
<p>Termi Kit Silicone Lubricant</p> 	<p>2-05-25 <b>500074</b></p>	<p>5 oz. Tube</p>	<p><b>ELMD SL5</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
STOPAQ Sealant 	2-05-30 <b>5000075</b>	.53 kg Tube	<b>STO FN2100-2002</b>
Solid Blade Cutout 	2-11-72 <b>5000076</b>	300 Amp 15 KV	<b>ABB Y2JCBNVA32</b>
Open Fuse Loadbreak Cutout 	2-11-84 <b>5001303</b>  2-11-88 <b>5001304</b>  2-11-92 <b>5001305</b>  2-11-94 <b>5001306</b>	100 Amp 15 KV 16,000 Interrupting  200 Amp 15 KV  100 Amp 14.4 - 25 KV  200 Amp 25 KV	<b>ALUM CSG15LX-100A-110-CB-16KA</b> <b>ABB Y1JCBNQA11</b> <b>AB CP730114PB</b>  <b>ALUM CSG15LX-200A-110-CB-12KA</b> <b>ABB Y1JCBNUA21</b> <b>AB CP730143PB</b>  <b>ALUM CSG27LX-100A-125-CB-16KA</b> <b>ABB Y2JCBNQA12</b> <b>AB CP730213PB</b>  <b>ALUM CSG27LX-200A-125-CB-16KA</b> <b>ABB Y2JCBNFA22</b> <b>AB CP730242PB</b>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Solid Blade Enclosed Cutout</p> 	<p>2-12-06 <b>5001307</b></p>	<p>400 Amp 5.2 KV</p>	<p><b>GE 9F36CAM406</b> <b>CP FE1EC7</b></p>
<p>Replacement Solid Blade Door for 2-12-06</p> 	<p>2-12-08 <b>5000077</b></p>	<p>400 Amp 5.2 KV</p>	<p><b>CP FE1EC57</b></p>
<p>Solid Blade Disconnect</p> 	<p>2-12-30 <b>5000078</b></p> <p>2-12-32 <b>5000079</b></p>	<p>600 Amp 15 KV</p> <p>600 Amp 25 KV</p>	<p><b>S&amp;C 4922R10-ED1</b></p> <p><b>S&amp;C 4943R10-ED1</b></p>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Line Tension Disconnect - Pad Style</p>  <p>Line Tension Disconnect - Ampact Style</p> 	<p>2-12-34 <b>500080</b></p> <p>2-12-36 <b>502532</b></p> <p>2-12-38 <b>502534</b></p>	<p>600 Amp 25 KV</p> <p>900 Amp, 25 KV 4/0 266 &amp; 336 MCM</p> <p>900 Amp 25 KV 477 MCM</p>	<p><b>AB</b> ALTD06200R</p> <p><b>TE</b> 1710726-2</p> <p><b>TE</b> 1710726-3</p>
<p>Three Phase Cluster Style Mounting Unit</p>  <p>Uses 7-41-40 fuses - Qty 3 per cluster</p>	<p>2-12-40 <b>500081</b></p>	<p>SMD-40</p>	<p><b>S&amp;C</b> 192342-E</p>
<p>Solid Blade Disconnect Three Phase Cluster c/w - Cyproxy insulators, 90 degree stop, clamp type terminals</p> 	<p>2-12-44 <b>500082</b></p>	<p>900 Amp 25 KV</p>	<p><b>Mindcore</b> DHS327A7 <b>Specification 1270</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Insulator Insert in Operating Shaft</p> 	<p>2-12-49 <b>500083</b></p>	<p>Critical Spare Only</p>	
<p>Three Phase Group Operated Switch Horizontal Mounting c/w Wildlife Protection</p> 	<p>2-12-50 <b>500084</b></p> <p>2-12-51 <b>500085</b></p>	<p>600 Amp 15 KV</p> <p>600 Amp 25 KV</p>	<p><b>S&amp;C</b> 147422R4- A2P1W- ED-701R4-S2V1</p> <p><b>S&amp;C</b> 147423R4- A2P1W- ED-701R4-S2V1</p>
<p>Three Phase Group Operated Switch Vertical Mounting</p> 	<p>2-12-52 <b>500086</b></p> <p>2-12-53 <b>500087</b></p>	<p>600 Amp 15 KV</p> <p>600 Amp 25 KV</p>	<p><b>S&amp;C</b> 147512R4-A1P1- ED703R4-S2S15V1</p> <p><b>S&amp;C</b> 147513R4-A1P1- ED703R4-S2S15V1</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Indoor Fused Disconnect</p> 	<p>2-13-02 <b>5000088</b></p>	<p>200 Amp 4.8 KV</p>	<p><b>S&amp;C SM487360R1</b></p>
<p>Indoor Fused Cutout Type NX</p> 	<p>2-13-06 <b>5000089</b></p>	<p>200 Amp 8.3 KV</p>	<p><b>CP FA1D1</b></p>
<p>Lightning Arrestor Distribution Class c/w Ground Lead Insulator</p> <p>Metal Oxide Type c/w Polymer Housing</p> 	<p>2-16-03 <b>5001308</b></p> <p>2-16-12 <b>5001309</b></p> <p>2-16-18 <b>5001310</b></p>	<p>3 KV</p> <p>12 KV</p> <p>18 KV</p>	<p><b>MACZHP003-0C00100</b> <b>GE 9L23AXA403AH</b> <b>HUB 2137037324</b> <b>CP UHS03030A1A1B1A</b></p> <p><b>HUB 2137107324</b> <b>GE 9L23AXA412AH</b> <b>MACZHP012-0C00100</b> <b>CP UHS12060A1A1B1A</b></p> <p><b>HUB 213715-7324</b> <b>CP UHS18080A1A1B1A</b></p>







DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Pin Type Insulator Polymer</p> 	<p>2-17-20 <b>500090</b></p>	<p>15 - 25 KV 1" Hole</p>	<p><b>Hendrix HPI55501</b></p>
<p>Pin Type Insulator - Clamp Top Polymer</p> 	<p>2-17-30 <b>5001491</b></p>	<p>25 KV</p>	<p><b>HendrixHPI-25VTP-1 PLP IP-25-VTU1</b></p>
<p>Shear Bolt for Clamp Top Insulator</p>	<p>2-17-35 <b>5001492</b></p>	<p>25 KV</p>	<p><b>Hendrix B-1 NO SUBS</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Guy Strain Insulator Colored</p> 	<p>2-18-01 <b>5001311</b></p> <p>2-18-03 <b>5001312</b></p>	<p>4.4 KV 12000 lbs.</p> <p>6.6 KV 20000 lbs.</p>	<p><b>NGK HCP-191</b> <b>PP 504</b> <b>OB 31504</b> <b>BM 504</b></p> <p><b>NGK HCP-192</b> <b>PP 506</b> <b>OB 31506</b> <b>BM 506</b></p>
<p>Large Clevis Type Insulator Spool Polymer</p> <p>Black</p>  <p>Light Grey</p> 	<p>2-18-11 <b>5000091</b></p> <p>2-18-13 <b>5000092</b></p>	<p>Large Sec Volt 2500 lbs. 13/16" Hole</p> <p>Large Sec Volt 2500 lbs. 13/16" Hole</p>	<p><b>HUB C9091032P</b></p> <p><b>Hendrix HPI-53-2</b></p>
<p>Small Clevis Type Insulator Colored</p> <p>White</p> 	<p>2-18-27 <b>5001313</b></p> <p>2-18-39 <b>5001314</b></p>	<p>Small Sec Volt 2000 lbs. 11/16" Hole</p> <p>Small Sec Volt 2000 lbs. 11/16" Hole</p>	<p><b>SL 1608</b> <b>NGK HRP-614</b> <b>PP 5112</b> <b>ANSI 53-1</b></p> <p><b>SL 1608</b> <b>NGK HRP-614</b> <b>PP 5112</b> <b>ANSI 53-1 White</b></p>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Suspension Insulator Clevis Eye</p> 	<p>2-19-01 <b>5001315</b></p>	<p>10000 lbs. 7.2 KV</p>	<p><b>NGK CA-15923A</b> <b>OB 32433</b> <b>PP 86012</b> <b>LAPP 6605-70</b></p>
<p>Ball &amp; Socket Insulator Suspension</p> 	<p>2-19-05 <b>5001316</b></p>	<p>72 &amp; 138 KV 15000 lbs.</p>	<p><b>SED N70/146</b> <b>HUB PCN70146</b></p>
<p>Ball &amp; Socket Insulator Strain</p> 	<p>2-19-07 <b>5001317</b></p>	<p>72 &amp; 138 KV 25000 lbs.</p>	<p><b>SED N12/146</b> <b>HUB PCN12146</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Epoxy Deadend Insulator Eye-Clevis End</p>  <p>Eye-Eye End</p>	<p>2-19-30 <b>5001318</b></p> <p>2-19-32 <b>5001319</b></p>	<p>10000 lbs. 4 KV, 15 KV &amp; 25 KV</p> <p>10000 lbs. 15 KV &amp; 25 KV</p>	<p><b>KL</b> KL28ASCTM <b>PER</b> RL-25 <b>LAPP</b> 151002 <b>OB</b> PDI-28 <b>AB</b> 401028-6215 <b>SED</b> ODI-1S-70-Z8 <b>GLP</b> DS-28 <b>SAL</b> 9502U-SI</p> <p><b>AB</b> 401428-6215 <b>PER</b> RL-25 <b>KL</b> KL28ASTTM <b>LAPP</b> 151002E</p>
<p>Phase Conduction Spacing Insulator</p>	<p>2-19-44 <b>5000093</b></p>	<p>25 KV Conductor range .20 - .858" c/w 2 clamps</p>	<p><b>EPAC</b> EHCS-2-3545 45" Length</p>
<p>Polymer Insulator Suspension</p>	<p>2-19-50 <b>5000094</b></p>	<p>10,000 lbs 138 KV</p>	<p><b>NGK</b> 251-SN270-YT</p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Polymer Insulator Deadend	2-19-60 <b>500095</b>	25,000 lbs. 138 KV	<b>NGK 302-SS550-YC</b>
Line Post Insulator 	2-20-01 <b>500096</b>	15 KV	<b>LAPP 74115</b>
Polymer Line Post Insulator 	2-20-02 <b>500097</b>	28 KV	<b>K-Line KL28SKG</b>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Polymer Line Post Insulator	2-20-04 <b>5000098</b>	15 KV	
Station Post Insulator for S & C 600 Amp Loadbreak Switches  	2-20-05 <b>5001320</b>	15 KV	<b>OB 231002</b> <b>NGK DA-45006A</b>
Polymer Line Post Insulator  	2-20-06 <b>5000099</b>  2-20-07 <b>5000100</b>	138 KV 1150 lb MDCL Flat Base  138 KV 1150 lb MDCL Gain Base	<b>MACP H211075VX06</b>  <b>MACP H291075VX06</b>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Station Post Insulator 650KV Bil	2-20-08 <b>5000101</b>	138 KV Height = 54"	<b>NGK</b> Locke PS06510 <b>Specification 3304</b>
Corona Ring	2-20-09 <b>5000102</b>	138 KV	<b>NGK</b> 97004-RG
Cable Cleats Single Cable Clamp 	2-20-11 <b>5000103</b>  2-20-13 <b>5000104</b>	26 mm - 38 mm  36 mm - 52 mm	<b>KOZ</b> 26-38  <b>KOZ</b> 36-52




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Cable Cleats Three Cable Clamp</p>  <p>Multi Cable Clamp</p> 	<p>2-20-15 <b>5000105</b></p> <p>2-20-17 <b>5000106</b></p> <p>2-20-19 <b>5000107</b></p>	<p>25 mm - 40 mm</p> <p>38 mm - 53 mm</p> <p>30 mm - 47 mm</p>	<p><b>KOZ Triangle 25-40</b> 3 Hole</p> <p><b>KOZ Triangle 38-53</b> 3 Hole</p> <p><b>KOZ Universal 30-47</b></p>
<p>Insulator Cable Rack Type</p> 	<p>2-20-21 <b>5001321</b></p>	<p>Polymer</p>	<p><b>SL 2120</b> <b>CP DE11U1</b> <b>MACP U628</b> <b>ENE 3003</b></p>
<p>Epoxy Insulator Split Spool Moulded for Network</p> 	<p>2-20-23 <b>5000108</b></p>	<p>1 1/2"</p>	<p><b>MULT A215-009</b></p>









DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Insulator Triplex Spreader Block 	2-20-25 <b>5000109</b>		<b>SL 1750</b>
Insulator Indoor for Switching Cubicle	2-20-27 <b>5001322</b>	15.5 KV (95 KV BIL)	<b>CP FM2A1 or FW14XC1</b>
Black Plastic Moulding 	2-27-08 <b>5001323</b>	1/2" x 8'	<b>LAC 755P                      NE 125                      POL P128PM</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Cable Guards</p> <p>Guard Straps</p>	<p>2-27-20 <b>5000110</b></p> <p>2-27-25 <b>5001324</b></p> <p>2-27-30 <b>5000111</b></p>	<p>8' x 3/4" Steel</p> <p>8' x 1 1/8" Steel</p>	<p><b>HYD 834UC</b></p> <p><b>HYD 8114UC</b> <b>MP J984</b></p> <p><b>MP J995</b></p>
<p>Oil Switch Light Sensor Control (to be used with Oil Switch)</p> 	<p>2-52-01 <b>5000112</b></p>	<p>200 Amp 14.4 KV</p>	<p><b>TRIN CSD6770/6743/6637</b></p>
<p>Single Pole Electric</p> 	<p>2-52-02 <b>5001325</b></p>	<p>200 Amp 14.4 KV</p>	<p><b>GE 9F90DFC100</b> <b>TRIN CSD-125</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Preformed Plastic Line 1/2" Construction</p> 	<p>2-55-01 <b>5001326</b></p> <p>2-55-02 <b>5001327</b></p> <p>2-55-03 <b>5001328</b></p>	<p>OD .270-.350 OD .257-.523</p> <p>OD .644-.872 OD .522-.770 OD .724-1.030</p> <p>OD .414-.644</p>	<p><b>PLP</b> PSU-MS-2682 <b>ENE</b> 2711</p> <p><b>PLP</b> PSU-MS-2762 <b>ENE</b> 2730 <b>ENE</b> 2731</p> <p><b>FAR</b> GS-953 <b>ENE</b> 2742</p>
<p>Structural Rod Replacement for AGS Unit Only</p> <p>Use with 2-02-44</p> <p>Use with 2-02-45</p> 	<p>2-56-13 <b>5000113</b></p> <p>2-56-15 <b>5000114</b></p>	<p>266.8 ACSR</p> <p>477 ACSR</p>	<p><b>PLP</b> 4000108</p> <p><b>PLP</b> 4000118</p>
<p>Armour Rod (Shield Wire)</p>	<p>2-56-20 <b>5000115</b></p> <p>2-56-25 <b>5000116</b></p>	<p>5/16" Steel Range 0.309"-0.326"</p> <p>7/16" Steel Range 0.416-0.436" (Use for #1/0 AWAC 5/2 Alumoweld)</p>	<p><b>PLP</b> AR-1128</p> <p><b>PAY</b> Aster-52-A</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Preformed Super Top Tie 	2-58-00 <b>5000117</b>  2-58-02 <b>5000118</b>  2-58-04 <b>5000119</b>  2-58-06 <b>5000120</b>  2-58-08 <b>5026173</b>	2/0 ACSR Bare Blue  4/0 ACSR Bare Pink  336.4 MCM Alum Bare & ACSR Bare Brown  477 MCM Alum Bare & ACSR Bare Purple  1/0 ACSR Bare/AAC Yellow	<b>AB STT-70</b>  <b>AB STT-90</b>  <b>AB STT-110</b>  <b>AB STT-120</b>  <b>AB STT-60</b>
Nonmetallic Composite Insulator Top Tie 	2-58-10 <b>5000121</b>  2-58-11 <b>5000122</b>  2-58-12 <b>5000123</b>	#2 & #4 Poly Copper "F" Neck Small White/Yellow (4KV & 15 KV Glass)  #2 & #4 Poly Copper "J" Neck Large White/Yellow (25 KV Glass)  2/0 ACSR Poly 2/0 Poly Copper "F" Neck Small Green/Yellow	<b>FAR GJ-611FC</b> <b>NO SUBS</b>  <b>FAR GJ-621FC</b> <b>NO SUBS</b>  <b>FAR GJ-612FC</b> <b>NO SUBS</b>
Nonmetallic Composite Insulator Top Tie 	2-58-13 <b>5000124</b>  2-58-14 <b>5000125</b>  2-58-15 <b>5000126</b>	4/0 Poly Copper "F" Neck Small Blue/Yellow  336 MCM Poly Alum "F" Neck Small Orange/Yellow  336 MCM Poly Alum "J" Neck Large Orange/Yellow	<b>FAR GJ-613FC</b> <b>NO SUBS</b>  <b>FAR GJ-614FC</b> <b>NO SUBS</b>  <b>FAR GJ-624FC</b> <b>NO SUBS</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Damper Spiral Shield Wire</p> 	<p>2-58-20 <b>5000127</b></p> <p>2-58-26 <b>5000128</b></p>	<p>for 5/16" Steel</p> <p>for .416" Dia AWAC Conductor</p>	<p><b>PLP 5050103</b></p> <p><b>PLP 5050104</b></p>
<p>Damper Stockbridge</p> 	<p>2-58-30 <b>5000129</b></p> <p>2-58-36 <b>50S01329</b></p>	<p>5/16" - 3/8" Steel Range 0.250" - 0.385"</p> <p>477 MCM ACSR Hawk Range 0.266"-0.865"</p>	<p><b>FAR 60704-8/0</b></p> <p><b>FAR 60705-10/11</b> <b>DULM DB1-18</b></p>
<p>Copper Conductor MHD Poly Covered (Coils)</p>  <p>Copper Conductor MHD Poly Covered (Reel)</p>	<p>2-60-04 <b>5026405</b></p> <p>2-60-05 <b>5000130</b></p> <p>2-60-06 <b>5000131</b></p> <p>2-60-08 <b>5000132</b></p>	<p>#6 Solid</p> <p>#4 Solid</p> <p>#2 Solid</p> <p>#2 Solid</p>	<p><b>Specification #1308</b> 300 M Reel</p> <p><b>Specification #1308</b> 150 M Coils</p> <p><b>Specification #1308</b> 150 M Coils</p> <p><b>Specification #1308</b> 500 M Reel</p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Copper Conductor Soft Poly Covered (Overhead Transformer Leads)</p> 	<p>2-61-09 <b>5000133</b></p> <p>2-61-11 <b>5000134</b></p>	<p>2/0 Stranded</p> <p>4/0 Stranded</p>	<p><b>Specification #1310</b></p> <p><b>Specification #1310</b></p>
<p>Copper Conductor Soft Bare (Coils)</p> <p>Stranded</p> 	<p>2-63-05 <b>5000135</b></p>	<p>#4</p>	<p><b>Specification #1318</b> 150 M Coils</p>
<p>Aluminum Conductor Steel Reinforced XLPE Covered</p> <p>Stranded</p> 	<p>2-64-09 <b>5026407</b></p>	<p>2/0</p>	<p><b>Specification #1311</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Aluminum Conductor Poly Covered Stranded 	2-65-11 <b>5000136</b>  2-65-13 <b>5000137</b>  2-65-14 <b>5000138</b>	4/0  336 MCM  477 MCM	Specification #1312  Specification #1312  Specification #1312
Aluminum Conductor Solid Bare Tie Wire 	2-66-00 <b>5000139</b>	#4	
Aluminum Conductor Bare Stranded 	2-66-08 <b>5017889</b>  2-66-11 <b>5000140</b>  2-66-13 <b>5000141</b>  2-66-14 <b>5000142</b>	1/0  4/0  336 MCM  477 MCM Cosmos	Specification #1316  Specification #1316  Specification #1316  Specification #1316



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Aluminum Conductor Steel Reinforced Bare  Stranded  	2-68-09 <b>5000143</b>  2-68-11 <b>5000144</b>  2-68-12 <b>5000145</b>  2-68-14 <b>5000146</b>	2/0  4/0  266.8 MCM  477 MCM Hawk	<b>Specification #1320</b>  <b>Specification #1320</b>  <b>Specification #1320</b>  <b>Specification #1320</b>
Duplex SB  Stranded  	2-69-04 <b>5000147</b>	#6	<b>Specification #1302 &amp; Addendum</b>
Triplex SB  Stranded  	2-70-05 <b>5000148</b>  2-70-06 <b>5000149</b>  2-70-09 <b>5000150</b>  2-70-11 <b>5000151</b>	#4  #2  2/0  4/0	<b>Specification #1304 &amp; Addendum</b> 150 M Coils  <b>Specification #1304 &amp; Addendum</b> 100 M Coils  <b>Specification #1304 &amp; Addendum</b> 300 M Reel  <b>Specification #1304 &amp; Addendum</b> 300 M Reel





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Quadriplex SB</p> <p>Stranded</p> 	<p>2-71-06 <b>5000152</b></p> <p>2-71-09 <b>5000153</b></p> <p>2-71-11 <b>5000154</b></p>	<p>#2</p> <p>2/0</p> <p>4/0</p>	<p><b>Specification #1306 &amp; Addendum</b> 100 M Coils</p> <p><b>Specification #1306 &amp; Addendum</b> 300 M Reel</p> <p><b>Specification #1306 &amp; Addendum</b> 300 M Reel</p>
<p>Copper Cable 25 KV Concentric Neutral</p> <p>Stranded</p> 	<p>2-73-07 <b>5000155</b></p> <p>2-73-14 <b>5000156</b></p>	<p>#1</p> <p>500 MCM 33%</p>	<p><b>Specification #2316 &amp; Addendum</b></p> <p><b>Specification #2316 &amp; Addendum</b></p>
<p>Copper Cable 15 KV Shielded 1 Conductor</p> <p>Stranded</p> 	<p>2-74-16 <b>5000157</b></p>	<p>1000 MCM</p>	<p><b>Specification #2322 &amp; Addendum</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Copper Cable 15 KV Concentric Neutral</p> <p>Stranded</p> 	<p>2-75-07 <b>5000158</b></p> <p>2-75-12 <b>5000159</b></p> <p>2-75-14 <b>5001330</b></p> <p>2-75-15 <b>5000160</b></p>	<p>#1</p> <p>250 MCM 33%</p> <p>500 MCM 33% 4.025 kg/m</p> <p>750 MCM 33% 5.630 kg/m</p>	<p><b>Specification #2316 &amp; Addendum</b></p> <p><b>Specification #2316 &amp; Addendum</b></p> <p><b>Specification #2316 &amp; Addendum</b></p> <p><b>Specification #2316 &amp; Addendum</b></p>
<p>Aluminum Cable 600 Volt XLPE Twisted Individual Conductors USEI90</p> 	<p>2-82-02 <b>5020779</b></p> <p>2-82-10 <b>5023025</b></p>	<p>#6 3 Conductor</p> <p>1/0-3C</p>	<p><b>Specification #2315 &amp; Addendum</b></p>
<p>Copper Cable 600 Volt XLPE Concentric Neutral</p> <p>Stranded</p>	<p>2-83-04 <b>5000161</b></p>	<p>#6 1 Conductor</p>	<p><b>Specification #2306 &amp; Addendum</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Copper Cable 600 Volt XLPE Concentric Neutral</p> <p>Stranded</p> 	<p>2-84-09 <b>5000162</b></p> <p>2-84-11 <b>5000163</b></p>	<p>2/0 2 Conductor &amp; Neutral</p> <p>4/0 2 Conductor &amp; Neutral</p>	<p><b>Specification #2308 &amp; Addendum</b></p> <p><b>Specification #2308 &amp; Addendum</b></p>
<p>Copper Cable 600 Volt XLPE Twisted Individual Conductors USEI90</p> 	<p>2-85-02 <b>5000164</b></p> <p>2-85-03 <b>5000165</b></p> <p>2-85-04 <b>5000166</b></p> <p>2-85-05 <b>5000167</b></p>	<p>#6 3 Conductor</p> <p>#6 4 Conductor</p> <p>#2 3 Conductor</p> <p>#2 4 Conductor</p>	<p><b>Specification #2312 &amp; Addendum</b></p> <p><b>Specification #2312 &amp; Addendum</b></p> <p><b>Specification #2312 &amp; Addendum</b></p> <p><b>Specification #2312 &amp; Addendum</b></p>
<p>Copper Cable 600 Volt XLPE Twisted Individual Conductors USEI90</p> 	<p>2-85-06 <b>5000168</b></p> <p>2-85-08 <b>5000169</b></p> <p>2-85-14 <b>5000170</b></p>	<p>2/0 3 Conductor</p> <p>4/0 3 Conductor</p> <p>500 MCM 4 Conductor</p>	<p><b>Specification #2312 &amp; Addendum</b></p> <p><b>Specification #2312 &amp; Addendum</b></p> <p><b>Specification #2312 &amp; Addendum</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Network Cable 600 Volt XLPE</p> <p>Stranded</p>	<p>2-85-21 <b>5000171</b></p> <p>2-85-22 <b>5000172</b></p> <p>2-85-23 <b>5000173</b></p> <p>2-85-31 <b>5000174</b></p>	<p>500 MCM Red 1 Conductor</p> <p>500 MCM Yellow 1 Conductor</p> <p>500 MCM Blue 1 Conductor</p> <p>750 MCM</p>	<p><b>Specification #2310 &amp; Addendum</b></p> <p><b>Specification #2310 &amp; Addendum</b></p> <p><b>Specification #2310 &amp; Addendum</b></p> <p><b>Specification #2314 &amp; Addendum</b></p>
<p>Copper Cable 1000 Volt RWU 90, XLPE</p> <p>Stranded</p> 	<p>2-87-04 <b>5000175</b></p> <p>2-87-06 <b>5000176</b></p> <p>2-87-09 <b>5000177</b></p> <p>2-87-11 <b>5000178</b></p>	<p>#6</p> <p>#2</p> <p>2/0</p> <p>4/0</p>	<p><b>Specification #2304 &amp; Addendum</b></p> <p><b>Specification #2304 &amp; Addendum</b></p> <p><b>Specification #2304 &amp; Addendum</b></p> <p><b>Specification #2304 &amp; Addendum</b></p>
<p>Copper Cable 600 Volt RW90 or Equivalent -40 degrees C. Rated, Standard Stranded Street Light Wire</p> 	<p>2-87-51 <b>5000179</b></p> <p>2-87-52 <b>5000180</b></p>	<p>#12 <b>Black</b></p> <p>#12 <b>White</b></p>	



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Control Cable 90 degrees C. PVC Jacket 600 Volt	2-88-02 <b>5016467</b>	#12 2 Conductor	<b>Specification #3306</b>
	2-88-04 <b>5016466</b>	#12 4 Conductor	<b>Specification #3306</b>
	2-88-07 <b>5000181</b>	#12 7 Conductor	<b>Specification #3306</b>
Control Cable 90 degrees C. PVC Jacket 600 Volt	2-88-16 <b>5000182</b>	#20 6 Pair	<b>Specification #3308</b>
	2-88-22 <b>5000183</b>	#20 12 Pair	<b>Specification #3308</b>
Communication Cable RS - 485	2-88-40 <b>5000184</b>	CAT 6 Ethernet Cable	

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Switchgear Cable	2-88-60 <b>5000185</b>	#12 AWG 65 Str	<b>S1S</b> 12-65 STR
	2-88-62 <b>5026770</b>	#14 AWG 41 Str	<b>S1S</b> 14-41 STR
Metering Coded Wire 600 Volt TWH 7 Strand 	2-89-00 <b>5000186</b>	#12 Yellow	<b>NEX</b> 12CU STR YEL
	2-89-01 <b>5000187</b>	#12 Red	<b>NEX</b> 12CU STR RED
	2-89-02 <b>5000188</b>	#12 Blue	<b>NEX</b> 12CU STR BLU
	2-89-03 <b>5000189</b>	#12 Green	<b>NEX</b> 12CU STR GRN
Metering Coded Wire 600 Volt TWH 7 Strand 	2-89-05 <b>5000190</b>	#12 Red/Black Stripe	<b>SYC</b> 12CU STR R/B
	2-89-06 <b>5000191</b>	#12 Red/White Stripe	<b>SYC</b> 12CU STR R/W
	2-89-07 <b>5000192</b>	#12 Yellow/Black Stripe	<b>SYC</b> 12CU STR Y/B
	2-89-08 <b>5000193</b>	#12 Yellow/White Stripe	<b>SYC</b> 12CU STR Y/W
	2-89-09 <b>5000194</b>	#12 Blue/Black Stripe	<b>SYC</b> 12CU STR BLU/B
	2-89-10 <b>5000195</b>	#12 Blue/White Stripe	<b>SYC</b> 12CU STR BLU/W


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Copper Conductor Soft Bare (Reels)</p> <p>Stranded</p> 	<p>2-90-04 <b>5000196</b></p> <p>2-90-05 <b>5000197</b></p> <p>2-90-06 <b>5000198</b></p> <p>2-90-09 <b>5000199</b></p> <p>2-90-13 <b>5000200</b></p> <p>2-90-14 <b>5000201</b></p>	<p>#6</p> <p>#4</p> <p>#2</p> <p>2/0</p> <p>350 MCM</p> <p>500 MCM</p>	<p><b>Specification #2302 &amp; Addendum</b></p> <p><b>Specification #2302 &amp; Addendum</b></p> <p><b>Specification #2302 &amp; Addendum</b></p> <p><b>Specification #2302 &amp; Addendum</b></p> <p><b>Specification #2302 &amp; Addendum</b></p> <p><b>Specification #2302 &amp; Addendum</b></p>
<p>Copperclad Steel Groundwire Copperweld 7 Stranded (Reels)</p> 	<p>2-91-05 <b>5026525</b></p> <p>2-91-09 <b>5000202</b></p>	<p>#4</p> <p>2/0</p>	<p><b>CW</b> Q6C7X0680A-CAMO</p> <p><b>CW</b> Q6C7X07A-CAMO</p>
<p>Fibre Optic Cable Single Mode, Indoor/Outdoor, Riser Rated</p> 	<p>2-92-00 <b>5000203</b></p> <p>2-92-10 <b>5000204</b></p>	<p>48 Fibres</p> <p>96 Fibres</p>	<p><b>Specification #2350</b> 2000 M Reels</p> <p><b>Specification #2350</b> 2000 M Reels</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Fibre Optic Cable Single Mode, Outdoor Non-Armoured Fig-8</p> 	<p>2-93-00 <b>5000205</b></p> <p>2-93-10 <b>5000206</b></p>	<p>48 Fibres</p> <p>96 Fibres</p>	<p><b>Specification #1350</b> 2000 M Reels</p> <p><b>Specification #1350</b> 2000 M Reels</p>
<p>Fibre Optic Cable Multi Mode Outdoor Drop</p> 	<p>2-94-00 <b>5000207</b></p> <p>2-94-10 <b>5018355</b></p>	<p>6 Fibres Loose Tube</p> <p>6 Fibres Tight Buffered</p>	<p><b>Specification #9106</b></p>
<p>Fibre Optic Cable Hybrid Indoor/Outdoor</p> 	<p>2-95-00 <b>5001494</b></p>	<p>48MMF/48SMF</p>	<p><b>Specification #9106</b></p>








DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Wood Pole 	3-07-35 <b>5000208</b>  3-07-40 <b>5000209</b>  3-07-45 <b>5000210</b>  3-07-50 <b>5000211</b>	35 Feet Approx. 750 lbs  40 Feet Approx. 970 lbs  45 Feet Approx. 1145 lbs  50 Feet Approx. 1365 lbs	<b>As per Specs</b>
Wood Pole 	3-07-55 <b>5000212</b>  3-07-60 <b>5000213</b>  3-07-65 <b>5000214</b>  3-07-70 <b>5000215</b>	55 Feet Approx. 1540 lbs  60 Feet Approx. 1935 lbs  65 Feet Approx. 2200 lbs  70 Feet Approx. 2640 lbs	<b>As per Specs</b>
Steel Pole - Distribution, Tapered, Buck Arm	3-08-55 <b>5001331</b>  3-08-60 <b>5000216</b>	55 Feet Approx. 3280 lbs  60 Feet	<b>Dwg Ts-193A, Ms-425            Specification 1520,            5350</b>  <b>Dwg Ts-229            Plus            General Specifications</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Steel Pole - Support	3-09-40 <b>5000217</b>	40 Feet	<b>Dwg #MS419 Specification 1524</b>
Fibreglass Distribution Pole	3-10-40 <b>5000218</b>	40 Feet	<b>Shakespeare</b>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Precast Concrete Base for Steel Streetlight Pole Multiport  Up to 25 Foot Single Davit  Up to 35 Foot Single Davit  Up to 35 Foot Double Davit Up to 40 Foot Single Davit  Up to 60 Foot 18 Meter and Highway	4-01-25 <b>5000219</b>  4-01-35 <b>5000220</b>  4-01-40 <b>5000221</b>  4-01-60 <b>5000222</b>	<u>Bolt Spacing</u>  7 1/16" (179 mm) O.C. Approx. 1000 lbs  8 1/8" (206 mm) O.C. Approx. 1500 lbs  9 3/16" (233 mm) O.C. Approx. 1900 lbs  10" (254 mm) O.C. Approx. 2300 lbs	<b>Dwg. L2s-176</b>  <b>Dwg. L2s-124</b>  <b>Dwg. L2s-130</b>  <b>Dwg. L2s-173</b>
Decorative Base Includes Two Interchangeable Halves  	4-02-10 <b>5000223</b>  4-02-20 <b>5000224</b>  4-02-30 <b>5000225</b>	Broadway - 30" Octagon  Spadina Promenade - 36" (For Shaft 4-15-21) Octagon  Brighton (For Shaft 4-15-70) Round	<b>Dwg. L2s - 135</b>  <b>Dwg. L2s - 162</b>
Steel Anchor Base for Steel Street Light Pole 18' Pathway  25' & 30' Single Overbraced 30' & 35' Single Davit  35' Single Overbraced 30' Double Overbraced 35' Double Davit  50' Two Fixtures	4-03-18 <b>5001332</b>  4-03-30 <b>5001333</b>  4-03-35 <b>5001334</b>  4-03-50 <b>5001335</b>	6 3/8" to 8 1/2" OC (162mm to 216mm) 48" Long, 6.63" Dia  6 3/8" to 9 7/8" OC (162mm to 252mm) 84" Long, 6.63" Dia  7 3/4" to 12" OC (198mm to 305mm) 84" Long, 8.6" Dia  9 7/8" to 11 5/8" OC (252mm to 296mm) 120" Long, 10.75" Dia	<b>HUB SA1122305</b> <b>RED LEAF 04-06-12</b> <b>MACP D06048BBB08118V</b>  <b>HUB T1121051</b> <b>RED LEAF 7612</b> <b>MACP D06084BBB08148V</b>  <b>HUB C11242QG4VP</b> <b>RED LEAF 7-08-14</b> <b>MACP D08084BBB11178V</b>  <b>HUB T1121083</b> <b>RED LEAF 10-10-16</b> <b>MACP D10120BBB11170V</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Steel Streetlight Pole For Single or Double Davit Arm</p> 	<p>4-10-20 <b>5000226</b></p> <p>4-10-24 <b>5000227</b></p> <p>4-10-25 <b>5000228</b></p>	<p>Shaft - 11 ft. long 20 ft. (6m) fxt height Galvanized</p> <p>Shaft - 15 ft. long 24 ft. (7m) fxt height Green</p> <p>Shaft - 15 ft. long 24 ft. (7m) fxt height Galvanized</p>	<p><b>Specification 5200, 5350</b> <b>Dwg L2s-191</b></p> <p><b>Specification 5200, 5350, 5365, 5390</b> <b>Dwg L2s-184</b></p> <p><b>Specification 5200, 5350</b> <b>Dwg L2s-184</b></p>
<p>Steel Streetlight Pole For Single or Double Davit Arm</p> 	<p>4-10-30 <b>5000229</b></p> <p>4-10-31 <b>5000230</b></p> <p>4-10-32 <b>5000231</b></p> <p>4-10-33 <b>5001336</b></p>	<p>Shaft 30 ft (9m) fxt. height 7 5/8" to 9 1/4" Blt Sp 19.7' (6m) long</p> <p>Green</p> <p>Black</p> <p>Grey</p> <p>Galvanized</p>	<p><b>Specification 5200, 5350, 5365, 5390</b> <b>Dwg L2s-138</b></p> <p><b>Dwg L2s-197</b></p> <p><b>Specification 5350</b></p>
<p>Steel Streetlight Pole For Single or Double Davit Arm</p> 	<p>4-10-35 <b>5000232</b></p> <p>4-10-36 <b>5000233</b></p> <p>4-10-37 <b>5000234</b></p> <p>4-10-38 <b>5000235</b></p> <p>4-10-39 <b>5000236</b></p>	<p>Shaft 35 ft (11m) fxt. height 7 5/8" to 9 7/8" Blt Sp 26.2' (8m) long</p> <p>Green</p> <p>Black</p> <p>Red</p> <p>Grey</p> <p>Galvanized</p>	<p><b>Specification 5200, 5350, 5365, 5390</b> <b>Dwg L2s-139</b></p> <p><b>Dwg L2s-198</b></p> <p><b>Specification 5350</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Steel Streetlight Pole For Single or Double Davit Arm 	4-10-43 <b>5000237</b>	Shaft 40 ft (12m) fxt. ht 7 1/2" to 9 1/4" Blt Sp 30.2' (9.2m) long  Galvanized	<b>Specification 5200 5350</b> <b>Dwg L2s-174</b>  <b>Specification 5350</b>
Steel Streetlight Pole For Single or Double Davit Arm 	4-10-60 <b>5000238</b>	Shaft 59 ft (18m) fxt. ht 9 3/4" to 10 1/4" Blt Sp 49.2' (15m) long  Galvanized	<b>Specification 5200 Dwg L2s-155</b>  <b>Specification 5350</b>
Steel Streetlight Arm Single Davit 	4-10-70 <b>5000239</b>  4-10-71 <b>5000240</b>  4-10-73 <b>5000241</b>	Arm 8 ft (2.5m) overhang  Green  Black  Galvanized	<b>Specification 5200, 5350, 5365, 5390</b> <b>Dwg L2s-137</b>  <b>Specification 5350</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Steel Streetlight Arm Single Davit</p> 	<p>4-10-75 <b>5000242</b></p> <p>4-10-79 <b>5000243</b></p>	<p>Arm 10 ft (3m) overhang</p> <p>Green</p> <p>Galvanized</p>	<p><b>Specification 5200, 5350, 5365, 5390 Dwg L2s-136</b></p> <p><b>Specification 5350</b></p>
<p>Steel Streetlight Arm Double Davit</p> 	<p>4-10-80 <b>5000244</b></p> <p>4-10-81 <b>5000245</b></p> <p>4-10-83 <b>5000246</b></p> <p>4-10-85 <b>5000247</b></p>	<p>Arm 10 ft (3m) overhang</p> <p>Green</p> <p>Black</p> <p>Galvanized</p> <p>Arm 15 ft (3m) overhang</p> <p>Galvanized</p>	<p><b>Specification 5200, 5350, 5365, 5390 Dwg L2s-227</b></p> <p><b>Specification 5200, 5350</b></p> <p><b>Dwg L2s-234</b></p>
<p>Steel Streetlight Arm</p> <p>For Use in Evergreen</p>	<p>4-10-90 <b>5000248</b></p>	<p>Galvanized</p>	<p><b>Specification 5200 Dwg L2s-199</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Steel Streetlight Pole For Single or Double Overhead Wired Arm</p> 	<p>4-11-25 <b>5000249</b></p> <p>4-11-30 <b>5000250</b></p> <p>4-11-35 <b>5000251</b></p>	<p>Galvanized</p> <p>Shaft 25 ft (7.6m) fxt. ht. 7" to 7 3/4" Blt Sp 25' (7.8m) long</p> <p>Shaft 30 ft (9m) fxt. ht. 7 1/2" to 8 1/4" Blt Sp 30' (9.1m) long</p> <p>Shaft 35 ft (11m) fxt. ht. 7 1/2" to 9 1/4" Blt Sp 35' (10.7m) long</p>	<p><b>Specification 5200, 5350</b> <b>Dwg L2s-220-01</b></p> <p><b>Dwg L2s-220-02</b></p> <p><b>Dwg L2s-220-03</b></p>
<p>Steel Streetlight Arm Overhead Wired <b>NOT FOR WOOD POLES</b></p>  <p>Old Style</p> 	<p>4-11-75 <b>5000252</b></p> <p>4-11-85 <b>5000253</b></p>	<p>Galvanized</p> <p>Arm 10 ft (3m) overhang</p> <p>Arm 15 ft (4.5m) overhang</p>	<p><b>Specification 5200, 5350</b> <b>Dwg L2s-220-04</b></p> <p><b>Dwg L2s-220-05</b></p>
<p>Steel Streetlight Pole For Double Elliptical Arm</p>	<p>4-13-37 <b>5000254</b></p>	<p>Shaft 34 ft (10.4m) fxt. ht. 8 1/2" to 9 1/2" Blt Sp 27.3' (8.3m) long</p> <p>Red</p>	<p><b>Specification 5200, 5350, 5365, 5390</b> <b>Dwg L2s-149-01</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Steel Streetlight Arm Double Elliptical	4-13-76 <b>5000255</b>  4-13-77 <b>5000256</b>	Arm 10 ft (3m) overhang  Black  Red	<b>Specification 5200,                      5350, 5365, 5390                      Dwg L2s-149-02</b>
Steet Streetlight Pole For Vector or Mongoose Lighting  Bottom Section        Top Section	4-14-25 <b>5000257</b>        4-14-50 <b>5000258</b>	Galvanized    7.874 m 25' 10"        7.38 m 25' 8" 50' (15.24m Pole)	<b>Specification 5200,                      5350                      Dwg L2s-160</b>
Steel Streetlight Pole For PTL, Washington, Marine & Shoebox Fixtures  	4-15-11 <b>5000259</b>  4-15-12 <b>5000260</b>  4-15-13 <b>5000261</b>	<u>Bolt Spacing</u> 6 3/4" to 8 1/8" 12 ft (3.66m) Base 6"  Black  Red  Brown	<b>Specification 5200,                      5350, 5365, 5390                      Dwg. L2s-148</b>







DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Steel Streetlight Pole For Washington Fixture Only</p> 	<p>4-15-21 <b>5000262</b></p>	<p><u>Bolt Spacing</u> 6 3/4" to 8 1/8" 12 ft (3.66m) Base 4.75"</p> <p>Black For Ornamental Base</p>	<p><b>Specification 5200, 5350, 5365, 5390 Dwg. L2s-169</b></p>
<p>Steel Streetlight Pole For PTL &amp; Marine Fixture</p> 	<p>4-15-30 <b>5000263</b></p> <p>4-15-31 <b>5000264</b></p> <p>4-15-33 <b>5000265</b></p> <p>4-15-35 <b>5000266</b></p>	<p><u>Bolt Spacing</u> 6 3/4" to 8 1/8" 18 ft (5m)</p> <p>Green</p> <p>Black</p> <p>Brown</p> <p>Grey</p>	<p><b>Specification 5200, 5350, 5365, 5390 Dwg. L2s-165</b></p>
<p>Steel Streetlight Pole</p> <p>For Use in Evergreen</p>	<p>4-15-50 <b>5000267</b></p>	<p><u>Bolt Spacing</u> 6 3/4" to 8 1/8" 18 ft (5m)</p> <p>Galvanized</p>	<p><b>Specification 5200 &amp; 5350 Dwg L2s-200</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Steel Streetlight Pole Brighton Subdivision	4-15-70 <b>5000268</b>	Black	<b>Specification 5200, 5350, 5365, 5390 Dwg L2s-239</b>
Steel Streetlight Arm Brighton Subdivision	4-15-80 <b>5000269</b>	Black	<b>Specification 5200, 5350, 5365, 5390 Dwg L2s-237</b>
Steel Streetlight Pole For Invue Fixture	4-16-10 <b>5000270</b>  4-16-12 <b>5000271</b>  4-16-16 <b>5000272</b>  4-16-23 <b>5000273</b>	Graphite Metallic  10 Foot  12 Foot  16 Foot  23 Foot	<b>Specification 5200, 5350, 5365, 5390</b>  <b>Dwg L2s-185-02</b>  <b>Dwg L2s-185-01</b>  <b>Dwg L2s-185-03 &amp; Dwg L2s-185-04</b>  <b>Dwg L2s-185-05</b>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Steel Streeilight Arm For Invue Fixture</p> <p>Flite Style</p>  <p>Slide Style</p> 	<p>4-16-30 <b>5000274</b></p> <p>4-16-32 <b>5000275</b></p> <p>4-16-34 <b>5000276</b></p>	<p>Graphite Metallic</p> <p>Arm Flite Style</p> <p>Arm Slide Style</p> <p>Arm Slide Style 250 Watt Only</p>	<p><b>CP FLS-ARM-GM</b></p> <p><b>CP SLS-ARM-GM</b></p> <p><b>CP SDM1-ARM-GM</b></p>
<p>Invue Decorative Base</p>	<p>4-16-50 <b>5000277</b></p> <p>4-16-51 <b>5000278</b></p>	<p>4" Hole</p> <p>5" Hole</p>	<p><b>CP 1000D49H01GM</b></p>
<p>Invue 18" Pole Extension &amp; Cap</p>	<p>4-16-52 <b>5000279</b></p>	<p>Graphite Metallic</p> <p>For use with 4-16-30 @ 12'Mounting height</p>	<p><b>Dwg L2s-185-01</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Icon Style Streetlighting</p> <p>Pole</p> <p>Arm</p>	<p>4-17-16 <b>5000280</b></p> <p>4-17-30 <b>5000281</b></p>	<p>16' Stone Grey</p> <p>Upsweep</p>	<p><b>Specification 5174 Dwg L2s-215</b></p> <p><b>CP VA1006 Specification 5174 Dwg L2s-215</b></p>
<p>Streetlight Elliptical Arm <b>FOR WOOD POLES</b></p> 	<p>4-20-02 <b>5000282</b></p> <p>4-20-06 <b>5000283</b></p> <p>4-20-10 <b>5000284</b></p> <p>4-20-12 <b>5000285</b></p> <p>4-20-18 <b>5000286</b></p>	<p>1 1/2" x 2'</p> <p>2" x 6'</p> <p>2" x 10'</p> <p>2" x 12'</p> <p>2" x 18'</p>	<p><b>Specification 5200, 5350 Dwg L2s-196-01</b></p> <p><b>Dwg L2s-196-02</b></p> <p><b>Dwg L2s-196-03</b></p> <p><b>Dwg L2s-196-04</b></p> <p><b>Dwg L2s-161-01&amp;02</b></p>
<p>Streetlight Arm For Marine Fixtures</p> 	<p>4-21-30 <b>5000287</b></p> <p>4-21-31 <b>5000288</b></p> <p>4-21-32 <b>5000289</b></p> <p>4-21-33 <b>5000290</b></p>	<p>30"</p> <p>Green</p> <p>Red</p> <p>Blue</p> <p>Black</p>	<p><b>Specification 5390 Dwg L2s-154 Colour as per Application</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Streetlight Arm For Marine Pendant Fixture</p> 	<p>4-22-30 <b>5000291</b></p>	<p>Black</p>	<p><b>Specification 5390</b> <b>Dwg L2s-188</b></p>
<p>Streetlight Arm Steel</p> <p>For use on 3rd Avenue</p> <p>For use in Kensington</p> <p>LED Floodlight Arm Attachment to wood pole</p>	<p>4-22-40 <b>5000292</b></p> <p>4-22-50 <b>5000293</b></p> <p>4-23-15 <b>5000294</b></p>	<p>6' Straight Graphite Metallic</p> <p>Decorative Black</p>	<p><b>Specification 5200,</b> <b>5350, 5390</b> <b>Dwg Ls-417-04</b></p> <p><b>Dwg L2s-230</b></p> <p><b>Dwg L2s-228</b></p>
<p>Streetlight Arm &amp; Bracket For Washington Fixtures</p> 	<p>4-23-30 <b>5000295</b></p> <p>4-23-31 <b>5000296</b></p>	<p>Black</p>	<p><b>HCI A316-1A-CM-6-</b> <b>RAL9011-BLACK</b></p> <p><b>HCI CLAMP-6-</b> <b>RAL9011-BLACK</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Streetlight Arms</p> <p>For Washington Fixtures on Wood Poles</p> <p>For Floodlights - Double Bullhorn</p> <p>For Offset Lighting - Double Bullhorn Mongoose/Vector</p> <p>For Offset Lighting - Triple Bullhorn Mongoose/Vector</p>	<p>4-23-40 <b>5000297</b></p> <p>4-24-10 <b>5000298</b></p> <p>4-24-20 <b>5000299</b></p> <p>4-24-21 <b>5000300</b></p>	<p>Black</p> <p>Green</p> <p>Galvanized</p> <p>Galvanized</p>	<p><b>Dwg L2s-168</b></p> <p><b>Dwg L2s-186-02</b></p> <p><b>Dwg L2s-186-01</b></p> <p><b>Dwg L2s-186-03</b></p>
<p>Arm Shoebox LED - Brown Single Arm</p>  <p>Double Arm</p> 	<p>4-25-05 <b>5000301</b></p> <p>4-25-06 <b>5026150</b></p>	<p>Sepia Brown</p> <p>Sepia Brown</p>	<p><b>Dwg L2s-226-02</b></p> <p><b>Dwg L2s-226-03</b></p>
<p>Steel Extensions For Combination Traffic and Streetlight Poles</p> <p>Black - For use in Kensington</p>	<p>4-26-04 <b>5000302</b></p> <p>4-26-06 <b>5000303</b></p> <p>4-26-12 <b>5000305</b></p> <p>4-26-13 <b>5000306</b></p>	<p><b>Graphite Metallic</b> Extension 4' Octagonal Pole</p> <p><b>Galvanized</b> Extension 6' Octagonal Pole</p> <p>Extension 12' Octagonal Pole</p> <p>Extension 13' Octagonal Pole</p>	<p><b>Dwg L2s-193</b></p> <p><b>Dwg L2s-170</b></p> <p><b>Dwg L2s-179</b></p> <p><b>Dwg L2s-229</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Steel Pole Tenon Adapter For Washington, Marine & PTL Fixtures	4-27-01 <b>500307</b>	Small Round (4") Sepia Brown (RAL8014)	<b>Dwg L2s-158-01</b>
	4-27-04 <b>500308</b>	Octagonal (4 5/8") Black	<b>Dwg L2s-147</b>
	4-27-05 <b>500309</b>	Small Round (5") Black	<b>Dwg L2s-158-01</b>
	4-27-06 <b>500310</b>	Medium Round (6") Black	<b>Dwg L2s-158-01</b>
	4-27-07 <b>500311</b>	Large Round (7") Blue	<b>Dwg L2s-158-01</b>
	4-27-09 <b>500312</b>	Large Round (9") Blue	<b>Dwg L2s-158-01</b>
Steel Pole Tenon Adapter For Mongoose Fixture	4-27-20 <b>500313</b>		<b>Dwg L2s-158-02</b>
Base Plate Adapter for Steel Pole    (Electronic Shop also use these)	4-28-07 <b>500314</b>  4-28-12 <b>500315</b>	Galvanized  1" Dia. Bolt <u>Bolt Spacing</u> 6 3/4" to 8 1/8" Height 7"  1" Dia. Bolt <u>Bolt Spacing</u> 6 3/4" to 8 1/8" Height 12"	<b>POLE Dwg L2s-133</b>  <b>POLE Dwg L2s-133</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Steel Streetlight Pole Extension</p> 	<p>4-29-12 <b>5000316</b></p>	<p>Galvanized  Bolt Spacing 7 11/16" to 10" Height 12"</p>	<p><b>Dwg L2s-195</b></p>
<p>Reaction Plates - Breakaway Base Small</p> <p>Medium &amp; Large</p> 	<p>4-33-35 <b>5000317</b></p> <p>4-33-50 <b>5000318</b></p>	<p>Use on New Installs  With 4-36-35  With 4-36-40 &amp; 4-36-50</p>	<p><b>Dwg L2S-232-04</b></p> <p><b>Dwg L2S-232-05</b></p>
<p>Couplers - Breakaway Base For Repairs</p> <p>35 Foot Single Davit</p> <p>35 Foot Double Davit 40 Foot Single Davit 50 Foot Highway</p>	<p>4-36-35 <b>5000319</b></p> <p>4-36-40 <b>5000320</b></p>	<p>1" Dia. Bolt Round</p> <p>1 1/4" Dia. Bolt Round</p>	<p><b>SB C-5</b></p> <p><b>SB C-7</b></p>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Shroud - Breakaway Base</p> <p>35 Foot Single Davit</p> <p>35 Foot Double Davit 40 Foot Single Davit</p> <p>50 Foot Vector Lighting</p> 	<p>4-37-35 <b>5000321</b></p> <p>4-37-40 <b>5000322</b></p> <p>4-37-50 <b>5000323</b></p>	<p>Stainless Steel</p> <p>For 8 1/8" On Square</p> <p>For 9 3/16" On Square</p> <p>For 10 1/4" On Square</p>	<p><b>Dwg L2S-232-01</b> <b>SB S-3C</b></p> <p><b>Dwg L2S-232-02</b> <b>SB S-5C</b></p> <p><b>Dwg L2S-232-03</b> <b>SB S-8C</b></p>
<p>Hand Hole Assembly</p> 	<p>4-38-01 <b>5000324</b></p> <p>4-38-21 <b>5000325</b></p> <p>4-38-30 <b>5000326</b></p> <p>4-38-40 <b>5000327</b></p>	<p>Bolt to be cadmium</p> <p>6" - Primed</p> <p>12" - Galvanized</p> <p>12" Rectangle- Primed</p> <p>12" For 4" Round Pole Graphite Metalic</p>	<p><b>CIM</b></p> <p><b>Dwg L2s 194-01</b></p> <p><b>Dwg L2s 194-02</b></p> <p><b>Dwg L2s 194-03</b></p> <p><b>Dwg L2s 194-04</b></p>
<p>Backer Bar for Handhole</p>  <p>Tamper Proof Bolts</p>	<p>4-38-50 <b>5000328</b></p> <p>4-39-01 <b>5000329</b></p>	<p>14" x 1.5" x .25" c/w Threaded Insert</p> <p>3/8" x 4" SS</p>	<p><b>BRYCE 3GMRR37400</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Cable Retainer</p> 	<p>4-40-10 <b>5000331</b></p>	<p>6" Foundation Anchor</p>	<p><b>PELCO</b> SP-6200-GLV</p>
<p>Cobra Head Fixture - LED Local Roadway</p> 	<p>4-51-05 <b>5000332</b></p>	<p>34 Watt 120/277 Volt w receptacle</p>	<p><b>Leotek</b> GCJ1-20H-MV-WW- 2R-GY-530-PCR7</p>
<p>Cobra Head Fixture - LED Collector Roadway</p> 	<p>4-51-10 <b>5000333</b></p>	<p>47 Watt 120-277 Volt w receptacle</p>	<p><b>GE Current</b> ERL1006B330- AXXXXILR</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Cobra Head Fixture - LED Arterial Roadway</p> 	<p>4-51-15 <b>5000334</b></p> <p>4-51-18 <b>5000335</b></p> <p>4-51-20 <b>5000336</b></p>	<p>64 Watt 120-277 Volt w receptacle</p> <p>64 Watt 347 Volt w receptacle</p> <p>120-277 Volt w receptacle</p> <p><b>LED Roadway (115W)</b> L6-060M-5-7-2ES-W-S-GY-3-UL-2-S-A-0628</p> <p><b>Leotek (123 W)</b> GCM3-60J-MV-30K-2R-GY-170-PCR7-SP2-WL</p> <p><b>ACUITY (130W)</b> ATB2-60BLEDE70-MVOLT-R2-3K-P7-RAL7035-RFD312465</p>	<p><b>Leotek</b> GCJ3-30J-MV-30K-2R-GY-90-PCR7-WL</p> <p><b>Leotek</b> GCJ3-30J-HV-30K-2R-GY-075-PCR7-WL</p> <p><b>LITH RSX2 LED P3</b> 30K R3 MVOLT IS PER7 DNAXD <b>CP GAN-AF-05-LED-U-T2R-AP-ADJS-8030-600-4N7-TH</b></p>
<p>Mongoose Fixture - LED</p> 	<p>4-56-42 <b>5000338</b></p> <p>4-56-92 <b>5000341</b></p>	<p>4COB/168W 347/600 V Low Angle</p> <p>9COB/367W 347/600 V High Angle</p>	<p><b>HOL MGLED-43KAHWLVGNL</b></p> <p><b>HOL MGLED-93KAHWLVGNL</b></p>
<p>Highway Fixture - LED</p> 	<p>4-57-51 <b>5000343</b></p> <p>4-57-52 <b>5000344</b></p>	<p><b>120/240 V</b> RSX2-P3/147W</p> <p>5 Square/162W</p> <p><b>347/600 V</b> RSX2-P3/147W</p> <p>5 Square/162W</p>	<p><b>LITH RSX2 LED P3</b> 30K R3 MVOLT IS PER7 DNAXD <b>CP GAN-AF-05-LED-U-T2R-AP-ADJS-8030-600-4N7-TH</b></p> <p><b>LITH RSX2 LED P3</b> 30K R3 HVOLT IS PER7 DNAXD <b>CP GAN-AF-05-LED-9-T2R-AP-ADJS-8030-600-4N7-TH</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Highway Fixture - LED</p> 	<p>4-57-54 <b>5000345</b></p>	<p><b>120/240 V</b> Horizontal Tenon RSX2-P3/147W 5 Square/162W</p>	<p><b>LITH RSX2 LED P3</b> 30K R3 MVOLT MA PER7 DNAXD <b>CP GAN-AF-05-LED-</b> U-T2R-AP-MA- 8030-600-4N7-TH</p>
<p>Highway Fixture - LED</p> 	<p>4-57-81 <b>5000346</b></p> <p>4-57-82 <b>5000347</b></p>	<p><b>120/240 V</b> RSX3-P3/266W</p> <p>8 Square/257W</p> <p><b>347/600 V</b> RSX3-P3/266W</p> <p>8 Square/257W</p>	<p><b>LITH RSX3 LED P3</b> 30K R3 MVOLT IS PER7 DNAXD <b>CP GAN-AF-08-LED-</b> U-T2R-AP-ADJS- 8030-600-4N7-TH</p> <p><b>LITH RSX3 LED P3</b> 30K R3 HVOLT IS PER7 DNAXD <b>CP GAN-AF-08-LED-</b> 9-T2R-AP-ADJS- 8030-600-4N7-TH</p>
<p>Galleon Fixture - LED</p> 	<p>4-57-91 <b>5000348</b></p> <p>4-57-92 <b>5000349</b></p>	<p>10 Square/323W 120/240 V</p> <p>10 Square/323W 347/600 V</p>	<p><b>CP GAN-AF-10-LED-</b> U-T2R-AP-ADJS- 8030-600-4N7-TH</p> <p><b>CP GAN-AF-10-LED-</b> 9-T2R-AP-ADJS- 8030-600-4N7-TH</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>High Mast Fixture</p> 	<p>4-58-10 <b>5026247</b></p>	<p>582 Watt LED 347/600 Volt</p>	<p><b>HOL</b> HMLED4 P4 30K HVOLT HGR AW- PR7 PCL3</p>
<p>Washington Fixture</p> 	<p>4-60-05 <b>5000350</b></p> <p>4-60-25 <b>5000351</b></p>	<p>Black</p> <p>35 Watt LED 120/240 Volt</p> <p>120 Watt LED 120/240 Volt</p>	<p><b>STERN</b> PT-A850SRLE D5P-2ARC27T3R- MDL03-A-BK <b>No Substitutes</b></p> <p><b>STERN</b> PT-A850S RLED-5P-24L27T4- MDL018-A-BK <b>No Substitutes</b></p>
<p>Fixtures - For use on 2nd Ave</p> <p>Pathway Fixture LED</p>  <p>Roadway Fixture LED</p>	<p>Charcoal Grey</p> <p>4-61-05 <b>5000352</b></p> <p>4-61-10 <b>5000353</b></p>	<p>20 Watt 120/277 Volt</p> <p>100 Watt 120/277 Volt</p>	<p><b>CYCLONE</b> CLE17T4C-FGC-4- 20W-3K-240-R30- RAL7026-TX</p> <p><b>CYCLONE</b> CLE17T4C-FGC-4- 100W-3K-240-R30- RAL7026-TX</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Euro Series Fixture</p> 	<p>4-62-03 <b>5000354</b></p>	<p>For Central Avenue</p> <p>20 Watt LED</p>	<p><b>STERN E350LED-SF-12L30T5-MDL006-SV1/BKT</b></p>
<p>Villa Maria Fixture</p> 	<p>4-63-05 <b>5020814</b></p> <p>4-63-10 <b>5020805</b></p>	<p>23 Watt LED 120/240 Volt</p> <p>112 Watt LED 120/240 Volt</p>	<p><b>CYCLONE VMAT4A-NL-T1-P10-30K-MVOLT-10KV-R30-BK-TX</b></p> <p><b>CYCLONE VMAT4A-NL-T3M-P70-30K-MVOLT-10KV-R30-BK-TX</b></p>
<p>Marine Fixture LED</p> 	<p>4-65-01 <b>5000355</b></p> <p>4-65-02 <b>5000356</b></p>	<p>35 Watt 120/277 Volt 23" Brim <b>Blue</b></p> <p>35 Watt 120/277 Volt 23" Brim <b>Black Currant</b></p>	<p><b>HCI SF130-S-CPC-LED35W-3000K-120-277V-TYPEIII-DIM-RAL5015</b></p> <p><b>HCI SF130-S-CPC-LED35W-3000K-120-277V-TYPEIII-DIM-RAL3005</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Marine Fixture LED</p> 	<p>4-65-07 <b>5000357</b></p> <p>4-65-08 <b>5000358</b></p>	<p>35 Watt 120/277 Volt 23" Brim <b>Green</b></p> <p>35 Watt 120/277 Volt 23" Brim <b>Red</b></p>	<p><b>HCI SF130-S-CPC-LED35W-3000K-120-277V-TYPEIII-DIM-RAL6029</b></p> <p><b>HCI SF130-S-CPC-LED35W-3000K-120-277V-TYPEIII-DIM-RAL3002</b></p>
<p>Marine Fixture LED</p> 	<p>4-65-10 <b>5000359</b></p> <p>4-65-11 <b>5000360</b></p>	<p>55 Watt 120/277 Volt 23" Brim <b>Green</b></p> <p>35 Watt 120/277 Volt 23" Brim <b>Black</b></p>	<p><b>HCI SF130-S-CPC-LED55W-3000K-120-277V-TYPEIII-DIM-RAL6029</b></p> <p><b>HCI SF130-S-CPC-LED35W-3000K-120-277V-TYPEIII-DIM-RAL9017</b></p>
<p>Marine Fixture HPS</p> 	<p>4-65-27 <b>5000361</b></p>	<p>250 Watt 120/240 Volt 32" Brim <b>Blue</b></p>	<p><b>SDL SLF985-RD3-250S-120/240-CC Specification 5150, 5390 Dwg L2s-153</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Pendant Marine Fixture - LED  	4-66-10 <b>5001337</b>  4-66-25 <b>5001338</b>	Black  54 Watt LED 120/277 Volt  100 Watt LED 120/277 Volt	<b>HCI F172-L-MOD-54WLED-120-277V-IES3-HSS-RAL9011</b>  <b>HCI F172-L-MOD-100WLED-120-277V-IES3-HSS-RAL9011</b>
LED Retro Fit Kit for Marine Fixture	4-66-30 <b>5017828</b>  4-66-35 <b>5017839</b>	54 Watt LED 120/277 Volt  100 Watt LED 120/277 Volt	<b>HCI RETRO-FIT-LED-F172-L-MOD-54WLED-120-277V-IES3</b>  <b>HCI RETRO-FIT-LED-F172-L-MOD-100WLED-120-277V-IES3</b>
Fixtures & Poles - For use on 3rd Avenue  Pedestrian Pole & Fixture  Historical Pendant Fixture	4-67-05 <b>5000362</b>  4-67-25 <b>5000363</b>	Graphite Metallic  12' & 50 Watt MH  120 Watt LED 347 Volt	<b>Specification 5111 Dwg L2s-218</b>  <b>HCI F302-MOD-CTG-120W-LED-347V-IES3-3000K-FINIAL-MOD-CUSTOM-COLOR</b>








DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Fixtures - For use in Kensington</p> <p>Historical Pendant Fixture LED Collector Roadway</p> 	<p>4-68-10 <b>5000365</b></p>	<p>Black</p> <p>120 Watt 120-277 Volt 4000K</p>	<p><b>HCI</b> F302-MOD-L-LTG-120W-LED-3000K-120-277V-IES3-MOD-FINIAL-RAL9017</p>
<p>Fixture Brighton Pendant LED</p> 	<p>4-69-05 <b>5000366</b></p>	<p>Black</p> <p>140 Watt 120/277 Volt</p>	<p><b>CYCLONE</b> CO12P1B-FGC-4-140W-3K-240-R30-RAL7026-TX</p>
<p>Pathway Fixture</p> 	<p>4-71-05 <b>5000368</b></p>	<p>15 Watt 120/277 V, 3000K with receptacle RAL8014-Sepia Brown</p>	<p><b>Leotek</b> GCJ0-15H-MV-WW-2R-CC-300-PCR7</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Wallpack Fixture</p> 	<p>4-72-07 <b>5000369</b></p> <p>4-72-08 <b>5000370</b></p> <p>4-72-10 <b>5000371</b></p> <p>4-72-11 <b>5000372</b></p>	<p>30 Watt LED 120/277 Volt Fail Safe</p> <p>30 Watt LED 347 Volt Fail Safe</p> <p>Bronze 30/40/60W Selectable 120-347V, 3000K/4000K/5000K Selectable</p> <p>40 Watt LED 347 Volt, 3000K5 w/o receptacle</p>	<p><b>CP G12-LD4-30W-30-CL-UNV-EDC1-CSTG/BZ</b></p> <p><b>CP G12-LD4-30W-30-CL-347V-EDC1-CSTG/BZ</b></p> <p><b>Keene WP-60-SCT-G2-10-BZ</b> <b>Lumark WPMLED15S</b></p>
<p>Floodlight Fixture - LED</p> <p>Traffic Bridge Pedestrian</p> 	<p>4-73-00 <b>5000373</b></p> <p>4-73-25 <b>5000374</b></p> <p>4-73-26 <b>5000375</b></p>	<p>Bronze</p> <p>25 Watt LED</p> <p>Order Slipfit knuckle</p> <p>129 Watt LED 120/277 Volt, 3000K</p> <p>Top &amp; Side Visor</p>	<p><b>HUB FSL-10L-25-3K-RM-U-K-DB S-302-M51</b></p> <p><b>CP NFFLD-C40-E-UNV-66-S-CB-7030</b> <b>No alternates</b></p> <p><b>CP TS2/NFFLD-CB</b></p>
<p>Invue Fixture - LED</p> 	<p>4-76-05 <b>5000377</b></p> <p>4-76-10 <b>5000378</b></p> <p>4-76-25 <b>5000379</b></p>	<p>Graphite Metallic</p> <p>25 Watt LED</p> <p>50 Watt LED</p> <p>125 Watt LED</p>	<p><b>CP ICS-E01-LED-E1-T3-GM-LCF</b></p> <p><b>CP ICS-E02-LED-E1-T3-GM-LCF</b></p> <p><b>CP ICM-E05-LED-E1-T3-GM-LCF</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Icon Fixture - LED</p> 	<p>4-77-10 <b>5000380</b></p>	<p>Stone Grey  50 Watt LED</p>	<p>CP ICS-E02-LED-E1-T3-RAL7030-LCF (VA1006-xx) Specification 5174 Dwg Ls-215</p>
<p>LED Fixture - For Use In Evergreen</p> <p>Pathway</p> <p>Roadway</p> <p>Roadway (Wide)</p> 	<p>4-78-05 <b>5000381</b></p> <p>4-78-10 <b>5000382</b></p> <p>4-78-15 <b>5000383</b></p>	<p>22 Watt LED w/o Receptacle</p> <p>55 Watt LED w/o Receptacle</p> <p>107 Watt LED 120/240 Volt w/o Receptacle</p>	<p><b>LED</b> SAT-24S-280mA-T2</p> <p><b>LED</b> SAT-48S-0-S-T2-350-GY-1-A-NS-XX</p> <p><b>LED</b> SAT-72M-450mA-T3</p>
<p>High Pressure Sodium Vapor Lamp Mogul Base, 30,000 Hour Non-cycling</p> 	<p>4-80-05 <b>5000384</b></p> <p>4-80-07 <b>5001339</b></p> <p>4-80-10 <b>5001340</b></p> <p>4-80-15 <b>5001341</b></p>	<p><b>30,000 Hour Non-cycling</b> 50 Watt</p> <p>70 Watt</p> <p>100 Watt</p> <p>150 Watt</p>	<p><b>SYL LU50/Plus/Eco</b></p> <p><b>SYL LU70/Plus/Eco</b> <b>GE LU70/Eco/NC</b></p> <p><b>SYL LU100/Plus/Eco</b> <b>GE LU100/Eco/NC</b></p> <p><b>SYL LU150/Plus/Eco</b> <b>GE LU150/Eco/NC</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>High Pressure Sodium Vapor Lamp Mogul Base</p> 	<p>4-80-20 <b>5000385</b></p> <p>4-80-25 <b>5000386</b></p> <p>4-80-40 <b>5000387</b></p>	<p><b>60,000 Hour Non-cycling</b> 200 Watt</p> <p>250 Watt</p> <p>400 Watt</p>	<p><b>SYL LU200/Plus/</b> XL/Eco</p> <p><b>SYL LU250/Plus/</b> XL/Eco</p> <p><b>SYL LU400/Plus/</b> XL/Eco</p>
<p>Metal Halide Lamp Medium Base</p> 	<p>4-81-07 <b>5000391</b></p> <p>4-81-40 <b>5000394</b></p>	<p>70 Watt</p> <p>400 Watt Mogul Base</p>	<p><b>PHI MHC70/U/M/4K/</b> ELITE</p> <p><b>PHI CDM330/U/O/4K/</b> ED28</p>
<p>LED Lamp - Warm White</p> <p>LED Lamp - Cool White</p> <p>LED Lamp - Red</p> <p>LED Lamp - Green</p> <p>LED Lamp - Blue</p>	<p>4-82-01 <b>5000395</b></p> <p>4-82-02 <b>5000396</b></p> <p>4-82-04 <b>5000397</b></p> <p>4-82-05 <b>5000398</b></p> <p>4-82-06 <b>5000399</b></p>	<p>C7</p>	<p><b>Specifications 5430</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>LED Lamp - Warm White</p> <p>LED Lamp - Cool White</p> <p>LED Lamp - Yellow</p> <p>LED Lamp - Red</p> <p>LED Lamp - Green</p> <p>LED Lamp - Blue</p>	<p>4-82-11 <b>500400</b></p> <p>4-82-12 <b>500401</b></p> <p>4-82-13 <b>500402</b></p> <p>4-82-14 <b>500403</b></p> <p>4-82-15 <b>500404</b></p> <p>4-82-16 <b>500405</b></p>	C9	Specifications 5430
<p>Pigtail Socket</p> 	<p>4-83-01 <b>500406</b></p>	120 Volt Only	Leviton 55 Eaton 145
<p>In-Line Fuse Holder Breakaway For 240 &amp; 347 V</p> 	<p>4-83-05 <b>500407</b></p> <p>4-83-06 <b>500408</b></p>	<p>600 Volt 30 Amp 100 kA #12 to #12</p> <p>600 Volt 30 Amp 100 kA #2 to #6</p>	<p><b>AM 65U</b> (No Subs)</p> <p><b>SHAW FEB-41-41-BA</b> <b>BUSS HEB-DW-</b> <b>RLC-B</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Photo Electric Cell</p>  <p>Latitude IQ</p>	<p>4-83-10 <b>5001342</b></p> <p>4-83-11 <b>5000409</b></p> <p>4-83-12 <b>5000410</b></p>	<p>120 Volt 1000 Watt</p> <p>120 Volt 1800 Watt</p> <p>120 Volt Green</p>	<p><b>FP 7760 SS9 PREC EXDV-AP-TD INT LED4536SC</b></p> <p><b>INT LC4536</b></p>
<p>Photo Electric Cell Bracket 3 Prong Type</p> 	<p>4-83-20 <b>5001343</b></p>		<p><b>FP S476-71 PREC M2A</b></p>
<p>Photo Electric Cell Shorting Cap</p> 	<p>4-83-25 <b>5001344</b></p>	<p>Min 15A Max 480V</p>	<p><b>FP FPS1039 PREC JP275 Ripley Lighting Controls 6005M-320V</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Street Light Relay Double Pole 	4-83-30 <b>5000411</b>	100 Amp 120/240 Volt	<b>Dwg L2-210</b>
Contactor - Three Pole 	4-83-35 <b>5000412</b>  4-83-36 <b>5000413</b>	60 Full Amp 75 Resistance Load Amps  90 Full Amp 120 Resistance Load Amps Coil 120 Volt	<b>Sq D 8910DPA63V02</b>  <b>Sq D 8910DPA93V02</b>
Coils  For 60A Contactor  For 90A Contactor	4-83-40 <b>5000414</b>  4-83-41 <b>5000415</b>  4-83-42 <b>5000416</b>  4-83-43 <b>5000417</b>	120 Volt  240 Volt  120 Volt  240 Volt	<b>Sq D 9998DA2V02</b>  <b>Sq D 9998DA2V09</b>  <b>Sq D 9998DA3V02</b>  <b>Sq D 9998DA3V09</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Primary Oil Switch Single Phase (Solenoid operated)</p> 	<p>4-83-50 <b>5000418</b></p>	<p>70 Amp 2400 Volt</p>	
<p>Circuit Breaker 1 Pole</p> 	<p>4-83-55 <b>5000419</b></p>	<p>120/240 Volt 15 Amp</p>	<p><b>SQ D QOU115</b></p>
<p>Circuit Breaker 2 Pole</p>	<p>4-83-60 <b>5000420</b></p> <p>4-83-65 <b>5000421</b></p>	<p>120/240 Volt 60 Amp</p> <p>120/240 Volt 100 Amp</p>	<p><b>SQ D QOU 260</b></p> <p><b>SQ D QOU 2100</b></p>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Weatherhead For Overbraced Street Light Pole	4-83-75 <b>5000422</b>	3/4" CAST ALUMINUM SERVICE ENTRANCE	<b>IBV CIEFSA-3/4</b>
Power Distribution Block  	4-84-10 <b>5000423</b>	3 Pole/460 Amps	<b>ILS PDB-212-4/0-3</b>
LED Retro Fit Kit for Invue Fixture	4-92-05 <b>5000441</b>  4-92-10 <b>5000442</b>  4-92-25 <b>5000443</b>	25 Watt replaces 50 Watt MH 120/240 Volt  50 Watt replaces 100 Watt MH 120/240 Volt  125 Watt replaces 250 Watt MH 120/240 Volt	<b>CP PDR64597-FLS- E01-LED-E1-T3- GM-RETRO</b>  <b>CP PDR60272-SDS- E02-LED-E1-T3- GM-RETRO</b>  <b>CP PDR60271-SDM- E05-LED-E1-T3- GM-RETRO</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Ballast for Pedestrian Fixture	4-92-45 <b>5000444</b>	50 Watt MH 120/277/347 Volt	STAN 10067
	4-92-50 <b>5000445</b>	100 Watt MH 120/277/347 Volt	STAN 10069
Refractor  Wallpack Fixture    PTL Fixture Trouble Shift	4-93-10 <b>5000446</b>	100 Watt HPS Glass or Acrylic	HOL 579B
	4-93-11 <b>5000447</b>	100 Watt	AE RK245 R2/R3 AY
Black Acorn Globe for Washington Fixture	4-93-20 <b>5000448</b>	50 Watt	DIV HS1-BLK


<b>DESCRIPTION OF ITEM</b>	<b>DEPT. CODE NUMBER</b>	<b>SIZE / WEIGHT</b>	<b>ORDERING INFORMATION</b>
Banner Hardware  Bracket Black    Arm	4-95-01 <b>5000450</b>    4-95-02 <b>5000451</b>	Black    31" Black Casting Fibreglass Rod	BannerFlex D3    BannerFlex D3

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Parallel Groove Copper Compression Connector  	5-00-01 <b>5001345</b>  5-00-02 <b>5001346</b>  5-00-04 <b>5001347</b>  5-00-05 <b>5001348</b>	4 STR - 6 STR  4 STR - 4 STR  2 STR - 4 STR  2 STR - 2 STR	<b>BUR Crimpit YC4C6</b> <b>ILS ULT-4-Z</b> <b>T&amp;B BC46</b>  <b>BUR Crimpit YC4C4</b> <b>ILS ULT-5-Z</b> <b>T&amp;B BC44</b>  <b>BUR Crimpit YC2C4</b> <b>ILS ULT-6-Z</b> <b>T&amp;B BC24</b>  <b>BUR Crimpit YC2C2</b> <b>ILS ULT-7-Z</b> <b>T&amp;B BC22</b>
Parallel Groove Copper Compression Connector  	5-00-06 <b>5001349</b>  5-00-07 <b>5001350</b>  5-00-08 <b>5001351</b>	1/0 2/0 STR - 1/0 2/0 STR  3/0-4/0 - #6-#2  3/0 4/0 - 1/0 2/0 STR	<b>BUR Crimpit YC26C26</b> <b>T&amp;B BC2020</b> <b>ILS ULT-9-Z</b>  <b>T&amp;B CC402</b> <b>HOM CC402</b> <b>BUR Crimpit YC28C2</b> <b>ILS ULT-10-Z</b>  <b>BUR Crimpit YC28C26</b> <b>HOM CC4020</b> <b>T&amp;B BC4020</b> <b>ILS ULT-11-Z</b>
Parallel Groove Copper Compression Connector  	5-00-09 <b>5001352</b>	3/0 4/0 - 3/0 4/0 STR	<b>BUR Crimpit YC28C28</b> <b>ILS ULT12-Z</b> <b>T&amp;B BC4040</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Copper Compression Connector - Grounding</p> 	<p>5-00-12 <b>5001353</b></p> <p>5-00-14 <b>5001354</b></p>	<p>#2 2/0 STR 5/8" Rod</p> <p>300 500 MCM 5/8" Rod</p>	<p><b>BUR YGHR 26C58</b> <b>ILS RLT3</b> <b>T&amp;B GR58-202</b></p> <p><b>BUR YGHR 34C58</b> <b>ILS RLT8</b> <b>T&amp;B GR58-300500</b></p>
<p>Copper Compression Connector - Grounding</p> 	<p>5-00-16 <b>5001355</b></p> <p>5-00-17 <b>5001356</b></p>	<p>2/0 to #8, #2</p> <p>300 - 500 MCM Run to 300 - 500 MCM Tap</p>	<p><b>BUR YC26C2</b> <b>T&amp;B BC202</b></p> <p><b>BUR YGHC34C34</b> <b>T&amp;B CTP500500</b></p>
<p>Copper Compression Connector - Grounding</p> 	<p>5-00-18 <b>5001357</b></p> <p>5-00-19 <b>5001358</b></p>	<p>1/0, 2/0 STR 250, 500 MCM</p> <p>350 MCM Run to 350 MCM Tap</p>	<p><b>BUR YGHP 34C26</b> <b>ILS GGC-6</b> <b>T&amp;B 54890</b></p> <p><b>BUR YGHP 34C34</b> <b>ILS GGC-8</b> <b>T&amp;B 54900</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Parallel Groove Aluminum Compression Connector for Copper, Aluminum, ACSR, AAAC &amp; 5005</p> 	<p>5-00-30 <b>5023024</b></p> <p>5-00-31 <b>5000452</b></p> <p>5-00-32 <b>5000453</b></p>	<p>3/0, 2/0, 1/0 STR 2/0, 1/0, 1 ACSR</p> <p>St. Ltg. Trp. 6, 4 ACSR 2, 4 ACSR Comp. 6, 4, 2 STR Alum &amp; Cu 14 SOL, 8 STR Alum &amp; CU</p> <p>6, 4, 3, 2 SOL - 6, 4, 3, 2 SOL 6, 4, 3 STR 6, 4 ACSR - 6, 4 ACSR</p>	<p><b>BLK WR279</b></p> <p><b>BLK WR9</b> <b>NO SUBS</b></p> <p><b>BLK WR159</b> <b>NO SUBS</b></p>
<p>Parallel Groove Aluminum Compression Connector for Copper, Aluminum, ACSR, AAAC &amp; 5005</p> 	<p>5-00-33 <b>5000454</b></p> <p>5-00-34 <b>5000455</b></p>	<p>2, 1, 1/0, 2/0 STR - 6, 4, 3, 2 1 STR 2, 1, 1/0 2/0 ACSR - 6, 4 3, 2, 1 ACSR</p> <p>1/0, 2/0 STR - 1/0, 2/0 STR 1/0, 2/0 ACSR - 1/0, 2/0 ACSR</p>	<p><b>BLK WR189</b> <b>NO SUBS</b></p> <p><b>BLK WR259</b> <b>NO SUBS</b></p>
<p>Parallel Groove Aluminum Compression Connector for Copper, Aluminum, ACSR, AAAC &amp; 5005</p> 	<p>5-00-35 <b>5000456</b></p> <p>5-00-36 <b>5000457</b></p>	<p>2/0, 3/0 STR - 3, 2, 1 STR 1/0, 2/0, 3/0 ACSR - 4, 3, 2, 1 ACSR</p> <p>4/0, 250 STR - 3/0, 4/0 250 STR 3/0, 4/0 ACSR - 3/0, 4/0 ACSR</p>	<p><b>BLK WR289</b> <b>NO SUBS</b></p> <p><b>BLK WR419</b> <b>NO SUBS</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Parallel Groove Aluminum Compression Connector for Copper, Aluminum, ACSR, AAAC &amp; 5005</p> 	<p>5-00-37 <b>5000458</b></p> <p>5-00-38 <b>5000459</b></p> <p>5-00-39 <b>5000460</b></p>	<p>4/0, 250 STR - 1/0, 2/0, 3/0 STR 4/0 ACSR - 1/0 2/0 ACSR</p> <p>4/0, 250 STR - 3, 2, 1 STR 4/0 ACSR - 4, 3, 2, 1 ACSR</p> <p>477 MCM STR - 4, 2/0 STR 477 MCM ACSR - 6, 1/0 ACSR</p>	<p><b>BLK WR399</b> <b>NO SUBS</b></p> <p><b>BLK WR379</b> <b>NO SUBS</b></p> <p><b>BLK WR815</b> <b>NO SUBS</b></p>
<p>Parallel Groove Aluminum Compression Connector for Copper, Aluminum, ACSR, AAAC &amp; 5005</p> 	<p>5-00-41 <b>5000461</b></p> <p>5-00-43 <b>5000462</b></p> <p>5-00-45 <b>5000463</b></p>	<p>336, 477 ACSR - 250, 500 STR 2/0, 4/0 ACSR - 2/0, 4/0 STR</p> <p>336, 477 ACSR 250, 500 STR - 336 ACSR 250, 350 STR</p> <p>477 ACSR/Alum - 477ACSR/Alum</p>	<p><b>BLK WR835</b> <b>NO SUBS</b></p> <p><b>BLK WR875</b> <b>NO SUBS</b></p> <p><b>BLK WR885</b> <b>NO SUBS</b></p>
<p>Split Bolt Connector For Copper to Copper</p> 	<p>5-01-01 <b>5001359</b></p> <p>5-01-02 <b>5001360</b></p> <p>5-01-04 <b>5001361</b></p>	<p>MAIN Max-6 SOL Min-10 SOL TAP Max-6 SOL Min-12 SOL</p> <p>MAIN-#2 STR TAP Max-#2 STR Min-#14 STR</p> <p>MAIN-#4 STR TAP Max-#4 STR Min-#14 STR</p>	<p><b>BLK 6H</b> <b>BUR KS-17</b> <b>ILS IK-6</b></p> <p><b>BLK 1H</b> <b>BUR KS23</b> <b>ILS IK-2</b></p> <p><b>BLK 2H</b> <b>BUR KS22</b> <b>ILS IK3</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Split Bolt Connector For Copper to Copper  	5-01-06 <b>5001362</b>  5-01-07 <b>5001363</b>  5-01-08 <b>5001364</b>	MAIN-#6 STR TAP Max-#6 STR Min-#14 STR  2/O  MAIN Max-250 Min-2/0 TAP Max-250 Min-8 SOL	<b>BLK 4H</b> <b>BUR KS20</b> <b>ILS IK-4</b>  <b>BLK 20H</b> <b>BUR KS26</b> <b>ILS IK-2/O</b>  <b>BLK 40H</b> <b>ILS IK-250</b>
Split Bolt Post Connector for Cable to Flat Bar  	5-01-12 <b>5001365</b>  5-01-13 <b>5001366</b>	10, 3 STR - 10, 2 SOL 3/8" - 16 Stud  2/O	<b>BUR KC22</b> <b>T&amp;B SP3SL</b> <b>PU SSS-3A1</b>  <b>BUR KC26B1</b> <b>T&amp;B SP6SL</b> <b>PU SSS-6A1</b>
Two Bolt Connector  	5-01-22 <b>5001367</b>	Up to 800 MCM	<b>BUR KVSU40</b> <b>ILS IKB-800</b>








DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Bonding Jumper Clamp 	5-01-30 <b>5000464</b>	#6 CU - 1/4"STR	BLK K1
Ampact Connector 	5-02-05 <b>5000465</b>  5-02-07 <b>5000466</b>  5-02-09 <b>5000467</b>  5-02-13 <b>5000468</b>  5-02-15 <b>5000469</b>  5-02-17 <b>5000470</b>	2/0-2/0, 3/0-1/0, 4/0-2  4/0 - 2/0  4/0 - 4/0  336 - 4/0  336 - 336  477 - 2/0	AMP 600411  AMP 600459  AMP 600466  AMP 602004  AMP 602007  AMP 1-602031-8
Ampact Connector 	5-02-19 <b>5000471</b>  5-02-21 <b>5000472</b>  5-02-22 <b>5000473</b>  5-02-24 <b>5000474</b>  5-02-27 <b>5000475</b>  5-02-29 <b>5000476</b>	477 - 4/0  477 - 336  477 - 477  750 - 336  750 - 4/0  750 - 477	AMP 1-602031-6  AMP 1-602031-4  AMP 1-602031-3  AMP 602121-7  AMP 602121-9  AMP 602121




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Ampact Deadend Connector</p> 	<p>5-02-30 <b>5025366</b></p> <p>5-02-32 <b>5025368</b></p> <p>5-02-34 <b>5025370</b></p> <p>5-02-36 <b>5025372</b></p>	<p>4/0 AAC &amp; ACSR</p> <p>266 ACSR, 336 AAC &amp; ACSR</p> <p>477 AAC</p> <p>477 ACSR</p>	<p>AMP 83843-7</p> <p>AMP 83843-2</p> <p>AMP 83843-3</p> <p>AMP 83843-4</p>
<p>Ampact Shell</p> <p>Blue</p> <p>Red</p> <p>Yellow</p> <p>White</p> 	<p>5-02-41 <b>5000477</b></p> <p>5-02-42 <b>5000478</b></p> <p>5-02-44 <b>5000479</b></p> <p>5-02-46 <b>5000480</b></p>		<p>AMP 69338-1</p> <p>AMP 69338-2</p> <p>AMP 69338-4</p> <p>AMP 69338-5</p>
<p>Ampact Insulated Cover</p> 	<p>5-02-52 <b>5000481</b></p> <p>5-02-53 <b>5000482</b></p>	<p>Medium</p> <p>Large</p>	<p>AMP 602107</p> <p>AMP 602284 HOM PT-COVER-C</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Connectors Stirrup Aluminum Tap System</p> 	<p>5-02-69 <b>5000483</b></p> <p>5-02-70 <b>5000484</b></p> <p>5-02-72 <b>5000485</b></p> <p>5-02-74 <b>5000486</b></p> <p>5-02-76 <b>5000487</b></p> <p>5-02-78 <b>5000488</b></p>	<p>#6, #4</p> <p>#2</p> <p>1/0 - 2/0</p> <p>3/0 - 4/0</p> <p>336</p> <p>477</p>	<p>AMP 602585</p> <p>AMP 602586</p> <p>AMP 600464</p> <p>AMP 600469</p> <p>AMP 600474</p> <p>AMP 60204</p>
<p>Connector Stirrup Clamp Style</p> 	<p>5-03-01 <b>5000489</b></p> <p>5-03-03 <b>5000490</b></p>	<p>#4 - 1/0</p> <p>2/0 - 477</p>	<p>EPAC ASB-6-4/0 RIC BCASC2/0-E-W-45</p> <p>RIC BCASC397-E-45</p>
<p>Connector Stirrup Shearbolt Style</p> 	<p>5-03-10 <b>5000491</b></p>	<p>Use With</p> <p>#6 - #2 AL/CU</p>	<p>CPI102011-2</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Compression Sleeve Copper and Copperweld Full Tension  	5-04-02 <b>5000492</b>  5-04-03 <b>5000493</b>	2/0 (7, 19) STR  4/0 (7, 19) STR	<b>BUR</b> Hysplice YDS26  <b>BUR</b> Hysplice YDS28
Compression Sleeve Copper & Copperweld Full Tension  	5-04-07 <b>5000494</b>  5-04-08 <b>5000495</b>  5-04-09 <b>5000496</b>  5-04-10 <b>5000497</b>  5-04-11 <b>5000498</b>  5-04-12 <b>5000499</b>	#4 - #6 SOL Copper  #6 SOL Copper  #4 SOL Copper  #2 SOL #4 STR Copper  3/0 SOL 2/0 STR Copper  #2 SOL to #4 SOL	<b>SL</b> Nico Press 1-204X162P  <b>BUR</b> YDS6W  <b>BUR</b> YDS4W  <b>BUR</b> YDS2W  <b>SL</b> Nico Press 1-365/7G3  <b>SL</b> Nico Press Reducer 1-258X204X
Compression Sleeve Copper Repair  	5-04-22 <b>5000500</b>	4/0 STR	<b>BUR</b> YCU28

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Compression Sleeve Aluminum Full Tension  	5-04-34 <b>5000501</b>  5-04-35 <b>5000502</b>  5-04-36 <b>5000503</b>  5-04-37 <b>5000504</b>	2/0 Alum  4/0 Alum  336 MCM  477 MCM	BUR YDS26AT  BUR YDS28AT  BUR YDS301AT HOM 2176  BUR YDS331AT
Compression Sleeve Aluminum Jumper  	5-04-41 <b>5000505</b>  5-04-42 <b>5000506</b>  5-04-43 <b>5000507</b>  5-04-44 <b>5000508</b>	4/0 Alum  336 MCM Alum  477 MCM Alum  477 MCM ACSR	BUR YCS28RL  BUR YCS321R  BUR YCS35R HOM 874  BUR YCS36R
Compression Sleeve ACSR Repair	5-04-47 <b>5000509</b>	4/0 ACSR	BUR YVU28R




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Compression Sleeve Aluminum Repair 	5-04-50 <b>5000510</b>  5-04-51 <b>5000511</b>	336.4 MCM  477 MCM	<b>BUR YCU301A</b>  <b>BUR YOU331A</b>
Compression Sleeve Combination Aluminum & ACSR Full Tension 	5-04-62 <b>5000512</b>  5-04-63 <b>5000513</b>	2/0  4/0	<b>BUR Unisplice YDS26RL</b>  <b>BUR Unisplice YDS28RL</b>
Compression Sleeve ACSR Full Tension 	5-04-75 <b>5000514</b>  5-04-76 <b>5000515</b>  5-04-77 <b>5000516</b>  5-04-78 <b>5000517</b>  5-04-79 <b>5000518</b>	477 MCM Alum Section  477 MCM Steel Section  266 MCM Alum Section  266 MCM Steel Section  336 MCM Oriole Steel Section	<b>BUR YDS37RP1</b>  <b>BUR YDS36RP2</b>  <b>BUR YDS30RP1</b>  <b>BUR YDS30RP2</b>  <b>BUR YDS33R</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Automatic Splice  	5-04-84 <b>5000519</b> 5-04-86 <b>5000520</b> 5-04-88 <b>5000521</b> 5-04-89 <b>5000522</b> 5-04-90 <b>5001368</b>  5-04-92 <b>5001369</b>  5-04-94 <b>5000523</b>	2/0 ACSR  2/0 Copper  4/0 ACSR  4/0 Copper  336 ALUM  477 ALUM  477 ACSR 26/7 Strand	REL 7654AP  REL 207  REL 7656  REL 407  REL 7658AP FAR GL410  MP 7659 BLK ATS397477 HUB GLSF412 HUB GLSF412KR HUB GLT1319A NO SUBS
Compression Sleeve Steel Guy Strand Full Tension  	5-04-98 <b>5000524</b>  5-04-99 <b>5000525</b>	3/8 Steel Wire  5/16" Grade 110	SL 5-7/120G92  SLNico Press 5-7/104W
Compression Sleeve Insulated Service Entrance  	5-05-02 <b>5001370</b>  5-05-05 <b>5001371</b>  5-05-06 <b>5001372</b>  5-05-07 <b>5001373</b>	6 ACSR - 6 ACSR Blue-Blue  4 ACSR - 6 ACSR Orange-Blue  4 ACSR - 4 ACSR Orange-Orange  2 ACSR - 6 ACSR Red-Blue	BLK ICS64 BUR ES6R6R PU P1K44  BLK ICS67 BUR ES4R6R PU P1K24  BLK ICS68 ILS P1K22  BLK ICS71 BUR ES2R6R PU P1K14




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Compression Sleeve Insulated Service Entrance  	5-05-08 <b>5001374</b>  5-05-09 <b>5001375</b>	2 ACSR - 4 ACSR Red-Orange  2 ACSR - 2 ACSR Red-Red	<b>BUR ES2R4R</b> <b>BLK ICS72</b> <b>PU P1K12</b>  <b>BUR ES2R2R</b> <b>BLK ICS73</b> <b>PU P1K11</b>
Compression Sleeve Insulated Service Entrance  	5-05-10 <b>5001376</b>  5-05-11 <b>5001377</b>  5-05-12 <b>5001378</b>  5-05-13 <b>5001379</b>	1/0 - #2 Yellow-Red  2/0 - #2 Grey-Red  2/0 - 2/0 Grey-Grey  3/0 - #2 Black-Red	<b>BLK IKL35</b> <b>PU P1K01</b>  <b>BLK IKL45</b> <b>PU P1K201</b>  <b>BLK IKL47</b> <b>PU P1K2020</b>  <b>BLK IKL55</b> <b>PU P1K301</b>
Compression Sleeve Insulated Service Entrance  	5-05-14 <b>5001380</b>  5-05-15 <b>5001381</b>  5-05-16 <b>5001382</b>  5-05-20 <b>5023007</b>  5-05-22 <b>5023017</b>	4/0 - #2 Pink-Red  4/0 - 2/0 Pink-Grey  4/0 - 4/0 Pink-Pink  2/0 - 1/0  4/0 - 1/0	<b>BLK IKL65</b> <b>PU P1K401</b>  <b>BLK IKL67</b> <b>PU P1K4020</b>  <b>BLK IKL69</b> <b>PU P1K4040</b>  <b>BLK IKL46</b>  <b>BLK IKL66</b>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Connector Insulation Piercing</p> 	<p>5-05-24 <b>5025436</b></p> <p>5-05-26 <b>5025438</b></p>	<p>#6 - 3/0 Main #12 - #2 Tap</p> <p>#4 - 4/0 Main &amp; Tap</p>	<p>TE P2X95 U Mk2</p> <p>TE P3X4/0</p>
<p>Compression Sleeve Noninsulated Service Entrance</p> 	<p>5-05-33 <b>5001383</b></p> <p>5-05-34 <b>5000526</b></p> <p>5-05-35 <b>5000527</b></p>	<p>6 ACSR</p> <p>4 ACSR or ALUM</p> <p>2 ACSR or ALUM</p>	<p><b>BUR YSS6RG2</b> <b>HOM SNG66</b> <b>NO SUBS</b></p> <p><b>HOM SNG44</b></p> <p><b>HOM SNG22</b></p>
<p>GelCap c/w Connector For Streetlight Connections</p> 	<p>5-05-70 <b>5000528</b></p> <p>5-05-74 <b>5000529</b></p>	<p>600 V #14-2/0</p> <p>600 V #14-2/0 4 Conductor</p>	<p><b>RAY GelCap SL</b> 2/0-3 hole</p> <p><b>TYCO GTap-2</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Tinned Copper Compression Sleeve 	5-06-29 <b>5001384</b>  5-06-31 <b>5001385</b>  5-06-32 <b>5001386</b>  5-06-33 <b>5001387</b>  5-06-35 <b>5001388</b>	#6 STR  #4 STR  #2 STR  #1 STR  2/0 STR	<b>BUR YS-6C</b> <b>ILS CTL-6</b>  <b>BUR YS-4C</b> <b>ILS CTL-4</b>  <b>BUR YS-2C</b> <b>PAND SCL2-Q</b> <b>ILS CTL-2</b>  <b>BUR YS-1C</b> <b>ILS CTL-1</b>  <b>BUR YS-26</b> <b>PAND SCL2/0X</b> <b>ILS CTL-2/0</b>
Tinned Copper Compression Sleeve 	5-06-37 <b>5001389</b>  5-06-38 <b>5001390</b>  5-06-39 <b>5001391</b>  5-06-40 <b>5001392</b>  5-06-42 <b>5001393</b>  5-06-50 <b>5000530</b>	4/0 STR  250 MCM  350 MCM  500 MCM  750 MCM  500 - 750 MCM Transition	<b>BUR YS-28</b> <b>ILS CTL-4/0</b>  <b>BUR YS-29</b> <b>ILS CTL-250</b>  <b>BUR YS-31</b> <b>ILS CTL-350</b>  <b>BUR YS-34</b> <b>ILS CTL-500</b>  <b>BUR YS-39</b> <b>ILS CTL-750</b>  <b>3M2000T 500-750 cu/al</b>
Sleeve Compression AL Non-Insulated 	5-06-60 <b>5022804</b>	1/0 - 1/0	<b>IlSCO ASN-1/0</b> Blackburn CS78 Homac U1B1010




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Buchanan Splice Sleeve</p>  <p>Buchanan Insulator Cap</p> 	<p>5-07-01 <b>5000531</b></p> <p>5-07-03 <b>5000532</b></p> <p>5-07-05 <b>5000533</b></p> <p>5-07-07 <b>5000534</b></p>	<p>Small</p> <p>Large</p> <p>Small</p> <p>Large</p>	<p><b>BUCH 2006S</b> 100 pieces/box</p> <p><b>BUCH 2011S</b> 50 pieces/box</p> <p><b>BUCH 2007</b></p> <p><b>BUCH 2014</b></p>
<p>Luminaire Disconnect</p>  	<p>5-07-15 <b>5021127</b></p> <p>5-07-17 <b>5021129</b></p>	<p>2 Wire</p> <p>3 Wire</p>	<p><b>IDI PowerPlug 30-102</b></p> <p><b>IDI PowerPlug 30-103X</b></p>
<p>Bolted Lug - 1 Hole</p> 	<p>5-08-01 <b>5000535</b></p> <p>5-08-02 <b>5000536</b></p> <p>5-08-03 <b>5000537</b></p> <p>5-08-04 <b>5000538</b></p>	<p>1/0 - 2/0</p> <p>3/0 - 4/0</p> <p>250 - 350</p> <p>400 - 500</p>	<p><b>BUR Qiklug QA-26-B</b></p> <p><b>BUR Qiklug QA-28-B</b></p> <p><b>BUR Qiklug QA-31-B</b></p> <p><b>BUR Qiklug QA-34-B</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Bolted Lug  	5-08-54 <b>5000539</b>  5-08-55 <b>5000540</b>  5-08-56 <b>5000541</b>	Min #14 Max #8  Min #14 Max #4  Min #4 Max 2/0	T&B L35  T&B L70  T&B Cone Screw Lug 71010
Shearbolt Splice Connector  	5-08-65 <b>5001394</b>  5-08-70 <b>5001395</b>  5-08-75 <b>5000542</b>	#2 - 250 MCM For use with 7-92-13  4/0 - 500 MCM For use with 7-92-15  350 MCM - 750 MCM For use with 7-92-16 & 7-92-17	3M USMF-1 PRY CUS53821  3M USMF-2 PRY CUS53783  PRY CUS53826
Shearbolt Lug Connector Threaded  	<b>For Use with 6-70-50, 6-70-55 Elbow &amp; 15/25kV LRTP</b>  5-08-80 <b>5000543</b>  5-08-85 <b>5000544</b>	#3 AWG - 300 MCM 15/16" Threaded Hole Bimetal  350 - 750 MCM 15/16" Threaded Hole Bimetal	<b>RICHARDS/3M</b> P6AL-R1-15/16  <b>RICHARDS/3M</b> P6AL-R4-15/16





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Shearbolt Lug Connector Non-Threaded</p> 	<p><b>For Use with 6-70-50, 6-70-55 Elbow &amp; Plug &amp; Cap</b></p> <p>5-08-91 <b>5001495</b></p> <p>5-08-94 <b>5001496</b></p>	<p>#3 AWG - 300 MCM 11/16" Non-Threaded Bimetal</p> <p>350 - 750 MCM 11/16" Non-Threaded Bimetal</p>	<p><b>RICHARDS/3M</b> P6AL-R1</p> <p><b>RICHARDS/3M</b> P6AL-R4</p>
<p>Compression Type Lug for ACSR, Aluminum or Copper - 2 Hole Nema</p> 	<p>5-09-00 <b>5000545</b></p> <p>5-09-01 <b>5001396</b></p> <p>5-09-02 <b>5001397</b></p>	<p>#2</p> <p>2/0</p> <p>4/0</p>	<p><b>BLK AL4</b> <b>HOM SA 2 N</b></p> <p><b>BLK AL8</b> <b>HOM SA 2/0 N</b></p> <p><b>BLK AL12</b> <b>HOM SA 4/0 N</b></p>
<p>Compression Type Lug for ACSR or Aluminum 2 Hole Nema</p> 	<p>5-09-03 <b>5001398</b></p> <p>5-09-04 <b>5024983</b></p> <p>5-09-05 <b>5001399</b></p> <p>5-09-06 <b>5001400</b></p>	<p>336 ALUM</p> <p>266 ACSR</p> <p>477 ALUM</p> <p>477 ACSR</p>	<p><b>BLK AL20</b> <b>BUR YCA321R2N</b> <b>HOM AL 350 N</b></p> <p><b>BLK AL16</b> <b>BUR YCA30R2N</b> <b>HOM AL 350 N</b></p> <p><b>BLK AL24</b> <b>BUR YCA35R2N</b> <b>HOM AL 500 N</b></p> <p><b>BLK AL28</b> <b>BUR YCA37R2N</b> <b>HOM AL 600 N</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Compression Type Lug Copper - 1 Hole</p> 	<p>5-09-07 <b>5001401</b></p> <p>5-09-08 <b>5001402</b></p> <p>5-09-09 <b>5000546</b></p>	<p>1/2" Stud #4 UC</p> <p>#2 Short Barrel</p> <p>2/0</p>	<p><b>PAND LCA4-12-L</b> <b>ILS CSWS-4-12</b></p> <p><b>PAND LCA2-12-Q</b> <b>T&amp;B X54145</b> <b>NO SUBS</b></p> <p><b>T&amp;B 54951BE</b></p>
<p>Compression Type Lug for Copper - 2 Hole</p> 	<p>5-09-10 <b>5001403</b></p> <p>5-09-11 <b>5001404</b></p> <p>5-09-12 <b>5001405</b></p> <p>5-09-13 <b>5001406</b></p>	<p>2/0</p> <p>4/0</p> <p>250 MCM</p> <p>350 MCM</p>	<p><b>BUR Hylug YA26-2N</b> <b>ILS CLND-2/0-12-134</b> <b>T&amp;B 54862BE</b></p> <p><b>BUR Hylug YA28-2N</b> <b>PAND LCC4/0-12</b> <b>ILS CLND-4/0-12-134</b> <b>T&amp;B 54866BE</b></p> <p><b>BUR Hylug YA29-2N</b> <b>PAND LCC250-12</b> <b>ILS CLND-250-12-134</b> <b>T&amp;B 54868BE</b></p> <p><b>BUR Hylug YA31-2N</b> <b>PAND LCC350-12</b> <b>ILS CLND-350-12-134</b> <b>T&amp;B 54872BE</b></p>
<p>Compression Type Lug for Copper - 2 Hole</p> 	<p>5-09-14 <b>5001407</b></p> <p>5-09-15 <b>5001408</b></p> <p>5-09-16 <b>5001409</b></p>	<p>500 MCM</p> <p>750 MCM</p> <p>1000 MCM</p>	<p><b>BUR Hylug YA34-2N</b> <b>PAND LCC500-12</b> <b>ILS CLND-500-12-134</b> <b>T&amp;B 54876BE</b></p> <p><b>BUR Hylug YA39-2N</b> <b>PAND LCC750-12</b> <b>BLK LCN-75</b> <b>ILS CLND-750-12-134</b> <b>T&amp;B 54880BE</b></p> <p><b>BUR Hylug YA44-2N</b> <b>PAND LCC1000-12</b> <b>ILS CLND-1000-12-134</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Compression Type Lug for Copper - 1 Hole Type</p> 	<p>5-09-17 <b>5001410</b></p> <p>5-09-18 <b>5001411</b></p> <p>5-09-19 <b>5025078</b></p>	<p>1/2" Stud #1 CU</p> <p>4/0</p> <p>3/8" Stud #6 CU</p>	<p><b>PAND LCA1-12-E</b> <b>T&amp;B 54150</b> <b>3M 40029</b> <b>BUR YA1CL6</b></p> <p><b>BUR YA28</b> <b>T&amp;B 54970BE</b></p> <p><b>PAND LCA6-38-L</b> <b>ILS CSWS-6-38</b></p>
<p>Compression Type Lug for Copper - Universal Rod</p> 	<p>5-09-20 <b>5000547</b></p>	<p>#1</p>	<p><b>3M SC0001</b></p>
<p>Compression Type Lug for Aluminum - 1 Hole</p> 	<p>5-09-30 <b>5023021</b></p>	<p>1/0</p>	<p><b>Richards ALCD9</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Compression Type Lug for ACSR, Aluminum or Copper - 2 Hole Nema</p> 	<p>5-09-40 <b>5026119</b></p>	<p>1/0</p>	<p><b>BLK AL6 HOM SA 1/0 N</b></p>
<p>Bolted Type "T" Connector</p> 	<p>5-11-02 <b>5000548</b></p>	<p>750 MCM Run - 500 MCM Tap for Network</p>	<p><b>RIC MT23-18 NO SUBS</b></p>
<p>Station Connector Bar Tap</p> 	<p>5-13-01 <b>5000549</b></p>	<p>3" IPS 4 N</p>	<p><b>BUR WAB20A4N</b></p>







DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Station Connector</p> <p>Bus Support</p> 	<p>5-13-02 5000550</p>	<p>3" IPS 5" B.C.</p>	<p>BUR WOH20A5</p>
<p>Station Connector</p> <p>End Terminal Centre Formed</p>  <p>Corona Bell</p> 	<p>5-13-03 5000551</p> <p>5-13-04 5000552</p>	<p>3" IPS 4N</p> <p>3" IPS</p>	<p>BUR WAC20A4N</p> <p>BUR LB20A</p>
<p>Station Connector</p> <p>Bus Coupler</p> 	<p>5-13-05 5000553</p>	<p>3" IPS 12"</p>	<p>Dwg. Gs-249</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Station Connector</p> <p>Expansion Bus Support Coupler</p> 	<p>5-13-06 <b>5000554</b></p>	<p>3" IPS 5" B.C.</p>	<p><b>BUR WXHP20A5</b></p>
<p>Station Connector</p> <p>Expansion Terminal Center Formed</p> 	<p>5-13-07 <b>5000555</b></p>	<p>3" IPS 4 N</p>	<p><b>BUR WXA20A4N</b></p>
<p>Station Connector</p> <p>Separator for 477 Cosmos</p> 	<p>5-13-08 <b>5000556</b></p>	<p>477 ALUM 3"</p>	<p><b>Dwg. Gs-248</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Network Protector Braze Terminal Assembly (Antlers)</p> 	<p>5-14-01 <b>5026232</b></p>	<p>6 Tabs</p>	<p><b>Dwg. A1s-165F-01</b> <b>EATON 6416C96G01</b> <b>RIC 351-0109-00</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Single Phase - Deadfront 2400 - 120/240	6-04-05 <b>5025815</b>	50 KVA	Covered by 6-04-07
	6-04-07 <b>5025817</b>	75 KVA	<b>Specification 2104 &amp; Addendum</b>
	6-04-10 <b>5025820</b>	100 KVA	<b>Specification 2104 &amp; Addendum</b>
Padmount Transformer Single Phase - Livefront 4160/2400 - 120/240	6-10-01 (DNR) <b>5025804</b>	25 KVA	Covered by 6-04-07
	6-10-03 (DNR) <b>5025806</b>	37.5 KVA	Covered by 6-04-07
	6-10-05 (DNR) <b>5025809</b>	50 KVA	Covered by 6-04-07
	6-10-07 (DNR) <b>5025811</b>	75 KVA	Covered by 6-04-07
	6-10-09 (DNR) <b>5025813</b>	100 KVA	Covered by 6-04-10
	6-10-13 (DNR) <b>5000557</b>	167 KVA	Covered by 6-11-13
Padmount Transformer Single Phase - Deadfront Dual Voltage 2400 - 120/240 8320 - 120/240 200 Amp Bushings	6-10-25 <b>5001412</b>	50 KVA	<b>Specification 2132 &amp; Addendum</b>
	6-10-27 <b>5000558</b>	75 KVA	<b>Specification 2132 &amp; Addendum</b>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Padmount Transformer Single Phase - Deadfront Dual Voltage 2400 - 120/240 8320 - 120/240 600 Amp Bushing</p> 	<p>6-11-05 <b>5000559</b></p> <p>6-11-07 <b>5000560</b></p> <p>6-11-09 <b>5000561</b></p> <p>6-11-13 <b>5000562</b></p>	<p>50 KVA</p> <p>75 KVA</p> <p>100 KVA</p> <p>167 KVA</p>	<p><b>Specification 2132 &amp; Addendum</b></p> <p><b>Specification 2132 &amp; Addendum</b></p> <p><b>Specification 2132 &amp; Addendum</b></p> <p><b>Specification 2132 &amp; Addendum</b></p>
<p>Padmount Transformer Single Phase - Deadfront Dual Voltage 2400 - 240/480 8320 - 240/480</p> 	<p>6-12-05 <b>5000563</b></p>	<p>50 KVA</p>	<p><b>Specification 2132 &amp; Addendum</b></p>
<p>Padmount Transformer Single Phase - Deadfront 8320 - 120/240</p> 	<p>6-13-05 <b>5000564</b></p> <p>6-13-07 <b>5000565</b></p> <p>6-13-09 <b>5000566</b></p> <p>6-13-13 <b>5000567</b></p>	<p>50 KVA</p> <p>75 KVA</p> <p>100 KVA</p> <p>167 KVA</p>	<p><b>Specification 2104 &amp; Addendum</b></p> <p><b>Specification 2104 &amp; Addendum</b></p> <p><b>Specification 2104 &amp; Addendum</b></p> <p><b>Specification 2104 &amp; Addendum</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Single Phase - Deadfront 14400 - 120/240 	6-14-03 <b>5000568</b>  6-14-05 <b>5000569</b>  6-14-07 <b>5000570</b>  6-14-09 <b>5000571</b>  6-14-13 <b>5000572</b>	37.5 KVA  50 KVA  75 KVA  100 KVA  167 KVA	<b>Specification 2104 &amp; Addendum</b>  <b>Specification 2104 &amp; Addendum</b>  <b>Specification 2104 &amp; Addendum</b>  <b>Specification 2104 &amp; Addendum</b>  <b>Specification 2104 &amp; Addendum</b>
Padmount Transformer Single Phase - Deadfront 14400 - 240/480	6-15-02 <b>5001497</b>  6-15-05 (DNR) <b>5025832</b>	25 KVA  50 KVA	<b>Specification 2104 &amp; Addendum</b>  Covered by 6-15-02
Padmount Transformer Three Phase - Livefront 4160 - 240 Delta	6-20-04 (DNR) <b>5025834</b>	45 KVA	


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Three Phase - Livefront 4160 - 120/208	6-22-07 (DNR) <b>5000573</b>  6-22-11 (DNR) <b>5025822</b>  6-22-13 (DNR) <b>5025824</b>  6-22-15 (DNR) <b>5025826</b>  6-22-17 (DNR) <b>5025828</b>  6-22-19 (DNR) <b>5025830</b>	75 KVA  112.5 KVA  150 KVA  225 KVA  300 KVA  500 KVA	Covered by 6-27-15  Covered by 6-27-15  Covered by 6-27-15  Covered by 6-27-30  Covered by 6-27-30  Covered by 6-27-50
Padmount Transformer Three Phase - Deadfront 4160 - 120/208 Radial Feed  	6-24-13 (DNR) <b>5000574</b>  6-24-15 (DNR) <b>5000575</b>  6-24-17 (DNR) <b>5000576</b>  6-24-19 (DNR) <b>5000577</b>	150 KVA  225 KVA  300 KVA  500 KVA Approx. 4890 lbs (2222 kgs)	Covered by 6-27-15  Covered by 6-27-30  Covered by 6-27-30  Covered by 6-27-50
Padmount Transformer Three Phase - Livefront 4160 - 347/600	6-26-11 (DNR) <b>5025836</b>  6-26-13 (DNR) <b>5025797</b>  6-26-15 (DNR) <b>5025799</b>  6-26-17 (DNR) <b>5025801</b>  6-26-19 (DNR) <b>5025839</b>	112.5 KVA  150 KVA  225 KVA  300 KVA  500 KVA	Covered by 6-28-30  Covered by 6-28-30  Covered by 6-28-30  Covered by 6-28-30  Covered by 6-28-75


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Three Phase - Deadfront 4160 - 120/208 Loop Feed	6-27-15 <b>5025888</b>	150 KVA	<b>Specification 2114 &amp; Addendum</b>
	6-27-30 <b>5025890</b>	300 KVA	<b>Specification 2114 &amp; Addendum</b>
	6-27-50 <b>5025902</b>	500 KVA	<b>Specification 2114 &amp; Addendum</b>
Padmount Transformer Three Phase - Deadfront 4160 - 347/600 Radial Feed	6-28-15 (DNR) <b>5000578</b>	225 KVA	Covered by 6-28-30
	6-28-17 (DNR) <b>5000579</b>	300 KVA	Covered by 6-28-30
	6-28-19 (DNR) <b>5000580</b>	500 KVA	Covered by 6-28-75
	6-28-21 (DNR) <b>5000581</b>	750 KVA	Covered by 6-28-75
Padmount Transformer Three Phase - Deadfront 4160 - 347/600 Loop Feed	6-28-30 <b>5025843</b>	300 KVA	<b>Specification 2114 &amp; Addendum</b>
	6-28-50 <b>5025841</b>	500 KVA	<b>Specification 2114 &amp; Addendum</b>
	6-28-75 <b>5025846</b>	750 KVA	<b>Specification 2114 &amp; Addendum</b>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Three Phase - Deadfront 14.4 KV - 240 Loop Feed	6-29-13 (DNR) <b>5000582</b>	150 KVA	<b>Specification 2134 &amp; Addendum</b>
Padmount Transformer Three Phase - Deadfront 14.4 KV - 120/208 Radial Feed	6-30-07 (DNR) <b>5025854</b>  6-30-13 (DNR) <b>5025857</b>  6-30-15 (DNR) <b>5025859</b>  6-30-17 (DNR) <b>5025861</b>  6-30-19 (DNR) <b>5000583</b>  6-30-23 (DNR) <b>5000585</b>	75 KVA  150 KVA  225 KVA  300 KVA  500 KVA  1000 KVA Approx. 9020 lbs (4100 kgs)	Covered by 6-31-13  Covered by 6-31-13  Covered by 6-31-17  Covered by 6-31-17  Covered by 6-31-19
Padmount Transformer Three Phase - Deadfront 14.4 KV - 120/208 Loop Feed  	6-31-07 <b>5000586</b>  6-31-13 <b>5000587</b>  6-31-17 <b>5000588</b>  6-31-19 <b>5025864</b>	75 KVA  150 KVA  300 KVA  500 KVA	<b>Specification 2114 &amp; Addendum</b>  <b>Specification 2114 &amp; Addendum</b>  <b>Specification 2114 &amp; Addendum</b>  <b>Specification 2114 &amp; Addendum</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Padmount Transformer Three Phase - Deadfront 14.4 KV - 120/208 Loop Feed 600A</p> 	<p>6-31-67 <b>5000589</b></p>	<p>300 KVA</p>	<p><b>Specification 2114 &amp; Addendum</b></p>
<p>Padmount Transformer Three Phase - Livefront 14.4 KV - 347/600 Loop Feed</p>	<p>6-32-15 (DNR) <b>5025867</b></p> <p>6-32-19 (DNR) <b>5025869</b></p>	<p>225 KVA</p> <p>500 KVA</p>	<p>Covered by 6-33-17</p> <p>Covered by 6-33-19</p>
<p>Padmount Transformer Three Phase - Deadfront 14.4 KV - 347/600 Loop Feed</p> 	<p>6-33-13 <b>5000590</b></p> <p>6-33-17 <b>5000591</b></p> <p>6-33-19 <b>5000592</b></p> <p>6-33-21 <b>5000593</b></p> <p>6-33-23 <b>5000594</b></p>	<p>150 KVA</p> <p>300 KVA</p> <p>500 KVA</p> <p>750 KVA</p> <p>1000 KVA</p>	<p><b>Specification 2114 &amp; Addendum</b></p> <p><b>Specification 2114 &amp; Addendum</b></p> <p><b>Specification 2114 &amp; Addendum</b></p> <p><b>Specification 2114 &amp; Addendum</b></p> <p><b>Specification 2114 &amp; Addendum</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Padmount Transformer Three Phase - Deadfront 14.4 KV - 347/600 Loop Feed</p> 	<p>6-33-25 <b>5000595</b></p> <p>6-33-27 <b>5000596</b></p>	<p>1500 KVA</p> <p>2000 KVA</p>	<p><b>Specification 2114 &amp; Addendum</b></p> <p><b>Specification 2114 &amp; Addendum</b></p>
<p>Padmount Transformer Three Phase - Deadfront 14.4 KV - 347/600 Radial Feed</p>	<p>6-34-13 (DNR) <b>5000597</b></p> <p>6-34-15 (DNR) <b>5025871</b></p> <p>6-34-17 (DNR) <b>5025873</b></p> <p>6-34-19 (DNR) <b>5025875</b></p> <p>6-34-21 (DNR) <b>5025877</b></p> <p>6-34-23 (DNR) <b>5000598</b></p>	<p>150 KVA</p> <p>225 KVA</p> <p>300 KVA</p> <p>500 KVA</p> <p>750 KVA</p> <p>1000 KVA</p>	<p>Covered by 6-33-13</p> <p>Covered by 6-33-17</p> <p>Covered by 6-33-17</p> <p>Covered by 6-33-19</p> <p>Covered by 6-33-21</p> <p>Covered by 6-33-23</p>
<p>Padmount Transformer Three Phase - Deadfront 14.4 KV - 347/600 Radial Feed</p> <p>Network - 3 Bushing</p>	<p>6-34-25 (DNR) <b>5025879</b></p> <p>6-34-27 (DNR) <b>5025881</b></p>	<p>1500 KVA</p> <p>2000 KVA</p>	<p>Covered by 6-33-25</p> <p>Covered by 6-33-27</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Three Phase - Deadfront 14.4 KV - 4160 Radial Feed	6-36-19 (DNR) <b>5000599</b>  6-36-27 (DNR) <b>5000600</b>	500 KVA   2000 KVA	Covered by 6-38-20   Covered by 6-38-20
Padmount Transformer Three Phase - Deadfront 14.4 KV - 4160 Loop Feed	6-38-05 <b>5025884</b>  6-38-20 <b>5025886</b>	500 KVA   2000 KVA	<b>Specification 2118 &amp; Addendum</b>   <b>Specification 2118 &amp; Addendum</b>
Padmount Transformer Three Phase - Deadfront 24940 - 120/208 V Loop Feed  	6-40-13 <b>5000601</b>  6-40-15 (DNR) <b>5000602</b>  6-40-17 <b>5000603</b>	150 KVA  225 KVA  300 KVA	<b>Specification 2114 &amp; Addendum</b>  Covered by 6-40-17  <b>Specification 2114 &amp; Addendum</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Three Phase - Deadfront 24940 - 347/600 V Radial Feed	6-42-15 (DNR) <b>5000604</b>  6-42-17 (DNR) <b>5000605</b>  6-42-19 (DNR) <b>5000606</b>	225 KVA  300 KVA  500 KVA	Covered by 6-43-15  Covered by 6-43-19  Covered by 6-43-19
Padmount Transformer Three Phase - Deadfront 24940 - 347/600 V Loop Feed  	6-43-15 <b>5000607</b>  6-43-19 <b>5000608</b>  6-43-23 <b>5000609</b>  6-43-27 <b>5000610</b>	225 KVA  500 KVA  1000 KVA  2000 KVA	<b>Specification 2114 &amp; Addendum</b>  <b>Specification 2114 &amp; Addendum</b>  <b>Specification 2114 &amp; Addendum</b>  <b>Specification 2114 &amp; Addendum</b>
Padmount Transformer Three Phase - Deadfront 24940 - 4160 V Radial Feed	6-44-17 (DNR) <b>5000611</b>  6-44-23 (DNR) <b>5000612</b>	300 KVA  1000 KVA	Covered by 6-45-03  Covered by 6-45-10




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Padmount Transformer Three Phase - Deadfront 24940 - 4160 V Loop Feed 	6-45-03 <b>5025905</b>  6-45-10 <b>5025908</b>  6-45-15 (DNR) <b>5000613</b>	300 KVA  1000 KVA  225 KVA	<b>Specification 2118 &amp; Addendum</b>  <b>Specification 2118 &amp; Addendum</b>  Covered by 6-45-03
15 KV Switching Cubicle  2 Way - c/w Interrupter  3 Way  321, (600A LI), (200A 3PH FI)  321, (600A LI), (600A 3PH FI)  422, (200A LI), (200A 3PH FI)x2  413, (600A LI), (200A 3PH FI)x3 switch type/sources/interrupter	6-53-01 <b>5000614</b> 6-53-06 <b>5000615</b> 6-53-07 <b>5000616</b>  6-53-08 <b>5000617</b>  6-53-11 <b>5000618</b>  6-53-12 <b>5000619</b>	<b>NOTE: Joslyn Fuses</b> <b>Load Interrupter = LI, Fault Interrupter = FI</b> 600 Amp 600 Amp  600 Amp  <b>S&amp;C 933212-M1P103T1-E243</b>  <b>S&amp;C 853212-L2M10P94P103-E135</b>  <b>S&amp;C 934222-M4P94P103ST2-S356</b>  <b>S&amp;C 924132-L2M10P94P103</b>	<b>6-72-06 + 7-51-20</b> <b>Specification 2220</b>  <b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>
15 KV Switching Cubicle  440, (600A LI)  422, (600A LI), (200A 1PH FI)x2  431, (600A LI), (200A FI)  422, (600A LI), (200A 3PH FI)x2  523, (600A LI x 2), (200A FI x 3)  532, (600A LI x 3), (200A FI x 2)  6 Way - c/w Interrupter - 624	6-53-14 <b>5000620</b> 6-53-15 <b>5001413</b> 6-53-16 <b>5000621</b> 6-53-17 <b>5000622</b> 6-53-19 <b>5000623</b> 6-53-21 <b>5000624</b> 6-53-31 <b>5000625</b>	<b>S&amp;C 934222-L2M10P94P103T0-S411</b>  <b>S&amp;C 934312-M1P103T1-E151</b>  <b>S&amp;C 924222-L2M10P94P103</b>  600 Amp 200 Amp	<b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>  <b>Spec 2200 &amp; 2210</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
25 KV Switching Cubicle  3 Way - c/w Interrupter - 321  3 Way - 330  321, (600A LI), (200A 3PH FI)  321, (600A LI), (200A 1PH FI)  4 Way - 440	6-55-03 <b>5000626</b>  6-55-06 <b>5000627</b>  6-55-07 <b>5000628</b>  6-55-09 <b>5000629</b>  6-55-10 <b>5000630</b>	200 Amp 200 Amp  600 Amp  S&C 933213-L2M10P94P103T1-E139  S&C 933213-L2M10P94P103T0-E140	Spec 2200 & 2210  Spec 2200 & 2210  Spec 2200 & 2210  Spec 2200 & 2210
25 KV Switching Cubicle  4 Way - c/w Interrupter - 422  422, (600A LI), (200A 1PH FI)x2  422, (600A LI), (200A FI)x2  6 Way - c/w Interrupter - 624  switch type/sources/interrupter	6-55-11 <b>5000631</b>  6-55-15 <b>5001414</b>  6-55-17 <b>5000632</b>  6-55-31 <b>5000633</b>	200 Amp 200 Amp  S&C 934223-M1P94T0-E203	Spec 2200 & 2210  Spec 2200 & 2210  Spec 2200 & 2210
Precast Concrete Base for Padmount Transformer  Three Phase Box Pad	6-58-06 <b>5000634</b>	500 KVA & Up 1.630 x 1.895 x 1.150 m - Pad (64" x 74" x 45") Appr 6650 lbs	Dwg WS-263




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Fibreglass Pad for Padmount Transformers Single Phase Short  Single Phase Standard 4500 kg/9900 lb  Three Phase Large (Can be used S&C 2, 3, & 4 Way Sw Cub) 8200 kg/18,040 lb  S&C 2 Way Interrupter	6-59-01 <b>5000635</b>  6-59-02 <b>5000636</b>  6-59-05 <b>5000637</b>  6-59-06 <b>5000638</b>  6-59-08 <b>5000639</b>	42" x 48" x 15" Top opening 26"x 12"  38" x 50" x 28" Top opening 30"x 20"  66" x 58" x 28" Top opening 39"x 15"  69" x 63" x 28" Top opening 45" x 16" (10,000 lbs)  63" x 69" x 28"	Dwg. WS-421  SCT 02902  Dwg. WS-420  SCT 02903  SCT 02911
Fibreglass Pad for Dry Type Transformers	6-59-10 <b>5000640</b>	31" x 25" x 28" No Cut Out	SCT 02909
Precast Concrete Box Base for Switching Cubicle  3 Way Switch  4 Way Switch	6-61-03 <b>5000641</b>  6-61-05 <b>5000642</b> Suitable for ABB Solid Dielectric Switch Installation  6-61-07 <b>5000643</b>  6-61-09 <b>5000644</b>	1.524 x 2.222 x .991m 60" x 87" x 39" Approx. 3660 lbs  1.498 x 1.664 x .990m 59" x 66" x 39" Approx 3270 lbs  1.498 x 1.981 x .990m 79" x 60" Approx. 3620 lbs  1.905 x 2.007 x .990m 75" x 79" x 39" Approx. 4080 lbs	Specification 2429 Dwg. WS-241  Specification 2429 Dwg. WS-257  Specification 2429 Dwg WS-264  Specification 2429 Dwg. WS-266






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Precast Concrete Box Base for Switching Cubicle  Trayer 5 Way Switch   Canada Power Products 6 Way Switch	6-61-10 <b>5026761</b>  6-61-11 <b>5000645</b>	1.982 x 2.439 x .990m 78" x 96" x 39" Approx. 5350 lbs  2.310 x 1.752 x .991m 90" x 69" x 39" Approx. 4420 lbs	<b>Specification 2429</b> <b>Dwg WS-425</b>  <b>Specification 2429</b> <b>Dwg WS-298</b>
Precast Concrete Box Base for Switching Cubicle  For S & C 2, 3 & 4 Way  For S & C 3 & 4 Way (old)  For S & C 5 & 6 Way  For S & C 4 Way	6-61-14 <b>5000646</b>  6-61-15 <b>5000647</b>  6-61-16 <b>5000648</b>  6-61-18 <b>5000649</b>	1.930 x 1.651 x 990m 76" x 65" x 39"  1.930 x 1.752 x 990m 76" x 69" x 39" Approx. 4713 lbs  2.692 x 1.752 x 990m 106" x 69" x 39" Approx. 5972 lbs  87" x 54.25" x 39" Approx. 4000 lbs	<b>Dwg Ws-365</b>  <b>Dwg Ws-361-2</b>  <b>Dwg Ws-362-2</b>  <b>Dwg Ws-422</b>
Precast Concrete Box Base for 150 to 500 KVA Transformer	6-61-23 <b>5000650</b>	64" x 56" x 39" 1.626 x 1.422 x .991m	<b>Specification 2429</b> <b>Dwg Ws-383</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Pedestal Joint Use 	6-63-02 <b>5001415</b>  6-63-03 <b>5000651</b>	secondary buss panel for 6-63-03  24" x 24" x 48" (no secondary buss)	<b>Dwg W-221-2</b>  <b>Dwg W-221-3</b>
Pedestal - Street Lighting 	6-63-04 <b>5000652</b>  6-63-05 <b>5026148</b>	10" x 10" x 32"  Orange	<b>SMW 2114</b>
Underground Junction Box HDPE Body & Lid 	6-63-06 <b>5000653</b>	13 3/4" x 23 1/4" Opening 18" Deep	<b>CHANNELL</b> <b>BULK218N07204</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Pedestal - Metering</p> <p>Pedestal - Base (for above pedestal)</p> <p>Pedestal - Metered</p>	<p>6-63-10 <b>5000654</b></p> <p>6-63-12 <b>5000655</b></p> <p>6-63-14 <b>5000656</b></p>	<p>200 AMP 240/480 V</p>	<p>Dwg L2-209-01</p> <p>Dwg L2-209-01</p> <p>Dwg L2s-235</p>
<p>Fault Indicator</p>  <p>Test Tool</p> 	<p>6-66-10 <b>5000657</b></p> <p>6-66-20 <b>5000658</b></p> <p>6-66-30 <b>5000659</b></p>	<p>100 Amp Adaptive trip LED, 4 hour reset</p> <p>Test &amp; Reset Tool</p> <p>Lithium Battery</p>	<p>FP 1548FH-BNC3-L-N-A-1</p> <p>FP AT2186-10</p> <p>ABB A615-REP</p>
<p><b>Distribution Overhead</b></p> <p>Horstmann Fault Indicator</p> 	<p>6-66-50 <b>5022891</b></p>	<p>100 Amp Adaptive Trip LED, 4 hour reset Single Flash</p>	<p><b>REXEL 41-2001-301</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Horstmann Test Tool</p> 	<p>6-66-60 <b>5022912</b></p>	<p>Test &amp; Reset Tool</p>	<p><b>49-6001-002</b></p>
<p>Horstmann Battery</p>	<p>6-66-70 <b>5022915</b></p>	<p>Lithium-Ion Battery</p>	<p><b>REXEL 49-6002-023</b></p>
<p>Fault Indicator Fits Test Point on Elbow</p>  <p>Fits on Cable</p> 	<p>6-67-01 <b>5001416</b></p> <p>6-67-02 <b>5001417</b></p> <p>6-67-03 <b>5000660</b></p> <p>6-67-04 <b>5021090</b></p>	<p>200 Amp Elbow 400 Amp Trip</p> <p>600 Amp Elbow 800 Amp Trip</p> <p>800 Amp Trip</p> <p>400 Amp Trip</p>	<p><b>ELMD TPMVF-LT</b> <b>CP STLO</b></p> <p><b>ELMD TPMVF-HT</b> <b>CP STHI</b></p> <p><b>CP SDHI-4</b> (Cooper Only)</p> <p><b>CP SDLO-4</b> (Cooper Only)</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Fibre Optic Display for Fault Indicator</p> <p>Internal Fault Detector</p> 	<p>6-67-05 <b>5021115</b></p> <p>6-68-01 <b>5000661</b></p>	<p>6' Cable</p> <p>c/w 5 PSI Pressure</p>	<p><b>FP FO-CABLE 06</b></p> <p><b>IFD IFD-PT-5PSI-R5-BLK</b></p>
<p>Elbow Probe</p> 	<p>6-69-01 <b>5001418</b></p> <p>6-69-03 <b>5000662</b></p>	<p>200 Amp 15 KV</p> <p>200 Amp 25 KV</p>	<p><b>ELMD 165LRFR</b> <b>RTE 2637552-C-03</b></p> <p><b>ELMD 274 LRF</b></p>
<p>Elbow Stud Long W/Blunt Start Threads For 600A T-Body &amp; Bushing</p> <p>Elbow Connector</p> 	<p>6-69-05 <b>5000663</b></p> <p>6-69-10 <b>5001419</b></p>	<p>600A T-Body</p> <p>#1 STR 200 AMP 15/25 KV</p>	<p><b>CP Stud T</b></p> <p><b>ELMD 02500230</b> <b>RTE 2639043-A-05</b></p>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Elbow 200 Amp</p> 	<p>6-70-04 <b>5000664</b></p> <p>6-70-05 <b>5001420</b></p> <p>6-70-07 <b>5001421</b></p>	<p>200 AMP 25 KV #1 STR. Posi-break</p> <p>200 AMP 15KV 2/0 5 KV XLPE</p> <p>200 AMP 15 KV #1 STR UD Cable</p>	<p><b>CP PLE 225D05T0</b></p> <p><b>ELMD 162LR-A-5220</b> <b>RTE2604600-B-05-2/0</b></p> <p><b>ELMD 162LR-B-5230</b> <b>RTE LE215A05T</b></p>
<p>Elbow 600 Amp c/w Copper Compatible Connector</p> 	<p>6-70-12 <b>5001424</b></p> <p>6-70-15 <b>5022717</b></p> <p>6-70-20 <b>5001425</b></p>	<p>15 KV 250 MCM</p> <p>15 KV 500 MCM</p> <p>5 KV 500 MCM</p>	<p><b>T&amp;B 656 LRTP-J-0280-DRG</b> <b>3M 62LCT2H13AC-JB</b></p> <p><b>T&amp;B 656LRTP-K-0330-DRG</b> <b>3M62LCT2K18AD-JB</b></p> <p><b>T&amp;B 656 LRTP-H-0330-DRG</b> <b>3M 62LCT2H18AC-SLP-JB</b></p>
<p>Elbow 600 Amp Cold Shrink T-Body Kit</p>  <p>Kit Components T-Body, 15/16" Threaded Shear-Bolt Lug, Stud, Silica Gel</p> <p>LRTP &amp; Cap <b>OR</b> Insulating Plug &amp; Cap are separate from T-Body Kit</p>	<p>6-70-50 <b>5000665</b></p> <p>6-70-55 <b>5000666</b></p>	<p>15 KV #1AWG (6-70-40) 15 KV 250 MCM (6-70-12)</p> <p>5 KV 500 MCM (6-70-20) 15 KV 500 MCM (6-70-15) 15 KV 750 MCM (6-70-17) 25 KV 350 MCM (6-70-09) 25 KV 500 MCM (6-70-08)</p>	<p><b>RICHARDS/3M</b> 62CSHT1OR1-15/16-JB</p> <p><b>RICHARDS/3M</b> 62CSHT1PR4-15/16-JB</p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>LRTP 200 Amp 15/16" Threaded</p>  <p>Protective Cap is not included and needs to be ordered separately</p> <p>Will only fit onto T-Bodies that are equipped with 15/16" lugs</p>	<p><b>**Order 1 LRTP &amp; Cap OR Insulating Plug &amp; Cap per T-Body Kit</b></p> <p>6-70-60 <b>5001426</b></p> <p>6-70-65 <b>5001427</b></p>	<p>15 KV Protective Cap 6-81-00</p> <p>25 KV Protective Cap 6-81-04</p>	<p><b>3M P615LRTP CP LRTP615 HUB LRTP615 T&amp;B 650LRTPA3</b></p> <p><b>3M P625LRTP CP LRTP625 HUB LRTP625 T&amp;B K650LRTPA2</b></p>
<p>Insulating Plug &amp; Cap Assembly 11/16" Non-Threaded</p> 	<p>6-70-70 <b>5001428</b></p>	<p>15 - 25 KV</p>	<p><b>3M 625HIP CP DIP625A HUB 625BIP T&amp;B K650BIP</b></p>
<p>Compression Lug</p> 	<p>6-71-01 <b>5000667</b></p> <p>6-71-05 <b>5000668</b></p> <p>6-71-06 <b>5000669</b></p> <p>6-71-07 <b>5000670</b></p>	<p>#1AWG 11/16" Non- Threaded Bimetal</p> <p>250 MCM 15/16" Non- Threaded Bimetal</p> <p>500 MCM 15/16" Non- Threaded Bimetal</p> <p>750 MCM 15/16" Non- Threaded Bimetal</p>	<p><b>RICHARDS/3M P7ALCU-08</b></p> <p><b>RICHARDS/3M P7ALCU-13-15/16</b></p> <p><b>RICHARDS/3M P7ALCU-18-15/16</b></p> <p><b>RICHARDS/3M P7ALCU-23-15/16</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Bushing Well Insert</p> 	<p>6-72-00 <b>5001429</b></p>	<p>200 Amp 15 KV</p>	<p><b>ELMD 1601A4</b> <b>RTE LBI215X</b></p>
<p>Feed Y-Bushing</p> 	<p>6-72-02 <b>5001430</b></p>	<p>200 Amp 25 KV</p>	<p><b>ELMD 2701A4</b> <b>RTE LBI225X</b></p>
<p>6-72-03 <b>5001431</b></p>	<p>200 Amp 15 KV</p>	<p><b>ELMD 1602A3</b> <b>RTE 2637869C01</b></p>	
<p>6-72-04 <b>5001432</b></p>	<p>200 Amp 25 KV</p>	<p><b>ELMD 2702A1</b> <b>RTE 2637881-C01MC</b></p>	
<p>Bushing Well Insert - Fused use 7-51-20 fuse</p> <p>fuse holder 200 amp bushing use with 7-51-21 fuse</p>	<p>6-72-06 <b>5000671</b></p>	<p>15 KV</p>	<p><b>ELMD FH15</b></p>
<p>6-72-08 <b>5000672</b></p>	<p>25 KV</p>	<p><b>ELMD FH27</b></p>	
<p>Bushing Adapter 600 to 200 Amp</p> 	<p>6-72-15 <b>5001433</b></p>	<p>15 KV</p>	<p><b>ELMD 655-BEA-3</b> <b>CP DBA615</b></p>
<p>6-72-25 <b>5000673</b></p>	<p>25 KV</p>		









DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Bushing Extender	6-72-30 <b>5000674</b>	25 KV 600 Amp Use with 6-72-02	<b>ELMD K655BE</b>
Feed-Through c/w Universal Mount 15 KV 200 Amp  25 KV 200 Amp	6-74-13 <b>5001434</b>  6-74-14 <b>5001435</b>  6-74-23 <b>5001436</b>	3 Position  4 Position  3 Position	<b>ELMD 164J3</b> <b>CP LJ215C3B</b> <b>NO SUBS</b>  <b>ELMD 164J4</b> <b>RTE 2637172B03M</b> <b>NO SUBS</b>  <b>ELMD 271J3</b> <b>RTE 2637160B02MC</b> <b>NO SUBS</b>
Feed-Through c/w Universal Mount 15/25 KV 600 Amp  	6-74-32 <b>5001437</b>  6-74-33 <b>5001438</b>  6-74-34 <b>5001439</b>	2 Position  3 Position  4 Position	<b>RIC 625JD62B</b> <b>ELMD 650J2-U</b>  <b>RIC 625JD63B</b> <b>ELMD K650J3-U</b>  <b>RIC 625JD64B</b> <b>ELMD 650J4-U</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Feed Through Connectors c/w U-Straps 15/25 KV Compatible with 6-77-05</p>  	<p>6-75-01 <b>5000675</b></p> <p>6-75-03 <b>5000676</b></p> <p>6-75-05 <b>5000677</b></p>	<p>1 200 A Well, 2 600 A Bushings</p> <p>3 200 A Well</p> <p>3 600 A Bushings</p>	<p><b>Eaton JBI25C1W2BU</b></p> <p><b>Eaton LJ215C3U</b></p> <p><b>Eaton DJ625C3U</b></p>
<p>Portable Feed-Through</p> 	<p>6-76-01 <b>5001440</b></p> <p>6-76-02 <b>5001441</b></p>	<p>2 Position 200 Amp 15 KV</p> <p>2 Position 200 Amp 25 KV</p>	<p><b>CP LPF215H</b> <b>ELMD 164FT</b></p> <p><b>CP LPF225U</b> <b>ELMD 274FT</b></p>
<p>Cabinet for Mounting Feed Through Connectors</p> 	<p>6-77-05 <b>5000678</b></p>	<p>3 Position Compatible with: 6-75-01 &amp; 6-75-05</p>	<p><b>Eaton</b> <b>SEC34823F0000MGG</b></p> <p><b>Hubbell 63388046</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Base for Feed Through Connector Cabinet	6-77-10 <b>5000679</b>		Dwg Ws-424
Standoff Bushing  	6-78-01 <b>5001442</b>  6-78-03 <b>5001443</b>  6-78-05 <b>5001444</b>	200 Amp 15 KV  600 Amp 15 KV or 25 KV  200 Amp 25 KV	ELMD 161S0P CP ISB215  ELMD K650S0P RTE 2604791B01  ELMD 272S0P RTE 2625064B01-MC
Fused Elbow 200 Amp 15 KV  	6-79-01 <b>5000680</b>  6-79-03 <b>5000681</b>	#1 - 15 KV CN 3 - 45 Amp Fuse  #1 - 15 KV CN 65 - 80 Amp Fuse	ELMD 168FLR1-B0230  ELMD 168FLR3-B0230

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Arrestor Elbow 200 Amp</p> 	<p>6-79-11 <b>5001445</b></p> <p>6-79-12 <b>5001446</b></p>	<p>15 KV</p> <p>25 KV</p>	<p><b>ELMD 167ESA-10</b> <b>RTE 323811C10M</b></p> <p><b>ELMD 273ESA-18</b> <b>RTE 3238019C18M</b></p>
<p>Protective Cap</p> 	<p>6-81-00 <b>5001447</b></p> <p>6-81-02 <b>5001448</b></p> <p>6-81-04 <b>5001449</b></p>	<p>200 Amp 15 KV</p> <p>600 Amp 15 KV or 25 KV</p> <p>200 Amp 25 KV Posi-break</p>	<p><b>CP LPC215</b> <b>HUB 215ICI</b> <b>T&amp;B 160DRG</b> <b>3M 21LBICG</b></p> <p><b>CP 2625041A01</b> <b>ELMD 656 DR</b></p> <p><b>CP PLPC225</b> <b>HUB 9U01BEW500</b> <b>T&amp;B 273DRG</b> <b>3M 22LBICG</b></p>
<p>Bushing Well</p> 	<p>6-84-01 <b>5000682</b></p>	<p>200 Amp 15 KV or 25 KV</p>	<p><b>ELMD K1601PCC</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>One Piece Bushing with Clamping Plate</p> 	<p>6-85-03 <b>5000683</b></p>	<p>600 Amp 15 KV or 25 KV</p>	<p><b>RTE</b> Body-2637019B04 Clamp-2637023B01 Gasket-0501517A20 Stud-2638100B03</p>
<p>Single Phase Overhead Distribution Transformer 2400 - 120/240</p> 	<p>6-90-02 (DNR) <b>5025910</b></p> <p>6-90-03 (DNR) <b>5025912</b></p> <p>6-90-05 <b>5000684</b></p> <p>6-90-07 <b>5000685</b></p> <p>6-90-10 <b>5000686</b></p>	<p>25 KVA</p> <p>37.5 KVA</p> <p>50 KVA</p> <p>75 KVA</p> <p>100 KVA</p>	<p>Covered by 6-90-05</p> <p>Covered by 6-90-05</p> <p><b>Spec 1100 &amp; Addendum</b></p> <p><b>Spec 1100 &amp; Addendum</b></p> <p><b>Spec 1100 &amp; Addendum</b></p>
<p>Single Phase Overhead Distribution Transformer 2400 - 120/240</p> 	<p>6-90-14 (DNR) <b>5025914</b></p> <p>6-90-16 (DNR) <b>5000687</b></p>	<p>150 KVA</p> <p>167 KVA</p>	<p>Covered by 6-90-07</p> <p>Covered by 6-11-13</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Single Phase Overhead Distribution Transformer 4160 - 347</p> 	<p>6-90-33 (DNR) <b>5000688</b></p>	<p>333 KVA</p>	<p><b>Spec 1100 &amp; Addendum PARKTOWN HOTEL</b></p>
<p>Single Phase Overhead Distribution Transformer 2 HV Bushings 14.4 KV - 120/240</p> 	<p>6-91-03 (DNR) <b>5025921</b></p> <p>6-91-05 <b>5000689</b></p> <p>6-91-07 (DNR) <b>5000690</b></p> <p>6-91-10 (DNR) <b>5000691</b></p> <p>6-91-16 (DNR) <b>5000692</b></p>	<p>37.5 KVA</p> <p>50 KVA</p> <p>75 KVA</p> <p>100 KVA</p> <p>167 KVA</p>	<p>Covered by 6-91-27</p> <p><b>Spec 1100 &amp; Addendum</b></p> <p>Covered by 6-91-27</p> <p>Covered by 6-91-30</p> <p>Covered by 6-13-13</p>
<p>Single Phase Overhead Distribution Transformer Single HV Bushing 14.4 KV - 120/240</p> 	<p>6-91-23 (DNR) <b>5025934</b></p> <p>6-91-25 <b>5000693</b></p> <p>6-91-27 <b>5000694</b></p> <p>6-91-30 <b>5000695</b></p> <p>6-91-31 (DNR) <b>5000696</b></p>	<p>37 KVA</p> <p>50 KVA</p> <p>75 KVA</p> <p>100 KVA</p> <p>167 KVA</p>	<p>Covered by 6-91-25</p> <p><b>Spec 1100 &amp; Addendum</b></p> <p><b>Spec 1100 &amp; Addendum</b></p> <p><b>Spec 1100 &amp; Addendum</b></p> <p>Covered by 6-14-13</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Three Phase Overhead Distribution Transformer 4160 - 240 Delta</p> 	<p>6-92-04 (DNR) <b>5025936</b></p> <p>6-92-07 (DNR) <b>5000697</b></p> <p>6-92-11 (DNR) <b>5000698</b></p> <p>6-92-15 (DNR) <b>5000699</b></p> <p>6-92-22 (DNR) <b>5000700</b></p>	<p>45 KVA</p> <p>75 KVA</p> <p>112 KVA</p> <p>150 KVA</p> <p>225 KVA</p>	<p>Covered by 6-90-05</p> <p>Covered by 6-90-05</p> <p>Covered by 6-90-05</p> <p>Covered by 6-90-05</p> <p>Covered by 6-90-05</p>
<p>Three Phase Overhead Distribution Transformer 4160 - 120/208</p> 	<p>6-93-07 <b>5000701</b></p> <p>6-93-11 (DNR) <b>5000702</b></p> <p>6-93-15 <b>5000703</b></p> <p>6-93-22 (DNR) <b>5000704</b></p>	<p>75 KVA</p> <p>112 KVA</p> <p>150 KVA</p> <p>225 KVA</p>	<p><b>Spec 1101 &amp; Addendum</b></p> <p>Covered by 6-93-15</p> <p><b>Spec 1101 &amp; Addendum</b></p> <p>Covered by 6-27-30</p>
<p>Three Phase Overhead Distribution Transformer 4160 - 347/600</p> 	<p>6-94-11 (DNR) <b>5000705</b></p> <p>6-94-15 <b>5000706</b></p> <p>6-94-22 (DNR) <b>5000707</b></p>	<p>112 KVA</p> <p>150 KVA</p> <p>225 KVA</p>	<p>Covered by 6-94-15</p> <p><b>Spec 1101 &amp; Addendum</b></p> <p>Covered by 6-28-30</p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Three Phase Overhead Distribution Transformer 14.4 KV - 120/208</p> 	<p>6-95-07 <b>5000708</b></p> <p>6-95-11 <b>5000709</b></p> <p>6-95-15 <b>5000710</b></p> <p>6-95-22 (DNR) <b>5000711</b></p>	<p>75 KVA</p> <p>112 KVA</p> <p>150 KVA</p> <p>225 KVA</p>	<p><b>Spec 1101 &amp; Addendum</b></p> <p><b>Spec 1101 &amp; Addendum</b></p> <p><b>Spec 1101 &amp; Addendum</b></p> <p>Covered by 6-31-17</p>
<p>Three Phase Overhead Distribution Transformer 14.4 KV - 347/600</p> 	<p>6-96-11 (DNR) <b>5000712</b></p> <p>6-96-15 <b>5000713</b></p> <p>6-96-22 (DNR) <b>5000714</b></p>	<p>112 KVA</p> <p>150 KVA</p> <p>225 KVA</p>	<p>Covered by 6-96-15</p> <p><b>Spec 1101 &amp; Addendum</b></p> <p>Covered by 6-33-17</p>
<p>Single Phase Overhead Distribution Transformer Single HV Bushing 8320 - 120/240</p> 	<p>6-97-03 (DNR) <b>5000715</b></p> <p>6-97-05 <b>5001450</b></p> <p>6-97-07 <b>5000716</b></p> <p>6-97-10 <b>5000717</b></p> <p>6-97-12 (DNR) <b>5000718</b></p>	<p>37 KVA</p> <p>50 KVA</p> <p>75 KVA</p> <p>100 KVA</p> <p>167 KVA</p>	<p>Covered by 6-97-05</p> <p><b>Spec 1100 &amp; Addendum</b></p> <p><b>Spec 1100 &amp; Addendum</b></p> <p><b>Spec 1100 &amp; Addendum</b></p> <p>Covered by 6-13-13</p>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Single Phase Overhead Distribution Transformer Single HV Bushing 8320 - 240/480</p> 	<p>6-97-15 <b>5000719</b></p>	<p>50 KVA</p>	<p><b>Spec 1100 &amp; Addendum</b></p>
<p>Single Phase Overhead Distribution Transformer 2 HV Bushings 8320 - 120/240</p> 	<p>6-97-25 <b>5000720</b></p> <p>6-97-27 (DNR) <b>5000721</b></p>	<p>50 KVA</p> <p>75 KVA</p>	<p><b>Spec 1100 &amp; Addendum</b></p> <p>Covered by 6-97-07</p>
<p>Three Phase Overhead Distribution Transformer 14.4 KV - 240 Delta</p> 	<p>6-98-04 (DNR) <b>5017894</b></p> <p>6-98-07 (DNR) <b>5001498</b></p> <p>6-98-09 (DNR) <b>5000722</b></p> <p>6-98-12 (DNR) <b>5025939</b></p>	<p>45 KVA</p> <p>75 KVA</p> <p>112 KVA</p> <p>225 KVA</p>	<p>Covered by 6-97-05</p> <p>Covered by 6-97-05</p> <p>Covered by 6-97-05</p> <p>Covered by 6-97-05</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
<p>Three Phase Overhead Distribution Transformer 24940 - 240 Delta</p> 	<p>6-98-14 (DNR) <b>5025941</b></p> <p>6-98-17 (DNR) <b>5000723</b></p> <p>6-98-21 (DNR) <b>5025943</b></p> <p>6-98-25 (DNR) <b>5000724</b></p>	<p>45 KVA</p> <p>75 KVA</p> <p>112 KVA</p> <p>150 KVA</p>	<p>Covered by 6-91-25</p> <p>Covered by 6-91-25</p> <p>Covered by 6-91-25</p> <p>Covered by 6-91-25</p>
<p>Three Phase Overhead Distribution Transformer 24940 - 120/208</p> 	<p>6-98-27 <b>5000725</b></p> <p>6-98-31 <b>5000726</b></p> <p>6-98-35 <b>5000727</b></p> <p>6-98-42 (DNR) <b>5000728</b></p>	<p>75 KVA</p> <p>112 KVA</p> <p>150 KVA</p> <p>225 KVA</p>	<p><b>Spec 1101 &amp; Addendum</b></p> <p><b>Spec 1101 &amp; Addendum</b></p> <p><b>Spec 1101 &amp; Addendum</b></p> <p>Covered by 6-40-17</p>
<p>Three Phase Overhead Distribution Transformer 24940 - 347/600</p> 	<p>6-98-51 <b>5000729</b></p> <p>6-98-62 (DNR) <b>5000730</b></p>	<p>112 KVA</p> <p>225 KVA</p>	<p><b>Spec 1101 &amp; Addendum</b></p> <p>Covered by 6-43-15</p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE / WEIGHT	ORDERING INFORMATION
Three Phase Network Transformer 14700 - 347/600	6-99-01 <b>5025525</b>	2000 KVA	<b>Spec 4102</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Cookie Terminal Strips and Covers</p> 	<p>7-00-10 <b>5023035</b></p>		<p><b>ILSCO</b> N8247AQ2T</p>
<p>Insulated Roll-On Splice Cover For UG #2-2/0</p> 	<p>7-00-20 <b>5023009</b></p>		<p><b>Raychem</b> <b>RVS-11(B50)</b></p>
<p>Secondary Terminal Block</p> <p>Rubber Sleeve</p>	<p>7-04-20 <b>5000731</b></p> <p>7-04-30 <b>5000732</b></p>	<p>6 Position C/W Cover</p>	<p><b>HOM FS6-125</b></p> <p><b>CP CSN-2011</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Transformer Bushing Primary Voltage	7-05-06 <b>5000733</b>  7-05-20 <b>5000734</b>	14.4 KV  25 KV	FER-P B101024180  WEST Dwg. POB DL25A
SMU-40 Fuse Unit Standard  	7-41-40 <b>5000735</b>	200 AMP 15 KV 25,000 Interrupting	S&C SMU-40-144 No Subs
EE1-Nema Universal Screw 23" Button Link Type "K" Fast  	7-42-06 <b>5001451</b>  7-42-08 <b>5001452</b>  7-42-10 <b>5001453</b>  7-42-12 <b>5001454</b>	6 Amp  8 Amp  10 Amp  12 Amp	AB M6KA23 CP FL3K6 KRN 31006  AB M8KA23 CP FL3K8 KRN 31008  AB M10KA23 CP FL3K10 KRN 31010  AB M12KA23 CP FL3K12 KRN 31012

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
EE1-Nema Universal Screw 23" Button Link Type "K" Fast 	7-42-15 <b>5001455</b>  7-42-20 <b>5001456</b>  7-42-25 <b>5001457</b>  7-42-30 <b>5001458</b>	15 Amp   20 Amp   25 Amp   30 Amp	AB M15KA23 CP FL3K15 KRN 31015  AB M20KA23 CP FL3K20 KRN 31020  AB M25KA23 CP FL3K25 KRN 31025  AB M30KA23 CP FL3K30 KRN 31030
EE1-Nema Universal Screw 23" Button Link Type "K" Fast 	7-42-40 <b>5001459</b>  7-42-50 <b>5001460</b>  7-42-65 <b>5001461</b>  7-42-80 <b>5001462</b>	40 Amp   50 Amp   65 Amp   80 Amp	AB M40KA23 CP FL3K40 KRN 31040  AB M50KA23 CP FL3K50 KRN 31050  AB M65KA23 CP FL3K65 KRN 31065  AB M80KA23 CP FL3K80 KRN 31080
EE1-Nema Universal Screw 23" Button Link Type "K" Fast 	7-42-81 <b>5001463</b>  7-42-83 <b>5001464</b>  7-42-85 <b>5001465</b>	100 Amp   140 Amp   200 Amp	AB M100KA23 CP FL3K100 KRN 31100  AB M140KA23 CP FL3K140 KRN 31140  AB M200KA23 CP FL3K200 KRN 31200

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
EE1-Nema Universal Screw 23" Button Link Type "T" Slow 	7-43-06 <b>5001466</b>  7-43-08 <b>5001467</b>  7-43-12 <b>5001468</b>  7-43-15 <b>5001469</b>	6 Amp  8 Amp  12 Amp  15 Amp	AB M6TA23 CP FL3T6 KRN 51006  AB M8TA23 CP FL3T8 KRN 51008  AB M12TA23 CP FL3T12 KRN 51012  AB M15TA23 CP FL3T15 KRN 51015
EE1-Nema Universal Screw 23" Button Link Type "T" Slow 	7-43-20 <b>5001470</b>  7-43-25 <b>5001471</b>  7-43-30 <b>5001472</b>  7-43-40 <b>5001473</b>	20 Amp  25 Amp  30 Amp  40 Amp	AB M20TA23 CP FL3T20 KRN 51020  AB M25TA23 CP FL3T25 KRN 51025  AB M30TA23 CP FL3T30 KRN 51030  AB M40TA23 CP FL3T40 KRN 51040
EE1-Nema Universal Screw 23" Button Link Type "T" Slow 	7-43-50 <b>5001474</b>  7-43-65 <b>5001475</b>  7-43-80 <b>5001476</b>  7-43-81 <b>5001477</b>	50 Amp  65 Amp  80 Amp  100 Amp	AB M50TA23 CP FL3T50 KRN 51050  AB M65TA23 CP FL3T65 KRN 51065  AB M80TA23 CP FL3T80 KRN 51080  AB M100TA23 CP FL3T100 KRN 51100




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
EE1-Nema High Surge 23" Button Link Type "H" 	7-45-01 <b>5000736</b>  7-45-02 <b>5000737</b>  7-45-03 <b>5000738</b>  7-45-05 <b>5000739</b>	1 Amp  2 Amp  3 Amp  5 Amp	CP FL3H1  CP FL3H2  CP FL3H3  CP FL3H5
Distribution Fuse Link Type "X" 	7-46-67 <b>5000740</b>  7-46-68 <b>5000741</b>  7-46-76 <b>5000742</b>	250X Amp 7.5 KV  300X Amp 7.5 KV  200X Amp 15 KV	PUR UAX 75250  PUR UAX 75300  PUR SX 15200
Distribution Fuse Link Type "F"	7-46-87 <b>5000743</b>  7-46-88 <b>5000744</b>  7-46-98 <b>5000745</b>	250F Amp 7.5 KV  300F Amp 7.5 KV  300F Amp 15 KV	PUR UAF 75250  PUR UAF 75300  PUR UAF 15300








DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Padmount Fuse Unit 8 KV	7-47-12 <b>5000746</b>	12K Amp	S&C 511012R1
	7-47-15 <b>5000747</b>	15K Amp	S&C 511015R1
	7-47-20 <b>5000748</b>	20K Amp	S&C 511020R1
	7-47-25 <b>5000749</b>	25K Amp	S&C 511025R1
Padmount Fuse Unit 8 KV	7-47-30 <b>5000750</b>	30K Amp	S&C 511030R1
	7-47-40 <b>5000751</b>	40K Amp	S&C 511040R1
	7-47-50 <b>5000752</b>	50K Amp	S&C 511050R1
Plastic Latch  	7-48-01 <b>5000753</b>	For NX Hinged Fuses 7-48-xx	CP FM2E1C


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Indoor Current Limiting Fuse Type NX - 4.3 KV  	7-48-12 <b>5000754</b>  7-48-18 <b>5000755</b>  7-48-25 <b>5000756</b>  7-48-35 <b>5000757</b>	12 Amp  18 Amp  25 Amp  35 Amp	CP FA2A12  CP FA27A18  CP FA27A25  CP FA27A35
Indoor Current Limiting Fuse Type NX - 4.3 KV  	7-48-50 <b>5000758</b>  7-48-75 <b>5000759</b>  7-48-81 <b>5000760</b>	50 Amp  75 Amp  100 Amp	CP FA27A50  CP FA27A75  CP FA27A100
Indoor Current Limiting Fuse Type NX - 15.5 KV	7-49-12 <b>5000761</b>  7-49-18 <b>5000762</b>  7-49-25 <b>5000763</b>  7-49-40 <b>5000764</b>	12 Amp  18 Amp  25 Amp  40 Amp	CP FA30A12  CP FA30A18  CP FA30A25  CP FA30A40




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Outdoor Current Limiting Fuse 8.3 KV</p> 	<p>7-49-43 <b>5000765</b></p> <p>7-49-45 <b>5000766</b></p>	<p>25 Amp</p> <p>40 Amp</p>	<p><b>Specification 1</b> <b>AB K-Mate-25</b> C70L31KABO</p> <p><b>Specification 1</b> <b>AB K-Mate-40</b> C70L21KABO</p>
<p>Indoor Loadbreak Switchblade Type NX - 8.3 KV</p> 	<p>7-49-50 <b>5000767</b></p>	<p>200 Amp</p>	<p><b>CP FA7B1</b> <b>CP FA1B1</b></p>
<p>Fuse Holder for Wet Well Assembly Side Wall Mounted</p>  <p>Fuse Cartridge With End Plug</p>	<p>7-49-56 <b>5000768</b></p> <p>7-49-58 <b>5000769</b></p>	<p>14.4 KV</p> <p>14.4 KV</p>	<p><b>RTE 4001030B52M</b></p> <p><b>RTE 4001686-A-53</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Padmount Bayonet Fuse Dual Sensing  	7-49-60 <b>500770</b>  7-49-61 <b>500771</b>  7-49-62 <b>500772</b>	8 Amp  15 Amp  25 Amp	RTE 4000358C05  RTE 4000358C08  RTE 4000358C10
Padmount Bayonet Fuse Current Sensing  	7-49-65 <b>500773</b>  7-49-66 <b>500774</b>  7-49-67 <b>500775</b>  7-49-68 <b>500776</b>	40 Amp  65 Amp  100 Amp  140 Amp	RTE 4000353C12  RTE 4000353C14  RTE 4000353C16  RTE 4000353C17
Padmount Oil Immersible Bayonet Fuse 15.5 KV  Current Limiting Clip Style  Current Limiting Back-Up Screw Type  Current Limiting Back-Up Clip Style  	7-49-70 <b>500777</b>  7-49-78 <b>500778</b>  7-49-79 <b>500779</b>	8 Amp  100 Amp  100 Amp	RTE 3534008M11  RTE 3544100M51  RTE 3544100M11


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Padmount Dry Canister Clip Style Fuse Type NX 4.3 KV</p> 	<p>7-49-82 <b>5000780</b></p> <p>7-49-83 <b>5000781</b></p>	<p>50 Amp</p> <p>75 Amp</p>	<p><b>CP FA1H50</b></p> <p><b>CP FA1H75</b></p>
<p>Padmount Dry Canister Clip Style Fuse Type NX 15.5 KV</p> 	<p>7-49-86 <b>5000782</b></p> <p>7-49-87 <b>5000783</b></p> <p>7-49-88 <b>5000784</b></p> <p>7-49-89 <b>5000785</b></p>	<p>6 Amp</p> <p>8 Amp</p> <p>10 Amp</p> <p>12 Amp</p>	<p><b>CP FA4H6</b></p> <p><b>CP FA4H8</b></p> <p><b>CP FA4H10</b></p> <p><b>CP FA4H12</b></p>
<p>Padmount Dry Canister Clip Style Fuse Type NX 15.5 KV</p> 	<p>7-49-91 <b>5000786</b></p> <p>7-49-92 <b>5000787</b></p> <p>7-49-93 <b>5000788</b></p>	<p>18 Amp</p> <p>25 Amp</p> <p>40 Amp</p>	<p><b>CP FA4H18</b></p> <p><b>CP FA4H25</b></p> <p><b>CP FA4H40</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Padmount Dry Canister Clip Style Fuse Type CX 15.5 KV 	7-49-95 <b>5000789</b>	8C Amps	CH 5980C19G07
Drywell Canister	7-49-97 <b>5000790</b>	14.4KV	
Current Limiting Fuse Holder for Drywell Canister 	7-49-98 <b>5000791</b>  7-49-99 <b>5000792</b>	14.4 KV  14.4 KV	CGE 7559ZB1099  CGE 7559ZB3199



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Refill Power Fuse Unit Type SM-4 - 7.2 KV	7-50-02 <b>5000793</b>	40E Amp Std	S&C 121060R4
	7-50-04 <b>5000794</b>	50E Amp Std	S&C 121075R4
	7-50-06 <b>5000795</b>	200E Amp Slow	S&C 251300R4
Refill Power Fuse Unit Type SM-4 - 14.4 KV	7-50-07 <b>5000796</b>	100E Amp Std	S&C 122150R4
	7-50-08 <b>5000797</b>	200E Amp Std	S&C 122300R4
Refill Power Fuse Unit Type SM-5 - 14.4 KV  	7-50-12 <b>5000798</b>	80E Amp Std	S&C 132125R4
	7-50-16 <b>5000799</b>	125E Amp Slow	S&C 262200R4
	7-50-18 <b>5000800</b>	200E Amp Slow	S&C 262300R4
	7-50-20 <b>5000801</b>	400E Amp Std	S&C 132600R4



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Power Fuse Barrel Type Sm-4 - Outdoor (Without snuffler) 	7-50-40 <b>5000802</b>	200E Amp 7.2 KV	<b>S&amp;C 86051</b>
Type SM-4S - Indoor (With snuffler)	7-50-41 <b>5000803</b>	200E Amp 7.2 KV	<b>S&amp;C 86631R1</b>
Power Fuse Type RBA-ROB-400	7-50-50 <b>5000804</b>	250E Amps 15 KV	<b>WEST 423D815A44</b>
Switching Cubicle Fuse 	7-51-01 <b>5000805</b>	8.3 KV 200 Amp Current Limiting c/w cartridge	<b>RTE 3437851B01M</b>
	7-51-05 <b>5000806</b>	25 KV SLC-90 Current Limiting	<b>AB C705-0424</b>
	7-51-07 <b>5000807</b>	25 KV SLE-90 Oil Expulsion	<b>AB E553-3651</b>
	7-51-09 <b>5000808</b>	25 KV 95A 65E ELSG	<b>RTE 3595065M02M</b>








DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Elbow Fuse 8.3 KV</p> <p><b>** For in field replacement only</b> Not compatible with current 6-79-01</p> <p><b>** For in field replacement only</b> Not compatible with current 6-79-01</p>	<p>7-51-11 <b>5000809</b></p> <p>7-51-12 ** <b>5000810</b></p> <p>7-51-13 <b>5000811</b></p> <p>7-51-15 ** <b>5000812</b></p> <p>7-51-16 <b>5000813</b></p> <p>7-51-17 <b>5000814</b></p> <p>7-51-18 <b>5000815</b></p>	<p>8 Amp (use with 6-79-01)</p> <p>8 Amp</p> <p>30 Amp (use with 6-79-01)</p> <p>30 Amp</p> <p>45 Amp (use with 6-79-01)</p> <p>65 Amp (use with 6-79-03)</p> <p>80 Amp (use w 6-79-03)</p>	<p><b>ELMD EFX 083 008-E</b></p> <p><b>JOS PF8-8</b></p> <p><b>ELMD EFX 083 030-E</b></p> <p><b>JOS PF8-30</b></p> <p><b>ELMD EFX 083 045-E</b></p> <p><b>ELMD EFX 083 065-E</b></p> <p><b>ELMD EFX 083 080-E</b></p>
<p>SF6 Power Fuse</p> <p>Joslyn Switching Cubicle 1132-S (use with 6-72-06)</p> <p>Joslyn Switching Cubicle 1101-S (use with 6-72-08)</p>	<p>7-51-20 <b>5000816</b></p> <p>7-51-21 <b>5000817</b></p> <p>7-51-30 <b>5000818</b></p>	<p>100 Amp 15 KV</p> <p>140 Amp 15 KV</p> <p>65 Amp 25 KV</p>	<p><b>ELMD F100K-15</b></p> <p><b>JOS F140K-15</b></p> <p><b>ELMD F65K27</b></p>
<p>Plug Fuse - 120 Volt</p> 	<p>7-52-06 <b>5000819</b></p> <p>7-52-10 <b>5000820</b></p> <p>7-52-20 <b>5000821</b></p> <p>7-52-30 <b>5000822</b></p>	<p>6 Amp</p> <p>10 Amp</p> <p>20 Amp</p> <p>30 Amp</p>	<p><b>BUSS W-6</b> (No Subs)</p> <p><b>BUSS W-10</b> (No Subs)</p> <p><b>GLD GP-20</b> (No Subs)</p> <p><b>GLD GP-30</b> (No Subs)</p>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>One Time Fuse - 250 Volt, 10 KA Class H Ferrule Type</p> 	<p>7-53-10 <b>5000823</b></p> <p>7-53-15 <b>5000824</b></p> <p>7-53-20 <b>5000825</b></p> <p>7-53-30 <b>5000826</b></p> <p>7-53-50 <b>5000827</b></p> <p>7-53-60 <b>5000828</b></p>	<p>10 Amp</p> <p>15 Amp</p> <p>20 Amp</p> <p>30 Amp</p> <p>50 Amp</p> <p>60 Amp</p>	<p>NRN 10</p> <p>NRN 15</p> <p>NRN 20</p> <p>NRN 30</p> <p>NRN 50</p> <p>NRN 60</p>
<p>Mini Fuse One Time - 600 Volt, 100 KA Ferrule Type For 120V, 240V &amp; 347V Fixtures</p> 	<p>7-53-68 <b>5001478</b></p> <p>7-53-70 <b>5000829</b></p> <p>7-53-74 <b>5000831</b></p> <p>7-53-76 <b>5000833</b></p>	<p>6 Amp</p> <p>10 Amp</p> <p>20 Amp</p> <p>30 Amp</p>	<p><b>BUSS KTK-6 MER ATM6</b></p> <p><b>BUSS KTK-10 MER ATM10</b></p> <p><b>BUSS KTK-20 MER ATM20</b></p> <p><b>BUSS KTK-30 MER ATM30</b></p>
<p>Mini Fuse Neutral Link</p> 	<p>7-53-98 <b>5000835</b></p>		<p><b>SHAW MNL30</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>One Time Fuse - 250 Volt Knife Blade Type</p> 	<p>7-54-07 <b>5000836</b></p> <p>7-54-10 <b>5000837</b></p>	<p>70 Amp</p> <p>100 Amp</p>	
<p>PT Fuse</p>  <p>Main St, College Park &amp; Lorne Ave SS</p> <p>Friebel, Taylor &amp; Bunn SS</p> <p>For West PT's at Cowley &amp; Ave C SS For Landfill</p>	<p>7-63-01 <b>5000838</b></p> <p>7-63-07 <b>5000839</b></p> <p>7-63-08 <b>5000840</b></p> <p>7-63-09 <b>5000841</b></p> <p>7-63-11 <b>5000842</b></p> <p>7-63-12 <b>5000843</b></p> <p>7-63-15 <b>5000844</b></p>	<p>3/10 Amp, 2400 Volt</p> <p>2E Amp, 4800 Volt</p> <p>1/2E Amp, 7200 Volt</p> <p>1/2E Amp, 14400 Volt</p> <p>1E Amp, 14400 Volt</p> <p>1E Amp</p> <p>1/2 Amp, 25 KV</p>	<p><b>BUSS BNF1</b></p> <p><b>GE 328L497G13</b></p> <p><b>S&amp;C 271000</b></p> <p><b>GE 328L497G19</b></p> <p><b>S&amp;C T1265</b> <b>Brush 15-12CAV1E</b></p> <p><b>GE 328L0497G20</b></p> <p><b>EATON 25CLPT-.5</b></p>
<p>Secondary Fuse for Padmount Transformer &amp; Pedestal 600 Volt HRC Form J Type</p>	<p>7-65-15 <b>5000845</b></p>	<p>150 Amp</p>	<p><b>EE C150J</b> <b>SHAW A4J150</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Limiter Fuse for Pedestal  	7-65-16 <b>5000847</b>  7-65-17 <b>5000848</b>	150 Amp Old Style - Pre 1990  150 Amp New Style - After 1990	<b>BUR LF1025</b>  <b>BUSS UHW-K</b>
Limiter Fuse For Pedestal Terminal Block	7-65-20 <b>5000849</b>  7-65-22 <b>5000851</b>  7-65-24 <b>5000853</b>	# 2 str. cu  2/0 str. cu  4/0 str. cu	<b>CAB 2CL2BF</b> <b>FER 2CL2BF</b>  <b>CAB 2CL20BF</b> <b>FER 2CL20BF</b>  <b>CAB 2CL40BF</b> <b>FER 2CL40BF</b>
Current Limiting Fuse HRC Form J 600 Volt 200,000 Amp Interruption  	7-65-40 <b>5000855</b>	400 Amp	<b>EE C400J</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Network Limiter Fuse 600 Volt 200,000 Amp Interruption</p> 	<p>7-65-61 <b>5000856</b></p> <p>7-65-63 <b>5000857</b></p> <p>7-65-65 <b>5000858</b></p>	<p># 2</p> <p>2/0</p> <p>500 MCM</p>	<p><b>GLD CP2C3</b></p> <p><b>GLD CP20C3</b></p> <p><b>BUSS TYPE KDM GLD CP500C3</b></p>
<p>Secondary Network Protector Fuse</p>	<p>7-65-67 <b>5000860</b></p> <p>7-65-68 <b>5000861</b></p>	<p>600 Volt 2000 Amp 3 Hole</p> <p>600 Volt 2500 Amp 4 Hole</p>	<p><b>WEST 1300553</b></p> <p><b>WEST 1332318</b></p>
<p>Network Fuse</p>  <p>In-Line Fuseholder</p>  <p>Waterproof Sleeve</p> 	<p>7-65-70 <b>5000862</b></p> <p>7-65-71 <b>5000864</b></p> <p>7-65-72 <b>5000865</b></p>	<p>600 Volt 30 Amp 200 KA</p> <p>600 Volt 30 Amp 200 KA</p>	<p><b>BUSS KTKR-30 SHAW ATMR30</b></p> <p><b>SHAW FEC-11-11-BA</b></p> <p><b>BUSS 1A0512 SHAW FSB1</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Primary Network Limiter Fuse Control Cabinet	7-65-84 <b>500867</b>  7-65-86 <b>500869</b>	1 AMP 200,000 KA  5 AMP 200,000 KA	<b>BUSS KTK GLD ATMR1</b>  <b>BUSS KTK GLD ATMR5</b>
Network Fuse Type MPL	7-66-01 <b>500871</b>	2825 Amp	<b>WEST 140D318G02</b>
Network Limiter Protection  Rubber Sleeve  	7-69-00 <b>500872</b>		<b>HOM FS1175 GLD CPB10 part A2576B</b>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Tape</p> <p>PVC</p>  <p>Self Amalgamating Polyisobutylene Rotunda Selotape</p> 	<p>7-72-01 <b>5000874</b></p> <p>7-72-03 <b>5000875</b></p> <p>7-72-05 <b>5000876</b></p> <p>7-72-07 <b>5000877</b></p> <p>7-72-09 <b>5000878</b></p>	<p>3/4" x 66'</p> <p>3/4" x 66' x .0085" (For Winter Use)</p> <p>2"x36 yards x .0085"</p> <p>1" x 30' Linerless</p> <p>2" x 30'</p>	<p><b>3M</b> Temflex</p> <p><b>3M</b> - #88</p> <p><b>3M</b> #88-2"</p> <p><b>3M</b> - #130C</p> <p>Scapa 2501-2</p>
<p>Tape</p>  <p>Semi-Conducting</p> <p>Silicon Splicing</p> <p>Busbar Heatshrink Insulation</p>	<p>7-72-16 <b>5000879</b></p> <p>7-72-20 <b>5000880</b></p> <p>7-72-38 <b>5000881</b></p>	<p>3/4"</p> <p>1" x 30'</p> <p>2" x 25'</p>	<p><b>3M</b> #13 (No Substitutes)</p> <p><b>3M</b> #70 (No Substitutes)</p> <p><b>RAY</b> HVBT-2-R</p>
<p>Braid</p> <p>Tinned Copper Tinsel</p>  <p>Flexible</p> 	<p>7-72-40 <b>5000882</b></p> <p>7-72-42 <b>5000883</b></p>	<p>5/16"</p> <p>18" Strap</p>	<p>Belden 8663</p> <p><b>BUR</b> BD18</p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Phase Tape</p> <p>Red</p> <p>Yellow</p> <p>Blue</p> <p>White</p>	<p>7-72-60 <b>500884</b></p> <p>7-72-61 <b>500885</b></p> <p>7-72-62 <b>500886</b></p> <p>7-72-63 <b>500887</b></p>	<p>3/4" x 66'</p> <p>3/4" x 66'</p> <p>3/4" x 66'</p> <p>3/4" x 66'</p>	<p><b>3M</b> Colourflex-Red</p> <p><b>3M</b> Colourflex-Yellow</p> <p><b>3M</b> Colourflex-Blue</p> <p><b>3M</b> Colourflex-White</p>
<p>Phase Marker Disc Type</p> <p>Red</p> <p>Yellow</p> <p>Blue</p> 	<p>7-72-76 <b>500888</b></p> <p>7-72-77 <b>500889</b></p> <p>7-72-78 <b>500890</b></p>		
<p>Omni Marker Balls</p> <p>Red - Power</p> <p>Marker Plate</p> <p>Red - Power</p> 	<p>7-72-80 <b>500891</b></p> <p>7-72-82 <b>5018269</b></p>	<p>Part #160</p> <p>1251 EMS Full Range</p>	<p><b>3M</b> 80610221295</p>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Cable Tags</p> 	<p>7-72-90 <b>5000892</b></p> <p>7-72-91 <b>5000893</b></p> <p>7-72-92 <b>5000894</b></p> <p>7-72-93 <b>5000895</b></p>	<p>North</p> <p>South</p> <p>East</p> <p>West</p>	
<p>Duxseal</p> 	<p>7-73-01 <b>5000896</b></p>	<p>1 lb. Pug</p>	
<p>Aquaseal</p> 	<p>7-73-03 <b>5000897</b></p>	<p>1/8" x 3 3/4" x 10'</p>	<p><b>KRN 104742</b></p>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Cable Prep Kits	7-73-04 <b>5000898</b>	CC2	<b>3M</b>
Cadweld Thermite Cartridge 	7-74-06 <b>5000899</b>  7-74-09 <b>5000900</b>  7-74-11 <b>5000901</b>  7-74-20 <b>5000902</b>	#65  #90  #115  #200	CAD 90PLUSF20  CAD 115PLUSF20  CAD 200PLUSF20
Man Hole Lid  Man Hole Frame  Man Hole Collar	7-78-01 <b>5000903</b>  7-78-03 <b>5000904</b>  7-78-05 <b>5000905</b>	813mm (32")  813mm (32")  50mm (2")	Dwg. A1s-103  Dwg. A1s-103  Dwg. A1s-103






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Stress Cone Kit Indoor  	7-80-13 <b>5000906</b>  7-80-17 <b>5000907</b>	15KV-500, 750, 1000 25KV-500  1000 MCM - 15 KV XLPE Sh	3M 7655-T-150  ELMD 35MSC-KB
Stress Cone Kit - Cold Shrink Indoor	7-80-50 <b>5000908</b>	5KV 700-1500MCM 15KV 500-1000MCM	3M 7645-T-110
Sheild Adapter for Cold Shrink Stress Cones Constant Force Springs  Use with 7-72-40	7-82-04 <b>5000909</b>  7-82-10 <b>5000910</b>	Up to 500 MCM  750 MCM and over	3M CFS-0.80/1.50  3M CFS-1.50/3.00

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Stress Cone Kit Cold Shrink Concentric Neutral Outdoor	7-83-15 <b>5000911</b>	5 KV 4/0 - 400 MCM 15 KV #2 - 4/0 25 KV #2 - 1/0	<b>3M 7652-S-4</b>
	7-83-19 <b>5000912</b>	5 KV 500-750 MCM 15 KV 4/0 - 500 MCM 25 KV 2/0 - 250 MCM	<b>3M 7654-S-4</b>
	7-83-21 <b>5000913</b>	15 KV 750 MCM 15 KV 1000 MCM	<b>3M 7655-S-4</b>
Kellems Grip Mounting Bracket  	7-85-02 <b>5000914</b>		<b>CP DM9B1</b>
Cable Hanger Kellems Grip  	7-86-02 <b>5000915</b>	#1 - 15 KV 250 MCM - 15 KV #1 - 25 KV	<b>ELMD 35MTB1-B</b>
	7-86-04 <b>5000916</b>	250 MCM - 15 KV 500 MCM - 15 KV 500 MCM - 5 KV	<b>ELMD 35MTB1-A</b>
	7-86-06 <b>5000917</b>	750 MCM - 15 KV 1000 MCM - 15 KV	<b>ELMD 35MTB1-D</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Cable Hanger Kellems Grip For Substations Only</p> 	<p>7-86-12 <b>5000918</b></p> <p>7-86-16 <b>5000919</b></p> <p>7-86-17 <b>5000920</b></p>	<p>500 MCM - 15 KV Grip Range 1.562"-1.687"</p> <p>750 MCM - 15 KV Grip Range 1.812"-1.937"</p> <p>1000 MCM - 15 KV Grip Range 2.062"-2.187"</p>	<p><b>HUB 07401034</b></p> <p><b>HUB 074011031</b></p> <p><b>HUB 074011033</b></p>
<p>Cable Support Bracket</p> 	<p>7-86-22 <b>5000921</b></p> <p>7-86-24 <b>5000922</b></p> <p>7-86-26 <b>5000923</b></p> <p>7-86-28 <b>5000924</b></p>	<p>Cable OD Range</p> <p>1.0" - 1.25"</p> <p>1.0" - 1.5"</p> <p>1.5" - 2.0"</p> <p>2.0" - 2.5"</p>	<p><b>3M MB-3</b></p> <p><b>3M MB-4</b></p> <p><b>3M MB-5</b></p> <p><b>3M MB-6</b></p>
<p>Hooks for Cable Hangers</p> 	<p>7-86-50 <b>5000925</b></p> <p>7-86-55 <b>5000927</b></p>	<p>For Wood Poles</p> <p>For Steel Poles</p>	<p><b>MAC P J3316P</b> <b>SL 1316</b></p> <p><b>MAC P U2398</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Kellems Grip Support for Three Cables Standard</p> 	<p>7-87-01 <b>5000928</b></p> <p>7-87-02 <b>5000929</b></p> <p>7-87-03 <b>5000930</b></p> <p>7-87-04 <b>5000931</b></p>	<p>3.50 - 3.99" 750 MCM - 15 KV</p> <p>3.00 - 3.49" 500 MCM - 15 KV 500 MCM - 25 KV</p> <p>2.50 - 3.00" 250 MCM - 15 KV</p> <p>2.00 - 2.49" #1 - 15 KV 250 MCM - 5 KV #1 - 25 KV</p>	<p><b>HUB 022-01-012</b></p> <p><b>HUB 022-01-011</b></p> <p><b>HUB 022-01-010</b></p> <p><b>HUB 022-01-009</b></p>
<p>Kellems Grip Support for Three Cables Split</p> 	<p>7-87-11 <b>5000932</b></p> <p>7-87-12 <b>5000933</b></p> <p>7-87-14 <b>5000934</b></p>	<p>3.50 - 3.99" 750 MCM - 15 KV</p> <p>3.00 - 3.49" 500 MCM - 15 KV 500 MCM - 25 KV</p> <p>2.00 - 2.49" #1 - 15 KV 250 MCM - 5 KV #1 - 25 KV</p>	<p><b>HUB 022-03-012</b> <b>Eaton SGDR350</b></p> <p><b>HUB 022-03-011</b> <b>Eaton SGDR300</b></p> <p><b>HUB 022-03-009</b> <b>Eaton SGDR200</b></p>
<p>Kellem's Grip Support for Single Eye</p> 	<p>7-87-21 <b>5023011</b></p> <p>7-87-22 <b>5023032</b></p> <p>7-87-23 <b>5023023</b></p>	<p>1" - 1.24"</p> <p>1.25" - 1.49"</p> <p>1.5" - 1.74"</p>	<p><b>02401041</b></p> <p><b>02401042</b></p> <p><b>02401043</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Splice Kit - One Piece</p> 	<p>7-88-03 <b>5024921</b></p> <p>7-88-05 <b>5000935</b></p> <p>7-88-13 <b>5001479</b></p> <p>7-88-15 <b>5001480</b></p> <p>7-88-17 <b>5000937</b></p>	<p>#1 - 15 KV To meet IEEE Standard 404</p> <p>#1 - 25 KV To meet IEEE Standard 404</p> <p>500 MCM - 15 KV</p> <p>750 MCM - 15 KV</p> <p>500 MCM - 25 KV</p>	<p>ELMD 15 PCJ-1F2 230</p> <p>ELMD 25 PCJ-1G2 230 CP SP25B003C</p> <p>ELMD 15PCJ1K2330 RTE 2604904 B35M</p> <p>ELMD 15PCJ1M2380 RTE 2604904 B09M</p> <p>ELMD 25PCJ1L2330</p>
<p>Re-Jacketing Kit - Cold Shrink (Special instruction sheet in kit)</p>	<p>7-88-30 <b>5000938</b></p> <p>7-88-33 <b>5000939</b></p>	<p>For use with 7-88-05</p> <p>For use with 7-88-13, 7-88-15 &amp; 7-88-17</p>	<p>3M SJ-1A</p> <p>3M SJ-3A</p>
<p>Separable Splice Parts</p> <p>Straight Receptacle Housing </p> <p>Housing </p> <p>Insulated Cap c/w Bail </p> <p>Insulated Plug c/w Test Point </p>	<p>7-89-01 <b>5000940</b></p> <p>7-89-02 <b>5000941</b></p> <p>7-89-12 <b>5000942</b></p> <p>7-89-14 <b>5000943</b></p>	<p>600 Amp 15 KV</p> <p>600 Amp 15 KV</p> <p>600 Amp 15 KV</p> <p>600 Amp 15 KV</p>	<p>ELMD K655 YBSR</p> <p>ELMD K6561-HP</p> <p>ELMD K655-YDR</p> <p>ELMD K650 YB1P</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Separable Splice Parts 2 Way Insulated Bus Bar c/w Testpoint  3 Way Insulated Bus Bar  4 Way Insulated Bus Bar  Compression Lug 	7-89-22 <b>5000944</b>  7-89-23 <b>5000945</b>  7-89-24 <b>5000946</b>  7-89-32 <b>5000947</b>  7-89-33 <b>5000948</b>	600 Amp 15 KV  600 Amp 15 KV  600 Amp 15 KV  500 MCM  750 MCM	ELMD K656I-BUS  ELMD K656CY-BUS  ELMD K656CH-BUS  ELMD 03702330  ELMD 03702380
600 Amp Splice Parts Cable Adapter 	7-90-03 <b>5000949</b>  7-90-07 <b>5000950</b>  7-90-09 <b>5000951</b>	2/0 5KV Rubber 250MCM-5KV XLPE #1 - 15 KV XLPE CN or Sh  250MCM-5KV Rubber 500MCM-5KV XLPE CN or Sh  500 MCM - 5 KV Old Cable 250 MCM - 15 KV XLPE Sh	ELMD 655CA-F  ELMD 655CA-H  ELMD 655CA-J
600 Amp Splice Parts Cable Adapter 	7-90-11 <b>5000952</b>  7-90-13 <b>5000953</b>  7-90-15 <b>5000954</b>	500 MCM - 5 KV Rubber 500 MCM - 15 KV XLPE Sh & UD 350 MCM - 25 KV XLPE UD  500 MCM - 25 KV XLPE CN Injection adapter for 250 MCM  750 MCM - 15 KV XLPE CN or Sh Injection adapter for 500 MCM	ELMD 655CA-K  ELMD 655CA-L  ELMD 655CA-M





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>600 Amp Splice Parts</p> <p>Retaining Ring</p> 	<p>7-90-20 <b>5000955</b></p> <p>7-90-21 <b>5000956</b></p> <p>7-90-22 <b>5000957</b></p> <p>7-90-24 <b>5000958</b></p>	<p>250 MCM STR</p> <p>350 MCM STR</p> <p>500 MCM STR</p> <p>750 MCM STR</p>	<p><b>ELMD 650ARR-280</b></p> <p><b>ELMD 650ARR-300</b></p> <p><b>ELMD 650ARR-330</b></p> <p><b>ELMD 650ARR-380</b></p>
<p>Heat Shrink Splice</p> <p>600 Volt</p> 	<p>7-91-01 <b>5018306</b></p> <p>7-91-03 <b>5000959</b></p> <p>7-91-04 <b>5000960</b></p> <p>7-91-06 <b>5000961</b></p> <p>7-91-07 <b>5000962</b></p>	<p><b>NO SUBS</b></p> <p>#8 AWG - 1/0 AWG 0.20" - .80"</p> <p>#2 AWG - 4/0 AWG 0.37" - 1.10"</p> <p>3/0 AWG - 400 MCM 0.50" - 1.50"</p> <p>250 - 750 MCM 0.65" - 2.0"</p> <p>600 - 1200 MCM 1.0" to 3.0"</p>	<p><b>3M ITCSN-0800</b></p> <p><b>3M ITCSN-1100</b></p> <p><b>3M ITCSN-1500</b></p> <p><b>3M ITCSN-2000</b></p> <p><b>3M ITCSN-3000</b></p>
<p>Heat Shrink Splice</p> <p>600 Volt</p>  <p>Heat Shrink Splice Clear</p> <p>600 Volt</p> <p>Heat Shrink Cap</p>	<p>7-91-10 <b>5018300</b></p> <p>7-91-12 <b>5018301</b></p> <p>7-91-14 <b>5018309</b></p> <p>7-91-21 <b>5000963</b></p> <p>7-91-50 <b>5025962</b></p>	<p>#16 AWG - #12 AWG 0.12" - 0.35"</p> <p>#12 AWG - #6 AWG 0.16" - 0.51"</p> <p>#6 AWG - #1 AWG 0.24" - 0.75"</p> <p>2/0 Ground Leads 1" x 48"</p> <p>500 MCM</p>	<p><b>T&amp;B HS16-12-4</b></p> <p><b>T&amp;B HS12-6-4</b></p> <p><b>T&amp;B HS6-1-4</b></p> <p><b>3M 3MFP301</b></p> <p><b>ABB HSC300600</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Cold Shrink Splice Kit - For Copper or Aluminum Conductors - JCN and CN Cables - Kits include Shear-bolt connectors  	7-92-01 <b>5001481</b>	15 KV #1 AWG	<b>3M</b> 5415A-QCI-2-250-SKLP <b>PRY</b> 15SDJCe-C-6-3/0-ALSB <b>RIC</b> 62SSCNOR1-S-SASK
	7-92-03 <b>5001482</b>	15 KV 250 MCM	<b>3M</b> 5416A-QCI-2-250-SKLP <b>PRY</b> 15SFJCe-C-1/0-500-ALSB <b>RIC</b> 62SSCNOR1-SASK
	7-92-05 <b>5001483</b>	15 KV 500 MCM 750 MCM	<b>3M</b> 5417A-QCI-350-750-SKLP <b>PRY</b> 15SIPJCe-C-350-750-ALSB <b>RIC</b> 62SSCNPR2-SASK

Notes - 3M & Prysmian parts are not interchangeable. - Tape shielded cables require different splice kits or hand splices. - 1000 MCM splices are special order. - Contact Engineering Section (Spec 2326) if splicing an unknown cable in the field.	7-92-07 <b>5001484</b>	25 KV #1 AWG	<b>3M</b> 5456A-QCI-2-250-SKLP <b>PRY</b> 25SEJCe-C-6-3/0-ALSB <b>RIC</b> 62SSCNOR1-SASK
	7-92-09 <b>5001485</b>	25 KV 500 MCM	<b>3M</b> 5457A-QCI-350-750-SKLP <b>PRY</b> 25SIPJCe-C-1/0-500-ALSB <b>RIC</b> 62SSCNQR1-SASK

Voltage	#1 AWG	1/0 AWG	2/0 AWG	4/0 AWG	250 MCM	500 MCM	750 MCM
5 KV	7-92-01 3M • PRY			7-92-01 3M			
15 KV	7-92-01 3M • PRY RIC	Check with Engineering			7-92-03 3M • PRY RIC	7-92-05 3M • PRY RIC	7-92-05 3M • PRY RIC 7-92-09 RIC
25 KV	7-92-07 3M • PRY RIC	Check with Engineering				7-92-09 3M • PRY RIC	

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Cold Shrink Splice</p> 	<p>7-92-21 <b>5000969</b></p> <p>7-92-23 <b>5000970</b></p> <p>7-92-25 <b>5000971</b></p> <p>7-92-27 <b>5000972</b></p>	<p>1000 Volt #6 - #4</p> <p>1000 Volt #2 - 1/0</p> <p>1000 Volt 2/0 - 250 MCM</p> <p>1000 Volt 500 MCM - 800 MCM</p>	<p><b>3M</b> 8423-6</p> <p><b>3M</b> 8425-8</p> <p><b>3M</b> 8426-11</p> <p><b>3M</b> 8428-18</p>
<p>Grounding Sock for Splice Kits</p>  <p>Product is non current carrying</p>	<p>7-93-02 <b>5000973</b></p>	<p>4/0 500 MCM</p>	<p><b>3M</b> Product #SS 2</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Relay Feeder Management GE Multilin	8-10-10 <b>5000974</b>		<b>GE 760-P5-G5-S5-HI-A1-R-E</b>
<p>Network Protector Relay</p>  <p>Grounded CT's</p>	<p>8-12-01 <b>5020341</b></p> <p>8-12-02 <b>5020353</b></p> <p>8-12-03 <b>5026702</b></p> <p>8-12-04 <b>5026704</b></p>	<p>MPCV-D Relay For use with: Eaton CM-D Eaton CM-52</p> <p>MNPR Relay For use with: Richards 31XNP</p> <p>MPCV-HV Relay For use with: Eaton CM-22 (Vault 13) PT Block required</p> <p>PT Block</p>	<p><b>EAT 6417C82G01</b></p> <p><b>RIC 521968-H5-RS485</b></p> <p><b>EAT 8231A80G02</b></p> <p><b>EAT 8311A45H01</b></p>
<p>Potential Transformer</p> 	<p>8-14-02 <b>5026685</b></p> <p>8-14-04 <b>5026687</b></p>	<p>For Eaton NP's 347:125 VAC 60Hz</p> <p>For Richards NP's 347:125 VAC 60Hz</p>	<p><b>EAT 8310A75H03</b></p> <p><b>ETI 313-0052-50</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Control Power Transformer</p> 	<p>8-14-12 <b>5026689</b></p> <p>8-14-14 <b>5026694</b></p>	<p>For Eaton NP's 600:125/216 VAC 60Hz</p> <p>For Richards NP's 600:125/208 VAC 60Hz</p>	<p><b>EAT 8230A18H02</b></p> <p><b>ETI 313-0051-70</b></p>
<p>Capacitor Replacement</p> 	<p>8-14-22 <b>5026696</b></p>	<p>Solid State Module For Eaton CM-D style NP's Obsolete P/N's</p> <p><b>EAT 8310A96H01</b> <b>EAT NMD0014H01</b> <b>EAT NAS0279G01</b></p>	<p><b>EAT CTD-5-120</b></p>
<p>Electronic Meter, Single Phase 3 Wire, Self-Contained, 200A, 240V</p> <p>4-Jaw Socket Base</p>	<p>8-22-50 <b>5018069</b></p>	<p>Form 2</p>	<p><b>Aclara I210+ 727X-200174</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Electronic Meter, Single Phase 2 Wire, Transformer-Rated 20A, 120-480V (Auto Ranging)</p> <p>5-Jaw Socket Base, Demand with RS485 Communication and Mass Memory</p>	<p>8-23-72 <b>5018070</b></p>	<p>Form 3</p>	<p><b>Honeywell</b> A3RL ZDA210F00L4</p>
<p>Electronic Meter, Polyphase 3 Wire, 2 Element, Transformer-Rated 10A, 120-347V (Auto Ranging)</p> <p>A-Base, Demand with RS485 Communication and Mass Memory</p>	<p>8-24-22 <b>5018080</b></p>	<p>Form 5</p>	<p><b>Honeywell</b> A3RL ZD2210F00L4</p>
<p>Electronic Meter, Polyphase 4 Wire, 3 Element, Transformer-Rated 10A, 120-347V (Auto Ranging)</p> <p>13-Jaw Socket Base, Demand with RS485 Communication and Mass Memory</p>	<p>8-25-72 <b>5018087</b></p>	<p>Form 9</p>	<p><b>Honeywell</b> A3RL ZD8210F00L4</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Electronic Meter (AMI), Single Phase 2 Wire, Self-Contained, 100A, 120V</p> <p>A-Base</p> <p>4-Jaw Socket Base</p>	<p>8-31-00 <b>5018081</b></p> <p>8-31-50 <b>5026142</b></p>	Form 1	<p><b>Honeywell</b> GREX ZGA7K000500</p> <p><b>Honeywell</b> REXU ZHA120000004</p>
<p>Electronic Meter (AMI), Single Phase 3 Wire, Self-Contained, 100A, 240V</p> <p>A-Base</p> <p>4-Jaw Socket Base, Bidirectional</p> <p>4-Jaw Socket Base, Bidirectional with Remote Disconnect</p> <p>4-Jaw Socket Base, Bidirectional with Zigbee Communication</p>	<p>8-32-00 <b>5018092</b></p> <p>8-32-54 <b>5018093</b></p> <p>8-32-55 <b>5018094</b></p> <p>8-32-56 <b>5018215</b></p>	Form 2	<p><b>Honeywell</b> GREX ZGC74000500</p> <p><b>Honeywell</b> REXU ZHCWM000004</p> <p><b>Honeywell</b> REXU ZHCWMA00004</p> <p><b>Honeywell</b> R2S ZFCWM0B0000</p>
<p>Electronic Meter (AMI), Single Phase 2 Wire, Transformer-Rated 20A, 120-480V (Auto Ranging)</p> <p>5-Jaw Socket Base</p> <p>5-Jaw Socket Base with Mass Memory</p> <p>5-Jaw Socket Base, Demand with Mass Memory</p> <p>5-Jaw Socket Base with External Antenna and Mass Memory</p>	<p>8-33-50 <b>5018089</b></p> <p>8-33-52 <b>5018095</b></p> <p>8-33-53 <b>5018096</b></p> <p>8-33-58 <b>5018097</b></p>	Form 3	<p><b>Honeywell</b> REXU ZHA220000004</p> <p><b>Honeywell</b> A3TL ZD2210PH082</p> <p><b>Honeywell</b> A3RL ZDA210PH0L4</p> <p><b>Honeywell</b> A3TL ZD2210PK082</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Electronic Meter (AMI), Single Phase 2 Wire, Transformer-Rated 20A, 120-480V (Auto Ranging)</p> <p>5-Jaw Socket Base, Bidirectional Demand with Mass Memory</p> <p>5-Jaw Socket Base, Demand with External Antenna and Mass Memory</p> <p>5-Jaw Socket Base, Bidirectional Demand with External Antenna and Mass Memory</p>	<p>8-33-69 <b>5018098</b></p> <p>8-33-70 <b>5018099</b></p> <p>8-33-85 <b>5018090</b></p>	Form 3	<p><b>Honeywell</b> A3RAL ZDA210PH0LG</p> <p><b>Honeywell</b> A3RL ZDA210PK0L4</p> <p><b>Honeywell</b> A3RAL ZDA210PK0LG</p>
<p>Electronic Meter (AMI), Polyphase 3 Wire, 2 Element, Transformer-Rated 10A, 120-347V (Auto Ranging)</p> <p>A-Base with Mass Memory</p> <p>A-Base, Demand with Mass Memory</p> <p>A-Base, Demand with External Antenna and Mass Memory</p> <p>8-Jaw Socket Base, Demand with Mass Memory</p>	<p>8-34-02 <b>5018100</b></p> <p>8-34-03 <b>5018091</b></p> <p>8-34-20 <b>5018101</b></p> <p>8-34-53 <b>5018102</b></p>	Form 5	<p><b>Honeywell</b> A3TL ZD530098082</p> <p><b>Honeywell</b> A3RL ZD3210P80L4</p> <p><b>Honeywell</b> A3RL ZD2B10P90L4</p> <p><b>Honeywell</b> A3RL ZD2210P80L4</p>
<p>Electronic Meter (AMI), Polyphase 4 Wire, 3 Element, Transformer-Rated 10A, 120-347V (Auto Ranging)</p> <p>A-Base with Mass Memory</p> <p>13-Jaw Socket Base with Mass Memory</p> <p>13-Jaw Socket Base, Demand with Mass Memory</p> <p>13-Jaw Socket Base with External Antenna and Mass Memory</p> <p>13-Jaw Socket Base, Bidirectional Demand with Mass Memory</p>	<p>8-35-02 <b>5018103</b></p> <p>8-35-52 <b>5018112</b></p> <p>8-35-53 <b>5018113</b></p> <p>8-35-58 <b>5018104</b></p> <p>8-35-69 <b>5018105</b></p>	Form 9	<p><b>Honeywell</b> A3TL ZD8B10P8082</p> <p><b>Honeywell</b> A3TL ZD3210PH082</p> <p><b>Honeywell</b> A3RL ZD3210PH0L4</p> <p><b>Honeywell</b> A3TL ZD3210PK082</p> <p><b>Honeywell</b> A3RAL ZD3210PH0LG</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>13-Jaw Socket Base, Demand with External Antenna and Mass Memory</p> <p>13-Jaw Socket Base, Demand with KYZ Pulse and Mass Memory</p> <p>13-Jaw Socket Base, Bidirectional Demand with External Antenna and Mass Memory</p> <p>13-Jaw Socket Base, Bidirectional Demand with KYZ Pulse and Mass Memory</p> <p>13-Jaw Socket Base, Demand w External Antenna, KYZ Pulse and Mass Memory</p>	<p>8-35-70 <b>5018114</b></p> <p>8-35-71 <b>5018106</b></p> <p>8-35-85 <b>5018107</b></p> <p>8-35-86 <b>5018108</b></p> <p>8-35-88 <b>5018109</b></p>	Form 9	<p><b>Honeywell</b> A3RL ZD3210PK0L4</p> <p><b>Honeywell</b> A3RL ZD3213PH0L4</p> <p><b>Honeywell</b> A3RAL ZD3210PK0LG</p> <p><b>Honeywell</b> A3RAL ZD3213PH0LG</p> <p><b>Honeywell</b> A3RL ZD3213PK0L4</p>
<p>Electronic Meter (AMI), Polyphase 3 Wire, Network, Self-Contained 200A, 120/208V</p> <p>5-Jaw Socket Base, Bidirectional</p> <p>5-Jaw Socket Base, Bidirectional with Remote Disconnect</p>	<p>8-36-54 <b>5018110</b></p> <p>8-36-55 <b>5018115</b></p>	Form 12 (Network)	<p><b>Honeywell</b> REXU ZF53K000000</p> <p><b>Honeywell</b> REXU ZH53KA00000</p>
<p>Electronic Meter (AMI), Polyphase 3 Wire, 2 Element, Delta, Self-Contained, 200A, 120-480V (Auto Ranging)</p> <p>5-Jaw Socket Base with Mass Memory</p> <p>5-Jaw Socket Base, Demand with Mass Memory</p>	<p>8-37-52 <b>5018116</b></p> <p>8-37-53 <b>5018117</b></p>	Form 12 (Delta)	<p><b>Honeywell</b> A3TL ZD5310PH082</p> <p><b>Honeywell</b> A3RL ZD2210PH0L4</p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Electronic Meter (AMI), Polyphase 4 Wire, 3 Element, Self-Contained 200A, 120-347V (Auto Ranging)</p> <p>7-Jaw Socket Base with Mass Memory</p> <p>7-Jaw Socket Base, Demand with Mass Memory</p> <p>7-Jaw Socket Base with External Antenna and Mass Memory</p> <p>7-Jaw Socket Base, Bidirectional Demand with Mass Memory</p>	<p>8-38-52 <b>5018111</b></p> <p>8-38-53 <b>5018122</b></p> <p>8-38-58 <b>5018123</b></p> <p>8-38-69 <b>5018124</b></p>	Form 16	<p><b>Honeywell</b> A3TL ZD3310PH082</p> <p><b>Honeywell</b> A3RL ZD3310PH0L4</p> <p><b>Honeywell</b> A3TL ZD3310PK082</p> <p><b>Honeywell</b> A3RAL ZD3310PH0LG</p>
<p>Electronic Meter (AMI), Polyphase 4 Wire, 3 Element, Self-Contained 200A, 120-347V (Auto Ranging)</p> <p>7-Jaw Socket Base, Demand with External Antenna and Mass Memory</p> <p>7-Jaw Socket Base, Demand with Special Multiplier x100 and Mass Memory</p> <p>7-Jaw Socket Base, Bidirectional Demand with External Antenna and Mass Memory</p>	<p>8-38-70 <b>5018125</b></p> <p>8-38-74 <b>5018118</b></p> <p>8-38-85 <b>5018119</b></p>	Form 16	<p><b>Honeywell</b> A3RL ZD3310PK0L4</p> <p><b>Honeywell</b> A3RL ZD3310PH0L4</p> <p><b>Honeywell</b> A3RAL ZD3310PK0LG</p>
<p>Electronic Meter (AMI), Polyphase 4 Wire, 2.5 Element, Transformer-Rated 10A, 120-480V (Auto Ranging)</p> <p>A-Base with Mass Memory</p> <p>A-Base with External Antenna and Mass Memory</p> <p>13-Jaw Socket Base, Demand with Mass Memory</p> <p>13-Jaw Socket Base, Bidirectional Demand with Mass Memory</p>	<p>8-39-02 <b>5018120</b></p> <p>8-39-08 <b>5018121</b></p> <p>8-39-53 <b>5018132</b></p> <p>8-39-69 <b>5018133</b></p>	Form 36	<p><b>Honeywell</b> A3TL ZD8B10PH082</p> <p><b>Honeywell</b> A3TL ZD8B10PK082</p> <p><b>Honeywell</b> A3RL ZD8210PH0L4</p> <p><b>Honeywell</b> A3RAL ZD8210PH0LG</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Electronic Meter (AMI), Polyphase 4 Wire, 2.5 Element, Transformer-Rated 10A, 120-480V (Auto Ranging)</p> <p>13-Jaw Socket Base, Demand with External Antenna and Mass Memory</p> <p>13-Jaw Socket Base, Demand with KYZ Pulse and Mass Memory</p> <p>13-Jaw Socket Base, Bidirectional Demand with External Antenna and Mass Memory</p>	<p>8-39-70 <b>5018126</b></p> <p>8-39-71 <b>5018134</b></p> <p>8-39-85 <b>5018127</b></p>	Form 36	<p><b>Honeywell</b> A3RL ZD8210PK0L4</p> <p><b>Honeywell</b> A3RL ZD3213P80L4</p> <p><b>Honeywell</b> A3RAL ZD8210P9KLG</p>
<p>Electronic Meter (Power Quality), Polyphase 3 Wire, 2 Element, Transformer-Rated 10A, 120-347V (Auto Ranging)</p> <p>Flush Mount, Demand with Mass Memory</p> <p>Flush Mount, Demand with Totalized Billing and Mass Memory</p>	<p>8-44-03 <b>5018128</b></p> <p>8-44-23 <b>5018135</b></p>	Form 5	<p><b>SCHNEIDER ELEC</b> ION7550</p> <p><b>SCHNEIDER ELEC</b> ION7650</p>
<p>Electronic Meter (Power Quality), Polyphase 4 Wire, 3 Element, Transformer-Rated 10A, 120-347V (Auto Ranging)</p> <p>Flush Mount, Demand with Mass Memory</p> <p>Flush Mount, Demand with Totalized Billing and Mass Memory</p> <p>13-Jaw Socket Base, Demand with Mass Memory</p>	<p>8-45-03 <b>5018136</b></p> <p>8-45-23 <b>5018129</b></p> <p>8-45-53 <b>5018130</b></p>	Form 9	<p><b>SCHNEIDER ELEC</b> ION7550</p> <p><b>SCHNEIDER ELEC</b> ION7650</p> <p><b>SCHNEIDER ELEC</b> ION8650</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
AMI Gatekeeper  with Ethernet, Battery, Local LAN Ant and Polycarbonate NEMA4x Enclosure  Modem Kit  Battery  Modem  698-2700 MHz LTE Low Profile Antenna	8-50-00 <b>5018131</b>  8-50-50 <b>5018137</b>  8-50-51 <b>5018138</b>  8-50-52 <b>5018170</b>  8-50-53 <b>5018142</b>		<b>HONEYWELL</b> EE1110021100  <b>HONEYWELL</b> 1C12599G01  <b>HONEYWELL</b>  <b>SIERRA WIRELESS</b>  <b>HONEYWELL</b> 3A35573H01
AMI Gatekeeper  NMP to N-RF Terminal Adapter  9" Antenna Cable (RX Diversity)  6" Antenna Cable (Primary Cellular)  20" Ethernet Cable  Modem Mount	8-50-54 <b>5018143</b>  8-50-55 <b>5018144</b>  8-50-56 <b>5018145</b>  8-50-57 <b>5018139</b>  8-50-58 <b>5018140</b>		<b>HONEYWELL</b> 3A35573H02  <b>HONEYWELL</b> 1B11954G01  <b>HONEYWELL</b> 1B11954G03  <b>HONEYWELL</b> 1B11989G02  <b>HONEYWELL</b> 1C12579H01
AMI Gatekeeper Electronic Assembly  Timekeeping Battery  Pure Lead Acid Battery  Ethernet Surge Protective Device  Power Supply/Lead Acid Battery Charger  Thermostat	8-50-59 <b>5018141</b>  8-50-60 <b>5018152</b>  8-50-61 <b>5018153</b>  8-50-62 <b>5018154</b>  8-50-63 <b>5018155</b>  8-50-64 <b>5018156</b>		<b>HONEYWELL</b> 5D25648G92  <b>HONEYWELL</b> 1A46869H01  <b>HONEYWELL</b> 3A35552H02  <b>HONEYWELL</b> 1B12506G03  <b>HONEYWELL</b> 3A35590H01  <b>HONEYWELL</b> 3A35589H02




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
AMI Gatekeeper  AC Power Fuses  Surge Protective Device  Heater  LAN RF Filter  LAN Antenna	8-50-65 <b>5018157</b>  8-50-66 <b>5018158</b>  8-50-67 <b>5018146</b>  8-50-68 <b>5018159</b>  8-50-69 <b>5018160</b>		HONEYWELL 7S1743H002  HONEYWELL 5D26081G01  HONEYWELL 3A35589H01  HONEYWELL 7S1735H002  HONEYWELL 7S1706H001
AMI Repeater  120V, Local LAN Antenna with NEMA4 enclosure  240V, Local LAN Antenna with NEMA4 enclosure  Solar with Mounting Bracket (15 Degrees)  DC, Internal or External Antenna without Battery and Regulator	8-51-00 <b>5018161</b>  8-51-01 <b>5018162</b>  8-51-02 <b>5018147</b>  8-51-03 <b>5018148</b>		HONEYWELL 7S40M0G006  HONEYWELL 7S40M0G002  HONEYWELL 7S40M0G003  HONEYWELL
AMI Repeater Solar Repeater Electronic Assembly Module  Solar Repeater Battery  Solar Repeater Controller  Solar Repeater Powered Meter Heads  Repeater Pole Mount Kit 10 7/8" to 13 3/4  Solar Repeater Powered Meter Heads	8-51-50 <b>5018163</b>  8-51-51 <b>5018164</b>  8-51-52 <b>5018149</b>  8-51-53 <b>5018150</b>  8-51-54 <b>5018151</b>  8-51-55 <b>5025027</b>	12V 3.2AH for AMI    internal antenna   external antenna	HONEYWELL 5D26170G54  Discover D1232  HONEYWELL 1B11886H01  HONEYWELL 7S40K0G001  HONEYWELL 7S1852G002  HONEYWELL 7S41R1G006



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>AMI Fieldsense</p> <p>CT-60 Dolphin Handheld, with MeterSense, Inspector and MeterCat Server</p> <p>RF Belt Clip</p> <p>Wireless OptoWave Bluetooth Wireless Optical Probe</p>	<p>8-52-00 <b>5018165</b></p> <p>8-52-50 <b>5018172</b></p> <p>8-52-51 <b>5018173</b></p>		<p><b>HONEYWELL</b></p> <p><b>HONEYWELL</b></p> <p><b>HONEYWELL</b></p>
<p>Meter Seal</p> <p><b>ROTO</b></p> <p>Tooled</p> <p>Tooleless</p>	<p>8-70-20 <b>5000975</b></p> <p>8-70-21 <b>5000976</b></p>	<p>4"x.014"x8" wire</p> <p>4"x.014"x8" wire</p>	<p><b>BRO</b> ROTO SEAL 7050801-27</p> <p><b>BRO</b> ROTO SEAL 7470801-27</p>
<p>Meter Seal</p> <p>Plastic:</p> <p>Black</p> <p>White</p> <p>Orange</p> 	<p>8-70-25 <b>5000977</b></p> <p>8-70-30 <b>5000978</b></p> <p>8-70-35 <b>5000979</b></p>	<p>Stamped C.O.S. 1</p> <p>Stamped C.O.S. 2</p> <p>Stamped C.O.S. 3</p>	<p><b>(Numbered Consecutively)</b> <b>BRO</b> 6302000-8-10 Model HL-8</p> <p><b>BRO</b> 6302000-8-10 Model HL-8</p> <p>Model HL-8</p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Padlock Seal White with Green</p> 	<p>8-70-40 <b>5000980</b></p>	<p>Stamped "SL&amp;P Illegal to Tamper"</p>	<p><b>BRO 8001-SL&amp;P</b></p>
<p>Meter Blankoff Cover Clear Polycarbonate</p>	<p>8-72-10 <b>5000981</b></p>		
<p>Handi-Ring Screw Type Stainless Steel</p> <p>Locking Barrel</p>  <p>Cap Seal for Locking Barrel</p> 	<p>8-73-00 <b>5000982</b></p> <p>8-73-10 <b>5000983</b></p> <p>8-73-15 <b>5000984</b></p>	<p>F Style Key</p>	<p><b>EKS 10-9090</b></p> <p><b>BRO 8730019</b></p> <p><b>BRO 9750000-1</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Adapter, Interbase Low Profile 4 Jaw	8-87-50 <b>5000985</b>		<b>EKS LP-4J</b>
Socket Adaptors  SSD 2W Single Phase Residential  SHD 3W Single Phase Residential  PTR K 3 Phase Trans Type  PTR N 3 Phase Trans Type	8-88-00 <b>5000986</b>  8-88-05 <b>5000987</b>  8-88-15 <b>5000989</b>  8-88-20 <b>5000990</b>	2 Wire, 120 Volt  3 Wire, 240 Volt  3 Wire, 120/240 Volt  4 Wire, Auto Range Voltage	<b>BRO 1300002</b>  <b>BRO 1300024</b>  <b>BRO 0820014</b>  <b>BRO 0820020</b>
Current Transformer - 600 Volt Class Type MV-7 3 Wire    ** Discontinued MV6's will be returned from the field.	8-91-20 <b>5000994</b>  8-91-30 <b>5000995</b>	200/200:5  300/300:5	







DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Current Transformer - 600 Volt Class Type MV-7 3 Wire</p>  <p>** Discontinued MV6's will be returned from the field.</p>	<p>8-91-40 <b>5000996</b></p> <p>8-91-50 <b>5000997</b></p> <p>8-91-60 <b>5000998</b></p> <p>8-91-80 <b>5000999</b></p>	<p>400/400:5</p> <p>500/500:5</p> <p>600/600:5</p> <p>800/800:5</p>	
<p>Current Transformer - 700 Volt Class Type MV-7 2 Wire</p> 	<p>8-92-10 <b>5001000</b></p> <p>8-92-20 <b>5001001</b></p> <p>8-92-30 <b>5001002</b></p> <p>8-92-40 <b>5001003</b></p> <p>8-92-50 <b>5001004</b></p>	<p>100:5</p> <p>200:5</p> <p>300:5</p> <p>400:5</p> <p>500:5</p>	
<p>Current Transformer 700 Volt Class Type MV-7 2 Wire</p>  <p>R6L c/w bar assembly</p>	<p>8-92-60 <b>5001005</b></p> <p>8-92-80 <b>5001006</b></p> <p>8-92-81 <b>5001007</b></p> <p>8-92-82 <b>5001008</b></p> <p>8-92-83 <b>5001009</b></p>	<p>600:5</p> <p>800:5</p> <p>1000:5</p> <p>1200:5</p> <p>2000:5</p>	<p><b>ITRON 9092356-729</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Current Transformer - 5 KV Class Type MV-50 2 Wire</p> 	<p>8-93-02 <b>5001010</b></p> <p>8-93-05 <b>5001011</b></p> <p>8-93-07 <b>5001012</b></p> <p>8-93-10 <b>5001013</b></p>	<p>25:5</p> <p>50:5</p> <p>75:5</p> <p>100:5</p>	
<p>Current Transformer - 5 KV Class Type MV-50 2 Wire</p> 	<p>8-93-15 <b>5001014</b></p> <p>8-93-20 <b>5001015</b></p> <p>8-93-30 <b>5001016</b></p> <p>8-93-50 <b>5001017</b></p>	<p>150:5</p> <p>200:5</p> <p>300:5</p> <p>500:5</p>	
<p>Current Transformer - 5 KV Class Type MV-50 Dual Ratio</p>	<p>8-93-53 <b>5001018</b></p>	<p>100/50:5</p>	

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Potential Transformer - 600 Volt Class Type MP-6 	8-94-36 <b>5001019</b>  8-94-60 <b>5001020</b>	360:120  600:120	
Potential Transformer - 5 KV Class	8-95-24 <b>5001021</b>	2400:120	
Potential Transformer - 15 KV Class   For Landfill - <b>NO SUBS</b>	8-96-08 <b>5001022</b>  8-96-14 <b>5001023</b>  8-96-18 <b>5001024</b>	8400:120  14400:120  14400:120	<b>WEST PT-15</b>  <b>GE PV15F</b>  <b>ABB 218D934A12</b> <b>NO SUBS</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Single Phase Dry Type Transformer - 600 - 120/240V</p> <p>Single Phase Epoxy Filled 600 - 120/240V Used in Vaults</p> <p>Three Phase 600 - 240V Delta Nema 3 Enclosure</p> <p>Three Phase 600 - 120/208V Nema 3 Enclosure</p>	<p>8-96-25 <b>5001025</b></p> <p>8-96-36 <b>5001026</b></p> <p>8-96-74 <b>5001027</b></p> <p>8-96-75 <b>5001028</b></p>	<p>25 KVA</p> <p>37 KVA</p> <p>75 KVA</p> <p>75 KVA</p>	<p><b>FER-P</b></p> <p><b>MARC RES37.5A2</b></p> <p><b>BEM UC3075S240DD</b> Nema 3R</p> <p><b>BEM UC3075V</b> Nema 3R</p>
<p>Test Block Single Phase</p> 	<p>8-97-01 <b>5001029</b></p>		<p><b>States Co.</b> 80K04-A</p>
<p>Test Block - Three Phase</p> <p>Three Wire</p> 	<p>8-97-03 <b>5001030</b></p>		<p><b>SANG 909501</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Test Block - Three Phase</p> <p>Four Wire</p> 	<p>8-97-06 <b>5001486</b></p>	<p>Screw Type Compression Terminal</p>	<p><b>MESURINA 909762</b></p>
<p>Primary Metering Unit Three Phase Dry Type</p> 	<p>8-98-10 <b>5001031</b></p>	<p>14400/8320 Primary 200/100:5 Current</p>	<p><b>ABB CMU33-110 SPEC 1510</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Rigid Two Hole Pipe Strap 	9-04-31 <b>5001032</b>  9-04-32 <b>5001033</b>  9-04-33 <b>5001034</b>  9-04-34 <b>5001035</b>	1/2"  3/4"  1"  1 1/4"	
Rigid Two Hole Pipe Strap 	9-04-35 <b>5001036</b>  9-04-36 <b>5001037</b>  9-04-37 <b>5001038</b>  9-04-38 <b>5001039</b>	1 1/2"  2"  3"  4"	
Pyrotenax Clip 	9-05-01 <b>5001040</b>  9-05-02 <b>5001041</b>  9-05-03 <b>5001042</b>	426/465  396/425  346/387 2 Way	



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Galvanized Pipe 	9-09-03 <b>5001043</b>	2" x 21'	
HDPE Pipe	9-10-06 <b>5001044</b>	50 mm (2")	<b>Specification 2412</b>
Corrugated Pipe Grey  For UG Cart & Contractors	9-10-10 <b>5001045</b>  9-10-11 <b>5017526</b>	2" Corrugated 2000 Foot Reel  2" Corrugated 500 Foot Reel	<b>Specification 2415</b>  <b>Specification 2415</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
HDPE Pipe	9-10-15 <b>5001047</b>	100 mm (4")	<b>Specification 2412</b>
	9-10-16 <b>5001048</b>	125 mm (5")	<b>Specification 2412</b>
Duct Pipe PVC DB2	9-10-25 <b>5001049</b>	4" 20' Lengths	
	9-10-26 <b>5001050</b>	5" 20' Lengths	
Bend for PVC DB2 Duct Pipe 4" Flared End	9-11-04 <b>5001051</b>	90 Degree 24" Radius	<b>IPEX 129047</b>
	9-11-06 <b>5001052</b>	90 Degree 36" Radius	<b>IPEX 129095</b>
	9-11-10 <b>5017523</b>	11 1/4 Degree 60" Radius	<b>Custom</b> Made to Order
	9-11-12 <b>5001054</b>	22 1/2 Degree 60" Radius	<b>Custom</b> Made to Order
	9-11-14 <b>5001055</b>	45 Degree 60" Radius	<b>IPEX 129116</b>
	9-11-16 <b>5001056</b>	90 Degree 60" Radius	<b>IPEX 129096</b>







DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Bend for PVC DB2 Duct Pipe 5" Flared End	9-11-22 <b>5001057</b>	22 1/2 Degree 42" Radius	<b>IPEX 129249</b>
	9-11-24 <b>5001058</b>	45 Degree 42" Radius	<b>IPEX 129117</b>
	9-11-26 <b>5001059</b>	90 Degree 42" Radius	<b>IPEX 129097</b>
Bend for PVC Sched 40 4"	9-11-42 <b>5001499</b>	30 Degree 16" Radius	<b>IPEX 69250</b>
	9-11-44 <b>5001500</b>	45 Degree 16" Radius	<b>IPEX 69210</b>
	9-11-46 <b>5001501</b>	90 Degree 16" Radius	<b>IPEX 69090</b>
	9-11-48 <b>5001502</b>	90 Degree 36" Radius	<b>IPEX NSL 4-36</b>
Bend for PVC Sched 40 5"	9-11-52 <b>5001503</b>	30 Degree 24" Radius	<b>IPEX 69251</b>
	9-11-54 <b>5001504</b>	45 Degree 24" Radius	<b>IPEX 69211</b>
	9-11-56 <b>5001505</b>	90 Degree 24" Radius	<b>IPEX 69091</b>
	9-11-58 <b>5001506</b>	90 Degree 36" Radius	<b>IPEX 69263</b>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Bellend for PVC DB2 Duct Pipe	9-12-00 <b>5001060</b>	4" Flared	<b>IPEX 029064</b> (Bell 40) <b>NO SUBS</b>
	9-12-01 <b>5001061</b>	4" Flared c/w Knockout Plug	<b>IPEX 029827</b>
	9-12-20 <b>5001062</b>	5" Flared	<b>IPEX 029065</b> (Bell 50) <b>NO SUBS</b>
Plug for Bellend	9-13-00 <b>5001063</b>	4" Use with 9-12-00	<b>IPEX 029078</b>
	9-13-20 <b>5001064</b>	5" Use with 9-12-20	<b>IPEX 029079</b>
Coupling for DB2 Duct/PVC Sched 40/ Corrugated Pipe    	9-14-02 <b>5023438</b> 9-14-04 <b>5001065</b> 9-14-05 <b>5001066</b> 9-14-06 <b>5001067</b> 9-14-07 <b>5001068</b> 9-14-08 <b>5001069</b> 9-14-09 <b>5001070</b> 9-14-10 <b>5001071</b> 9-14-11 <b>5001072</b>	2" Plastic Coupler  1 1/2" (Rubber)  2" (Rubber)  1 1/2" - 2" (Rubber)  2" (Threaded)  2" (Corrugated) Complete with threading 2" PVC Sched 40  4" PVC DB2  4" Thin to Thick Wall	<b>DL ARN 20000123</b>  <b>Fernco 1056-150</b>  <b>Fernco 1056-22</b>  <b>Fernco MR56-215</b>  <b>CG 08566540</b>  <b>ETCO DEL-237</b>  <b>IPEX 077006</b>   <b>IPEX 29184</b> 4" ARLG Duct-Conduit


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Coupling for DB2 Duct/PVC Sched 40/ Corrugated Pipe	9-14-12 <b>5001073</b> 9-14-15 <b>5001074</b> 9-14-18 <b>5001075</b> 9-14-20 <b>5001076</b> 9-14-21 <b>5001077</b> 9-14-22 <b>5001078</b> 9-14-40 <b>5001507</b> 9-14-50 <b>5001508</b>	4" 5 Degree Bend  5" - 4" Reducing  5" 5 Degree Bend  5" PVC  5" Thin to Thick Wall  5" Rubber  4" PVC Sched 40  5" PVC Sched 40	<b>IPEX 029044</b>  <b>IPEX 029026</b>  <b>IPEX 029045</b>       <b>IPEX 077010</b>  <b>IPEX 077011</b>
Spacer for PVC DB2 Duct Pipe  	9-15-01 <b>5001079</b>          9-15-02 <b>5001080</b>	Base 4" x 1 1/2"          Intermediate 4" x 1 1/2"	<b>IPEX 029573</b> <b>No Alternate Supplier</b> <b>Unless Approved</b>          <b>IPEX 029557</b> <b>No Alternate Supplier</b> <b>Unless Approved</b>
Spacer for PVC DB2 Duct Pipe  	9-15-20 <b>5001081</b>          9-15-22 <b>5001082</b>          9-15-30 <b>5001083</b>          9-15-32 <b>5001084</b>	Base 5" x 1 1/2"          Intermediate 5" x 1 1/2"          Base 5"x 2"          Intermediate 5"x 2"	<b>IPEX 029576</b> <b>No Alternate Supplier</b> <b>Unless Approved</b>          <b>IPEX 029560</b> <b>No Alternate Supplier</b> <b>Unless Approved</b>          <b>IPEX 029577</b>          <b>IPEX 029561</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Expansion Joints for PVC Rigid Conduit	9-16-02 <b>5001085</b>	2"	<b>SCEP EJ35</b>
	9-16-04 <b>5001086</b>	4"	<b>SCEP EJ55</b>
	9-16-05 <b>5001087</b>	5"	<b>IPEX EJ60</b>
PVC Duct Primer	9-18-01 <b>5001088</b>	950 ml	<b>SCEP S100TQT</b>
PVC Duct Cement	9-18-10 <b>5001089</b>	950 ml	<b>SCEP S100QT</b>
PVC To HD Polywater Bonduit	9-18-20 <b>5001090</b>		<b>BT-KITB6</b>
Sceptacon Pipe	9-20-22 <b>5001091</b>	2" x 20 FT 1900 FT/Lift	<b>IPEX 106421</b>
	9-20-41 <b>5001092</b>	4" x 10 FT 540 FT/Lift	<b>IPEX 106440</b>
	9-20-42 <b>5001093</b>	4" x 20 FT 1080 FT/Lift	<b>IPEX 106441</b>
	9-20-51 <b>5001094</b>	5" x 10 FT 380 FT/Lift	<b>IPEX 106450</b>
	9-20-52 <b>5001095</b>	5" x 20 FT 760 FT/Lift	<b>IPEX 106451</b>





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Sceptacon Locking Strap	9-21-02 <b>5001096</b>	2" Pipe	<b>IPEX</b>
	9-21-04 <b>5001097</b>	4" Pipe	<b>IPEX</b>
	9-21-05 <b>5001098</b>	5" Pipe	<b>IPEX</b>
Sceptacon Repair Kit Conduit Rigid & DB2  Sceptacon Adapter Kit Conduit Rigid to DB2	9-21-14 <b>5001099</b>	4" Conduit EPR55	<b>IPEX 077957</b>
	9-21-15 <b>5001100</b>	5" Conduit EPR60	<b>IPEX 077956</b>
	9-21-24 <b>5001101</b>	4" Conduit EPRA55	<b>IPEX 077854</b>
	9-21-25 <b>5001102</b>	5" Conduit EPRA60	<b>IPEX 077855</b>
Drop In Anchor  	9-30-06 <b>5001103</b>  9-30-08 <b>5001104</b>  9-30-09 <b>5001105</b>	<b>NO SUBS</b>  1/4" Bolt Size  3/8" Bolt Size  1/2" Bolt Size	Anchor Products Power Fasteners  6304SD  6306SD  6308SD

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Single Phase Capacitor Unit Single Bushing 2400 V, No Rack</p> 	<p>9-31-10 <b>5001106</b></p> <p>9-31-20 <b>5001107</b></p>	<p>100 KVAR</p> <p>200 KVAR</p>	<p><b>GE 54L221RC5</b> <b>Specification 6</b></p> <p><b>Specification 6</b></p>
<p>Single Phase Capacitor Unit Double Bushing 14.4 KV, No Rack</p> 	<p>9-32-10 <b>5001108</b></p> <p>9-32-20 <b>5001109</b></p>	<p>100 KVAR</p> <p>200 KVAR</p>	<p><b>GE 54L383RC41</b> <b>Specification 8</b></p> <p><b>Specification 8</b></p>
<p>Single Phase Capacitor Unit Double Bushing 14.4 KV, No Rack</p> 	<p>9-33-10 <b>5001110</b></p> <p>9-33-20 <b>5001111</b></p>	<p>100 KVAR</p> <p>200 KVAR</p>	<p><b>GE 37V54L383WC48</b> <b>Specification 2</b></p> <p><b>GE 17V58L400WC59</b> <b>Specification 2</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Three Phase Capacitor Bank 4160 V, c/w Rack</p> 	<p>9-34-30 <b>5001112</b></p> <p>9-34-60 <b>5001113</b></p>	<p>300 KVAR</p> <p>600 KVAR</p>	<p><b>GE 2V33F4130BA3</b> <b>Specification 5</b></p> <p><b>Specification 5</b></p>
<p>Three Phase Capacitor Bank 14.4 KV c/w Rack</p>	<p>9-35-50 <b>5001114</b></p> <p>9-35-60 <b>5001115</b></p> <p>9-35-70 <b>5001116</b></p>	<p>300 KVAR</p> <p>600 KVAR</p> <p>1200 KVAR</p>	<p><b>Specification 1</b></p> <p><b>Specification 1</b></p> <p><b>GE 36F3144-1</b> <b>Specification 1</b></p>
<p>Three Phase Capacitor Bank 25 KV, c/w Rack</p>	<p>9-36-60 <b>5001117</b></p>	<p>600 KVAR</p>	<p><b>Specification 7</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Master Padlock 	9-38-05 <b>5001118</b>  9-38-07 <b>5001119</b>  9-38-08 <b>5001120</b>	#3 Smaller  #1  #1 Long Shank	<b>Keyed to 3543</b>  <b>Keyed to 3543</b>  <b>Keyed to 3543</b> <b>Master 1KALJ</b>
Padlocks  High Line Switch       Substations/Landfill Gas	9-38-14 <b>5001121</b>      9-38-16 <b>5026403</b>	1" Shackle       2 1/2" Shackle	<b>American Lock</b> Series 3700 #A3700Y  <b>Keyed to A25444</b>      <b>Master Lock</b> Pro Series 7042  <b>Keyed to TA41</b>
Padlock For Metering Equipment  	9-38-20 <b>5001122</b>   9-38-25 <b>5001123</b>	3" Shackle   1 1/2" Shackle	<b>Brooks 4920571</b>   <b>Brooks 4920541</b>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Bandit</p> 	<p>9-40-04 <b>5001124</b></p> <p>9-40-06 <b>5001125</b></p>	<p>3/4" Stainless Steel</p> <p>3/4" Black</p>	<p><b>BAND C20699</b></p> <p><b>BAND C206C9-P900</b></p>
<p>Bandit Buckles</p> 	<p>9-41-04 <b>5001126</b></p> <p>9-41-06 <b>5001127</b></p>	<p>3/4" Stainless Steel</p> <p>3/4" Black</p>	<p><b>BAND C25699</b></p> <p><b>BAND C25699-D900</b></p>
<p>Heater Cabinet</p>  <p>Submersible Pump for Vaults 1/3 HP</p> 	<p>9-50-80 <b>5001128</b></p> <p>9-51-00 <b>5023010</b></p>	<p>800W 120V C/W Thermostat</p>	<p>Little Giant 506254</p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Grounding Ferrules - Plain Type	9-60-01 <b>5001129</b>	2/0	<b>AB C600-2632</b>
	9-60-02 <b>5001130</b>	4/0	<b>AB C600-2633</b>
Grounding Ferrules - Threaded Shrouded Type	9-61-01 <b>5001131</b>	2/0 Copper	<b>AB C600-2624</b>
	9-61-03 <b>5001132</b>	Copper Tin Plated 2/0	<b>MACP 01-M-038-2/0</b>
Shrink Tubing for Ferrules	9-61-12 <b>5001133</b>	9"	<b>AB P600-2069P</b> <b>HA P50349-9</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Clamps - Ground	9-62-01 <b>5001134</b>	#6 - 950 MCM	<b>AB C600-0434</b>
Clamps - Plain Eye Screw Switch	9-63-01 <b>5001135</b>	3/4" x 1/8" flat - 2 1/2" x 1/4" flat	<b>MP 01-M-037</b> No Substitutions
Stud - Clamp Support	9-64-01 <b>5001136</b>  9-64-03 <b>5001137</b>	2 1/2"  1"	<b>AB G3626</b>  <b>MACP HC-30029-1</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Grounding Cable	9-65-01 <b>5001138</b>	Yellow Jacket 2/0	AB S6118
	9-65-02 <b>5001139</b>	Yellow Jacket 4/0	AB S6119
Ty-Wraps - White 	9-70-05 <b>5001140</b>	5" x .14" 100/pk	T&B TY24M
	9-70-07 <b>5001141</b>	7" x .19" 100/pk	T&B TY25M
	9-70-11 <b>5001142</b>	11" x .19" 100/pk	T&B TY253M
	9-70-13 <b>5001143</b>	13" x .27" 50/pk	T&B TY27M
	9-70-14 <b>5001144</b>	14" x .14" 100/pk	T&B TY244M
Ty-Wraps - Black 	9-71-05 <b>5001145</b>	5" x .14" 100/pk	T&B TY24MX
	9-71-07 <b>5001146</b>	7" x .19" 100/pk	T&B TY25MX
	9-71-11 <b>5001147</b>	11" x .19" 100/pk	T&B TY253MX
	9-71-13 <b>5001148</b>	13" x .27" 50/pk	T&B TY27MX
	9-71-14 <b>5001149</b>	14" x .14" 100/pk	T&B TY244MX
	9-71-30 <b>5001150</b>	30" x .27" FOR BANNERS 50/pk	T&B TY29M0 T&B TY29MX WURTH 553.59010




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Overhead Cable Support</p> <p>Ty-Wraps</p>  <p>Spacer</p> 	<p>9-72-00 <b>5001151</b></p> <p>9-72-05 <b>5001152</b></p>	<p>50 Per Bag</p> <p>250 Per Bag</p>	<p><b>T&amp;B CSS-135</b></p> <p><b>T&amp;B CSS-360</b></p>
<p>Cinch Tie with Grommet</p> 	<p>9-75-12 <b>5001153</b></p>	<p>12" 10/pk</p>	<p><b>PAND UGCTC3S-XO</b></p>
<p>Locate Flags - For Buried Cable</p> <p>Locate Paint - Red Marking Paint</p>	<p>9-80-00 <b>5001155</b></p> <p>9-80-10 <b>5026014</b></p>	<p>Red 500/bundle</p> <p>Red 12/case</p>	<p>Harvest Community</p> <p><b>Aervoe 261</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Gloves HV Class 0 14"	9-90-10	SZ 10	
	<b>5001156</b>		
	9-90-11	SZ 11	
	<b>5001157</b>		
	9-90-12	SZ 12	
	<b>5001158</b>		
	9-90-15	SZ 10.5	
	<b>5001159</b>		
	9-90-70	SZ 7.0	
	<b>5001160</b>		
	9-90-80	SZ 8.0	
	<b>5001161</b>		
	9-90-85	SZ 8.5	
	<b>5001162</b>		
9-90-90	SZ 9.0		
<b>5001163</b>			
9-90-95	SZ 9.5		
<b>5001164</b>			
Gloves HV Class 1 16"	9-91-10	SZ 10	
	<b>5001165</b>		
	9-91-11	SZ 11	
	<b>5001166</b>		
	9-91-12	SZ 12	
	<b>5001167</b>		
	9-91-15	SZ 10.5	
	<b>5001168</b>		
	9-91-70	SZ 7.0	
	<b>5001169</b>		
	9-91-80	SZ 8.0	
	<b>5001170</b>		
	9-91-85	SZ 8.5	
	<b>5001171</b>		
9-91-90	SZ 9.0		
<b>5001172</b>			
9-91-95	SZ 9.5		
<b>5001173</b>			
Gloves HV Class 2 16"	9-92-10	SZ 10	
	<b>5001174</b>		
	9-92-11	SZ 11	
	<b>5001175</b>		
	9-92-12	SZ 12	
	<b>5001176</b>		
	9-92-15	SZ 10.5	
	<b>5001177</b>		
	9-92-70	SZ 7.0	
	<b>5001178</b>		
	9-92-80	SZ 8.0	
	<b>5001179</b>		
	9-92-85	SZ 8.5	
	<b>5001180</b>		
9-92-90	SZ 9.0		
<b>5001181</b>			
9-92-95	SZ 9.5		
<b>5001182</b>			


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Gloves HV Class 3 18"	9-93-10	SZ 10	
	<b>5001183</b>		
	9-93-11	SZ 11	
	<b>5001184</b>		
	9-93-12	SZ 12	
	<b>5001185</b>		
	9-93-15	SZ 10.5	
	<b>5001186</b>		
	9-93-70	SZ 7.0	
	<b>5001187</b>		
	9-93-80	SZ 8.0	
<b>5001188</b>			
9-93-85	SZ 8.5		
<b>5001189</b>			
9-93-90	SZ 9.0		
<b>5001190</b>			
9-93-95	SZ 9.5		
<b>5001191</b>			
Mitts HV Class 2 16"	9-94-10	SZ 10	
	<b>5001192</b>		
	9-94-11	SZ 11	
<b>5001193</b>			
9-94-90	SZ 9.0		
<b>5001194</b>			
Mitts HV Class 3 18"	9-95-10	SZ 10	
	<b>5001195</b>		
	9-95-11	SZ 11	
<b>5001196</b>			
9-95-90	SZ 9.0		
<b>5001197</b>			

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
FR Shirts Pullover - Men's  	10-05-02 <b>5020369</b>  10-05-04 <b>5020370</b>  10-05-06 <b>5020356</b>  10-05-08 <b>5020371</b>  10-05-10 <b>5020357</b>  10-05-12 <b>5020358</b>	Small  Medium  Large  XL  2XL  3XL	<b>MWG 61x18</b>
FR Shirts Pullover - Men's  	10-05-14 <b>5020359</b>  10-05-16 <b>5020372</b>  10-05-18 <b>5020373</b>  10-05-20 <b>5020361</b>  10-05-22 <b>5020374</b>	Medium Tall  Large Tall  XL Tall  2XL Tall  3XL Tall	<b>MWG 61x18</b>
FR Shirts Pullover - Women's  	10-06-02 <b>5020375</b>  10-06-04 <b>5020552</b>  10-06-06 <b>5020383</b>  10-06-08 <b>5020376</b>  10-06-10 <b>5020384</b>  10-06-12 <b>5020377</b>	Small  Medium  Large  XL  2XL  3XL	<b>Rasco FR9637</b>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>FR Shirts Buttoned - Men's</p> 	<p>10-07-02 <b>5020385</b></p> <p>10-07-04 <b>5020386</b></p> <p>10-07-06 <b>5020387</b></p> <p>10-07-08 <b>5020388</b></p> <p>10-07-10 <b>5020378</b></p> <p>10-07-12 <b>5020379</b></p>	<p>Small</p> <p>Medium</p> <p>Large</p> <p>XL</p> <p>2XL</p> <p>3XL</p>	<p><b>Rasco FR6536OH</b></p>
<p>FR Shirts Buttoned - Men's</p> 	<p>10-07-14 <b>5020389</b></p> <p>10-07-16 <b>5020390</b></p> <p>10-07-18 <b>5020380</b></p> <p>10-07-20 <b>5020381</b></p> <p>10-07-22 <b>5020391</b></p>	<p>Medium Tall</p> <p>Large Tall</p> <p>XL Tall</p> <p>2XL Tall</p> <p>3XL Tall</p>	<p><b>Rasco FR6536OH</b></p>
<p>FR Shirts Buttoned - Women's</p> 	<p>10-08-02 <b>5020392</b></p> <p>10-08-04 <b>5020402</b></p> <p>10-08-06 <b>5020393</b></p> <p>10-08-08 <b>5020403</b></p> <p>10-08-10 <b>5020394</b></p> <p>10-08-12 <b>5020395</b></p>	<p>Small</p> <p>Medium</p> <p>Large</p> <p>XL</p> <p>2XL</p> <p>3XL</p>	<p><b>Rasco FR9536OH</b></p>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
FR Work Pants - Men's  	10-09-02 <b>5020396</b>  10-09-04 <b>5020397</b>  10-09-06 <b>5020398</b>  10-09-08 <b>5020405</b>  10-09-10 <b>5020399</b>  10-09-12 <b>5020400</b>	30"  32"  34"  36"  38"  40"	<b>Rasco</b> FR4133NV
FR Work Pants - Men's  	10-09-14 <b>5020406</b>  10-09-16 <b>5020401</b>  10-09-18 <b>5020412</b>  10-09-20 <b>5020407</b>  10-09-22 <b>5020413</b>	42"  44"  46"  48"  50"	<b>Rasco</b> FR4133NV
FR Work Pants - Women's  	10-10-00 <b>5020414</b>  10-10-02 <b>5020415</b>  10-10-04 <b>5020416</b>  10-10-06 <b>5020417</b>  10-10-08 <b>5020418</b>  10-10-10 <b>5020419</b>	0 (25-26")  2 (26-27")  4 (27-28")  6 (28-29")  8 (29-30")  10 (30-31")	<b>Bulwark</b> QP11-NV-NVY




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
FR Work Pants - Women's  	10-10-12 <b>5020420</b>  10-10-14 <b>5020421</b>  10-10-16 <b>5020422</b>  10-10-18 <b>5020423</b>  10-10-20 <b>5020424</b>  10-10-22 <b>5020408</b>	12 (31-32½")  14 (32½-34")  16 (34-35½")  18 (35½-37½")  20 (37½ - 39½")  22 (39½ - 41½")	<b>Bulwark</b> QP11-NV-NVY
Bulwark Sizing Chart - Woman's			




**LFC-02 — ALPHA/NUMERIC CONVERSION CHART — WOMEN'S MEASUREMENTS**




	XS		S		M		L		XL		XXL		3XL		4XL		
Size	0	2	4	6	8	10	12	14	16	18	20	22	24	26	28	30	32
Bust	32-33	33-34	34-35	35-36	36-37	37-38	38-39½	39½-41	41-42½	42½-44½	44½-46½	46½-48½	48½-50½	50½-52½	52½-54½	54½-56½	56½-58½
Waist	25-26	26-27	27-28	28-29	29-30	30-31	31-32½	32½-34	34-35½	35½-37½	37½-39½	39½-41½	41½-43½	43½-45½	45½-47½	47½-49½	49½-51½
Hip	34½-35½	35½-36½	36½-37½	37½-38½	38½-39½	39½-40½	40½-42	42-43½	43½-45	45-47	47-49	49-51	51-53	53-55	55-57	57-59	59-61




Height: **Petite:** 4'11"-5'3" **Regular:** 5'3½"-5'7" **Tall:** 5'7½"-5'11"




FR Cargo Pants - Men's  	10-11-02 <b>5020409</b>  10-11-04 <b>5020425</b>  10-11-06 <b>5020410</b>  10-11-08 <b>5020433</b>  10-11-10 <b>5020434</b>  10-11-12 <b>5020442</b>	30"  32"  34"  36"  38"  40"	<b>Rasco</b> FR4403NV

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
FR Cargo Pants - Men's  	10-11-14 <b>5020435</b>  10-11-16 <b>5020555</b>  10-11-18 <b>5020437</b>  10-11-20 <b>5020443</b>  10-11-22 <b>5020444</b>	42"  44"  46"  48"  50"	<b>Rasco FR4403NV</b>
FR Cargo Pants - Women's  	10-12-00 <b>5020438</b>  10-12-02 <b>5020445</b>  10-12-04 <b>5020446</b>  10-12-06 <b>5020447</b>  10-12-08 <b>5020448</b>	0  2  4  6  8	<b>Rasco FR8403NV</b>
FR Cargo Pants - Women's  	10-12-10 <b>5020453</b>  10-12-12 <b>5020454</b>  10-12-14 <b>5020455</b>  10-12-16 <b>5020456</b>  10-12-18 <b>5020449</b>	10  12  14  16  18	<b>Rasco FR8403NV</b>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>FR Unlined Coveralls</p> 	<p>10-15-36 <b>5020450</b></p> <p>10-15-38 <b>5020451</b></p> <p>10-15-40 <b>5020462</b></p> <p>10-15-42 <b>5020457</b></p> <p>10-15-44 <b>5020458</b></p> <p>10-15-46 <b>5020459</b></p>	<p>36</p> <p>38</p> <p>40</p> <p>42</p> <p>44</p> <p>46</p>	<p><b>Rasco FR8005OH</b></p>
<p>FR Unlined Coveralls</p> 	<p>10-15-48 <b>5020463</b></p> <p>10-15-50 <b>5020464</b></p> <p>10-15-52 <b>5020465</b></p> <p>10-15-54 <b>5020460</b></p>	<p>48</p> <p>50</p> <p>52</p> <p>54</p>	<p><b>Rasco FR8005OH</b></p>
<p>FR Unlined Coveralls</p> 	<p>10-16-40 <b>5020466</b></p> <p>10-16-42 <b>5020467</b></p> <p>10-16-44 <b>5020468</b></p> <p>10-16-46 <b>5020469</b></p> <p>10-16-48 <b>5020461</b></p>	<p>40 Tall</p> <p>42 Tall</p> <p>44 Tall</p> <p>46 Tall</p> <p>48 Tall</p>	<p><b>Rasco FR8005OH</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>FR Unlined Coveralls</p> 	<p>10-16-50 <b>5020472</b></p> <p>10-16-52 <b>5020473</b></p> <p>10-16-54 <b>5020470</b></p>	<p>50 Tall</p> <p>52 Tall</p> <p>54 Tall</p>	<p><b>Rasco FR8005OH</b></p>
<p>FR Unlined Bib Overalls</p> 	<p>10-17-02 <b>5020474</b></p> <p>10-17-04 <b>5020471</b></p> <p>10-17-06 <b>5020482</b></p> <p>10-17-08 <b>5020483</b></p> <p>10-17-10 <b>5020475</b></p> <p>10-17-12 <b>5020484</b></p>	<p>Small</p> <p>Medium</p> <p>Large</p> <p>XL</p> <p>2XL</p> <p>3XL</p>	<p><b>MWG 80E33</b></p>
<p>FR Unlined Bib Overalls</p> 	<p>10-17-14 <b>5020476</b></p> <p>10-17-16 <b>5020477</b></p> <p>10-17-18 <b>5020485</b></p> <p>10-17-20 <b>5020486</b></p> <p>10-17-22 <b>5020487</b></p>	<p>Medium Tall</p> <p>Large Tall</p> <p>XL Tall</p> <p>2XL Tall</p> <p>3XL Tall</p>	<p><b>MWG 80E33</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>FR Lined Bib Overalls</p> 	<p>10-18-02 <b>5020488</b></p> <p>10-18-04 <b>5020489</b></p> <p>10-18-06 <b>5020478</b></p> <p>10-18-08 <b>5020490</b></p> <p>10-18-10 <b>5020491</b></p> <p>10-18-12 <b>5020492</b></p>	<p>Small</p> <p>Medium</p> <p>Large</p> <p>XL</p> <p>2XL</p> <p>3XL</p>	<p><b>IFR 525</b></p>
<p>FR Lined Bib Overalls</p> 	<p>10-18-14 <b>5020480</b></p> <p>10-18-16 <b>5020502</b></p> <p>10-18-18 <b>5020503</b></p> <p>10-18-20 <b>5020493</b></p> <p>10-18-22 <b>5020494</b></p> <p>10-18-24 <b>5020551</b></p>	<p>4XL</p> <p>Large Tall</p> <p>XL Tall</p> <p>2XL Tall</p> <p>3XL Tall</p> <p>4XL Tall</p>	<p><b>IFR 525</b></p>
<p>FR Hooded Fleece</p> 	<p>10-20-02 <b>5020496</b></p> <p>10-20-04 <b>5020504</b></p> <p>10-20-06 <b>5020505</b></p> <p>10-20-08 <b>5020497</b></p> <p>10-20-10 <b>5020498</b></p> <p>10-20-12 <b>5020499</b></p>	<p>Small</p> <p>Medium</p> <p>Large</p> <p>XL</p> <p>2XL</p> <p>3XL</p>	<p><b>Rasco FR7119OH</b></p>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
FR Winter Jacket 	10-22-02 <b>5020506</b>  10-22-04 <b>5020500</b>  10-22-06 <b>5020507</b>  10-22-08 <b>5020501</b>  10-22-10 <b>5020512</b>  10-22-12 <b>5020535</b>	Small  Medium  Large  XL  2XL  3XL	<b>IFR 515</b>
FR Winter Jacket 	10-22-14 <b>5020513</b>  10-22-16 <b>5020514</b>  10-22-18 <b>5020508</b>  10-22-20 <b>5020515</b>  10-22-22 <b>5020509</b>  10-22-24 <b>5020510</b>	4XL  Large Tall  XL Tall  2XL Tall  3XL Tall  4XL Tall	<b>IFR 515</b>
FR Rain Overalls 	10-25-02 <b>5020511</b>  10-25-04 <b>5020516</b>  10-25-06 <b>5020522</b>  10-25-08 <b>5020536</b>  10-25-10 <b>5020524</b>  10-25-12 <b>5020517</b>	Small  Medium  Large  XL  2XL  3XL	<b>Lakeland ABPU10</b>  <b>Lakeland ABPU11</b>  <b>Lakeland ABPU12</b>  <b>Lakeland ABPU13</b>  <b>Lakeland ABPU14</b>  <b>Lakeland ABPU15</b>







DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>FR Rain Overalls</p> 	<p>10-25-14 <b>5020518</b></p> <p>10-25-16 <b>5020525</b></p>	<p>4XL</p> <p>5XL</p>	<p><b>Lakeland ABPU16</b></p> <p><b>Lakeland ABPU16</b></p>
<p>FR Rain Jackets</p> 	<p>10-26-02 <b>5020526</b></p> <p>10-26-04 <b>5020519</b></p> <p>10-26-06 <b>5020529</b></p> <p>10-26-08 <b>5020520</b></p> <p>10-26-10 <b>5020521</b></p> <p>10-26-12 <b>5020532</b></p>	<p>Small</p> <p>Medium</p> <p>Large</p> <p>XL</p> <p>2XL</p> <p>3XL</p>	<p><b>Lakeland AJPU10</b></p> <p><b>Lakeland AJPU11</b></p> <p><b>Lakeland AJPU12</b></p> <p><b>Lakeland AJPU13</b></p> <p><b>Lakeland AJPU14</b></p> <p><b>Lakeland AJPU15</b></p>
<p>FR Balaclava - Warm Weather</p> <p>FR Balaclava - Cold Weather</p> <p>FR Neck Gaiter</p> <p>FR Hard Hat Liner</p> <p>FR Toque</p>	<p>10-30-10 <b>5020533</b></p> <p>10-30-20 <b>5020534</b></p> <p>10-30-30 <b>5020530</b></p> <p>10-30-40 <b>5020531</b></p> <p>10-30-50 <b>5020542</b></p>	<p>O/S</p> <p>O/S</p> <p>O/S</p>	<p><b>Rasco BBC2</b></p> <p><b>Rasco WL2004B</b></p> <p><b>Rasco FR9142GY</b></p>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<b>SERVICE ITEMS</b> Oil Filter 	<b>5024235</b> <b>11-01-10</b>	ELEMENT AS Standard Efficiency	<b>CAT 1R-0726 (no subs)</b>
Oil Temperature Regulator	<b>5026673</b> <b>11-01-15</b>		<b>CAT 7W-0371 (no subs)</b>
Air Filter 	<b>5024238</b> <b>11-01-20</b>	Axial Seal Primary Standard Efficiency	<b>CAT 8N-6309 (no subs)</b>
CCV Intake Filter 	<b>5024239</b> <b>11-01-25</b>	Radial Seal Primary Standard Efficiency	<b>CAT 2W-4246 (no subs)</b>
Spark Plug 	<b>5024270</b> <b>11-01-30</b>	#4	<b>DENSO GI3-5 #4</b> <b>CAT 243-4291</b>




DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Fuel Train Filter 	5024271 11-01-40	28" x 5.1 " (ID)	PARKER 7CVP51-280
CCV Coalescing Filter 	5024327 11-01-45	38.62" x 4.2"	FLUTEK FLK 16-02358 HILCO DM639-00-C
Oil 	5024329 11-01-50	1 Barrel/ Drum SAE 40	CHEVRON LFG40 HDAX 9500
SCAs 	5024240 11-01-55	5 Gallon Pail	CAT 8C-3680 (no subs)
Natural Gas Coolant 	5024257 11-01-60	1 Barrel/ Drum Premix 50/50	CAT 339-3778 (no subs)

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Oil Sample Kit	<b>5024330</b> <b>11-01-65</b>	Natural Gas Engine Package	<b>AGAT LABS 30-402</b> (no subs)
Oil Sample Cap & Probe 	<b>5025632</b> <b>11-01-67</b>	Cap & Probe	<b>CAT 177-9343</b>
Coolant Sample Kit	<b>5024258</b> <b>11-01-70</b>		<b>CAT 320271114 (no subs)</b>
Oil Sampling Cap 	<b>5024261</b> <b>11-01-90</b>		<b>CAT 8C-3445 (no subs)</b>
<b>GENERAL SENSORS</b> Thermocouple 	<b>5024262</b> <b>11-02-10</b>	Type K PYROC/ W 24" SS Braid 1/4" probe 1/4" tube OD x 1/4" MNPT SS tube fitting Male	<b>ADV 5601-092-28</b> <b>CAT 383-2989</b> Swagelok





DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Timing Sensor 	5024263 11-02-30	Hex size 1.25" Thread size 3/8" - 16 13 VDC	CAT 522-1642 (no subs)
<b>OIL SYSTEM</b> Pre-lube Breaker 	5024265 11-03-10	30A	CAT 6N-9349 (no subs)
Oil Filter O-Ring 	5024266 11-03-30		CAT 6V-3907 (no subs)
CCV Boot 	5024280 11-03-50		CAT 217-6692
Pre-lube Pump	5024281 11-03-70		CAT 598-6002

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<b>IGNITION SYSTEM</b> Transformer Ignition Coil 	<b>5024282</b> <b>11-04-10</b>	CAT 232-6346 changes up to CAT 418-4861	<b>CAT 418-4861</b>
Umbrella (Garter) Spring 	<b>5026311</b> <b>11-04-12</b>	Free Length: 127.20mm	<b>CAT 316-4262</b>
Transformer Connector Body 	<b>5024283</b> <b>11-04-20</b>		<b>CAT 155-2270</b> <b>Gregg's Distributing</b> <b>763325B</b>
Transformer Gasket 	<b>5024284</b> <b>11-04-30</b>	ID: 36.2 mm/ OD: 46 mm/ Height: 7.25 mm/ Width: 4.94 mm	<b>CAT 135-2651</b>
Transformer/Umbrella Spring O-Ring 	<b>5024285</b> <b>11-04-40</b>	Material: FKM/ ID: 0.546" OD: 0.824" Cross Section Diameter: 0.139"	<b>CAT 125-1372</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>Lower O-Ring</p> 	<p><b>5024286</b> <b>11-04-50</b></p>	<p>Material: FKM/ ID: 0.468"/ OD: 0.624"/ Cross Section Diameter:0.078"</p>	<p><b>CAT 451-8550</b></p>
<p>Upper O-Ring</p> 	<p><b>5024287</b> <b>11-04-60</b></p>	<p>Material: FFKM/ ID: 0.546"/ OD: 0.824"/ Cross Section Diameter: 0.139"</p>	<p><b>CAT 187-3875</b></p>
<p>Transformer Insulator Extension</p> 	<p><b>5024288</b> <b>11-04-70</b></p>	<p>Spark Plug Extension with O-ring Seal ID: 0:59" Thread Size: 3/8-16 Old Style: CAT 116-7649 with CAT 5P-6718 O-Ring</p>	<p><b>CAT 437-4043</b></p>
<p>Insulator O-Ring</p> 	<p><b>5026315</b> <b>11-04-72</b></p>	<p>75A FKM 5.33 x 75.57mm</p>	<p><b>CAT 6V-5051</b></p>
<p>Knock Sensor</p> 	<p><b>5024289</b> <b>11-04-80</b></p>	<p>Old p/n: CAT 163-4411</p>	<p><b>CAT 574-8678</b></p>






DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p><b>COOLANT SYSTEM</b> Exhaust Fan Belt</p> 	<p><b>5024332</b> <b>11-05-01</b></p>	<p>B-74</p>	<p>Generic</p>
<p>Exhaust Fan Bearings</p>	<p><b>5024333</b> <b>11-05-05</b></p>	<p>1-7/16" Pillow Block Bearing</p>	<p><b>MOTION INDUSTRIES</b> <b>SO 1-7/16 PILLOW</b> <b>BLOCK</b></p>
<p>EJW Flex Inlet/ Outlet</p> 	<p><b>5024334</b> <b>11-05-10</b></p>	<p>5: X 15.5" Assembly Stainless Steel Flex 1-5" CAT Flange 1-5" X 150 lb Raised Face Flange</p>	<p><b>FLEXONICS/ 5" x 16"</b> <b>OAL MODEL 101</b> <b>CAT FLG x S/O FLG</b></p>
<p>EJW Flex Gasket Engine Side</p> 	<p><b>5024290</b> <b>11-05-14</b></p>	<p>8-Bolt</p>	<p><b>CAT 1S-5772</b></p>
<p>EJW Flex Gasket Outlet Side</p>	<p><b>5024335</b> <b>11-05-18</b></p>	<p>5" - 150 PSI Raised Face Flange Gasket</p>	<p>Generic</p>













DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
<p>A/C Flex</p> 	<p><b>5024336</b> <b>11-05-20</b></p>	<p>3" X 16" Assembly Stainless Steel Flex X 150 lbs Steel Flat Face Flange</p>	<p><b>FLEXONICS</b> H-SS101-061FF061FF-048-0016.00</p>
<p>Gasket Flange 3" Full Face for A/C Flex</p>	<p><b>5024337</b> <b>11-05-25</b></p>	<p>3" - 150 PSI Raised Face Flange Gasket</p>	<p><b>GARLOCK</b> #37721-5103</p>
<p>Element</p> 	<p><b>5024338</b> <b>11-05-35</b></p>	<p>12 KW Element for CSM31205-000</p>	<p><b>HOTSTART SALES</b> RECSM31205</p>
<p>Contactora</p> 	<p><b>5024339</b> <b>11-05-40</b></p>		<p><b>HOTSTART SALES</b> PRP232117-000</p>
<p>Water Pump</p> 	<p><b>5024292</b> <b>11-05-45</b></p>	<p>Book out with Water Pump Gasket Kit Part: <b>5024313</b> <b>11-05-70</b></p>	<p><b>CAT 10R-1669</b></p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Aux. Pump 	5024293 11-05-50	Book out with Parts: 5024294 5024295 5024296 5024297 5024298 5024299 5024300 5026317	CAT 20R-8813
Water Temperature Regulator 	5026317 11-05-52	Length: 3.6" Height: 2.8"	CAT 204-6708
Rad Fan Motor	5024340 11-05-55	2 HP 1180RPM 3-phase 575V 60hz Shaft: 1 1/8" Bearings: DE6206 ODE 6205 Frame Size 184T	GENERIC - Any supplier can match specs
Fan Motor Bearings - Front 	5024341 11-05-60	Front	MOTION INDUSTRIES 6207LLUC3
Fan Motor Bearings - Rear 	5024342 11-05-65	Rear	MOTION INDUSTRIES 6206VVCE


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Water Pump Gasket Kit	<b>5024313</b> <b>11-05-70</b>		CAT 304-7216
<b>ORDER ALL O-RINGS AND GASKETS WITH AUX. PUMP (CAT 20R-8813)</b>			
Auxiliary Water Pump - O-Ring 1  	<b>5024294</b> <b>11-05-71</b>	Material: NBR/ ID: 3.975"/ OD: 4.395"/ Cross Section Diameter: 0.21"	CAT 4F-7387
Auxiliary Water Pump - O-Ring 2  	<b>5024295</b> <b>11-05-72</b>	Material: FKM/ ID: 0.725"/ OD: 1.145"/ Cross Section Diameter: 0.21"	CAT 6V-3348
Auxiliary Water Pump - O-Ring 3  	<b>5024296</b> <b>11-05-73</b>	Material: FKM/ ID: 9.234"/ OD: 9.512"/ Cross Section Diameter: 0.139"	CAT 235-3546
Auxiliary Water Pump - O-Ring 4  	<b>5024297</b> <b>11-05-74</b>	Material: EPDM/ ID: 2.475"/ OD: 2.895"/ Cross Section Diameter: 0.21"	CAT 8T-1919

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Auxiliary Water Pump - Gasket 1 	<b>5024298</b> <b>11-05-81</b>	Material: NMF Rubber ID: 1.50"/ OD: 2.60" Thickness: 0.06" Hole Size: 0.41" (2X) Distance between flange holes: 2.61"	<b>CAT 5N-1940</b>
Auxiliary Water Pump - Gasket 2 	<b>5024299</b> <b>11-05-82</b>	Material: Sheet Overall Length: 116 mm Overall Width: 116 mm	<b>CAT 3P-6061</b>
Auxiliary Water Pump - Gasket 3 	<b>5024300</b> <b>11-05-83</b>	Material: Sheet ID: 4.25" Length: 3.24" Width: 3.24" Thickness: 0.03" Hole Size: 0.41"(4X)	<b>CAT 5G-1442</b>
<b>TURBO EXHAUST</b> Turbo Insert Cartridge 	<b>5024301</b> <b>11-06-10</b>	Book out with parts: <b>5024305</b> <b>5024306</b> <b>5024307</b> <b>5024308</b> <b>5024870</b>	<b>CAT 0R-6968</b>
Wastegate (Exhaust Bypass Valve) 	<b>5024302</b> <b>11-06-20</b>		<b>CAT 20R-7167</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Gasket (Turbo Exhaust) 	<b>5024303</b> <b>11-06-30</b>	Overall Width: 83 mm Overall Length: 88 mm	<b>CAT 7C-9710</b>
Locknut 	<b>5024304</b> <b>11-06-40</b>	410 Stainless Steel Thread size: 3/8 - 16 Height: 0.37" Drive: 9/16" Flange Diameter: 0.71"	<b>CAT 168-7800</b>
<b>ORDER ALL O-RINGS AND GASKETS WITH TURBO INSERT CARTRIDGE (CAT 0R-6968)</b>			
Turbo Insert Cartridge - O-Ring 	<b>5024305</b> <b>11-06-50</b>	Material: FKM ID: 0.91" Cross Section Diameter: 0.21"	<b>CAT 5P-9890</b>
Turbo Insert Cartridge - Gasket 1 	<b>5024306</b> <b>11-06-60</b>	Overall Width: 38 mm Overall Length: 72 mm	<b>CAT 1S-4810</b>
Turbo Insert Cartridge - Gasket 2 	<b>5024307</b> <b>11-06-70</b>	Overall Width: 28 mm Overall Length: 66 mm	<b>CAT 1S-6595</b>


DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Turbo Insert Cartridge - Gasket 3 	<b>5024308</b> <b>11-06-80</b>	Overall Width: 47 mm Overall Length: 78 mm	<b>CAT 252-8374</b>
Turbo Insert Cartridge - Intake to Manifold Gasket 	<b>5024870</b> <b>11-06-90</b>	Overall Width: 127 mm Overall Length: 127 mm	<b>CAT 7L-4302</b>
<b>FUEL TRAIN</b> Fuel Mixer Boot 	<b>5024343</b> <b>11-07-10</b>	6-7" Transition Boot	<b>INTAKE HOSES 7H6</b> (509) 489-3684, Spokane WA
Fuel Solenoid Valve 	<b>5024344</b> <b>11-07-20</b>	DUNGS VPS-S04-505 DMV-D(LE) 5100/11 4" 150 Flanged	<b>DUNGS VPS-S04-505</b>
Fuel Alarm Modules - HP 	<b>5024345</b> <b>11-07-30</b>	High Pressure Old p/n: 217-089A	<b>DUNGS 266918</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Fuel Alarm Modules - LP 	<b>5024349</b> 11-07-35	Low Pressure Old p/n: 217-088A	<b>DUNGS 266917</b>
Fuel Regulator 	<b>5024350</b> 11-07-40	FISHER 1098 EGR - Must be ordered by s/n: 20342127	<b>SPARTAN</b>
Fuel Regulator 1098 Repair Diaphragm & O-Rings	<b>5024351</b> 11-07-45	Kit for FISHER 1098 EGR	<b>Spartan Controls</b> <b>#R1098X00402</b>
Fuel Regulator Repair Pilot Valve Kit	<b>5026675</b> 11-07-47	Kit for FISHER 1098 EGR	<b>Spartan Controls</b> <b>#R6352X00012</b>
Fuel Regulator Repair Gasket Kit	<b>5026677</b> 11-07-49	Kit for FISHER 1098 EGR	<b>Spartan Controls</b> <b>#R63EGX00122</b>

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Fuel Flame Arrestor Element	<p><b>5024362</b> 11-07-50</p>	<p>Emerson Varec 4" Model: 501041 S/N: 1214930</p>	<p>FISHER ____ ?</p>
Fuel Flame Arrestor Gasket	<p><b>5024363</b> 11-07-55</p>		<p>FISHER ____ ?</p>
<p><b>GENERAL ENGINE</b> Head - New</p> 	<p><b>5024364</b> 11-08-10</p>	<p>New</p>	<p>CAT 20R-9943</p>
Head - Rebuild	<p><b>5024365</b> 11-08-12</p>	<p>Rebuild</p>	<p>TAZMECH (no exceptions)</p>
Head Gasket Kit	<p><b>5024309</b> 11-08-20</p>		<p>CAT 597-3813</p>



DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Cylinder Pack	<p style="text-align: center;"><b>5024310</b> 11-08-40</p>		CAT 0R-7700
Connecting Rod Bearings 	<p style="text-align: center;"><b>5024311</b> 11-08-60</p>		CAT 107-7330
Starter 	<p style="text-align: center;"><b>5024312</b> 11-08-80</p>		CAT 10R-9815 or local starter shops
<b>ENGINE CONTROLS</b> Valve - Engine Control 	<p style="text-align: center;"><b>5024366</b> 11-09-10</p>	New	<b>HEINZMANN</b> GMCU-85-LC Can be rebuilt
Actuator 	<p style="text-align: center;"><b>5024367</b> 11-09-20</p>	New	<b>HEINZMANN</b> STG-2080.21 Can be rebuilt

DESCRIPTION OF ITEM	DEPT. CODE NUMBER	SIZE	ORDERING INFORMATION
Governor	<p><b>5024368</b> <b>11-09-30</b></p>	PANDAROS DC6	<p><b>HEINZMANN</b> <b>PANDAROS DC6</b></p>
MAP Sensor 	<p><b>5024369</b> <b>11-09-40</b></p>		<p><b>BOSCH O-281-002-437</b> <b>ADVANTAGE</b> <b>GOVERNOR 600-00-082-</b> <b>00</b></p>
Crank Position Sensor	<p><b>5024370</b> <b>11-09-50</b></p>		<p><b>ADVANTAGE</b> <b>GOVERNOR</b> <b>600-00-006-02</b></p>